



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number DPCC/W/STP/24-25/314/1703

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2025

Dated 09/04/2025

1. Name of STP : Rohini
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 04.03.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	15	Inlet	7.3	234	125	272	18.8	10.8	10.5		Meeting the standards.
		Outlet	7.8	6	4	32	0.8	0.9	0.6	81	
		OLMS	7.5	9.0	6.5	78.7	-	3.3	-	-	
Total 15											

I/C Water Laboratory

Dr. Shweta Gupta

Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/24-25/315/1704

Dated 09/04/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2025

1. Name of STP : Narela
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 04.03.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	10	Inlet	6.5-9.0	10	10	50	10	5	2	230	Meeting the standards.
			7.6	292	160	460	16.8	9.7	9.6	-	
		Outlet	7.5	7	6	28	0.4	0.4	0.4	62	
		OLMS	7.8	7.7	5.0	22.5	-	1.6	-	-	
Total 10											

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/316/1705

Dated 09/04/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2025

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of sampling : 17.03.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Fecal Coliform MPN/100ml	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
1	Ph-I, II (20)	Inlet	7.5	252	150	312	16.4	11.7	10.2	-	Meeting the standards.
		Outlet	7.2	9	8	36	0.8	1.3	0.7	180	
		OLMS	7.6	7.2	5.2	21.2	-	1.5	-	-	
		Inlet	7.1	276	167	360	15.2	11.4	11.8	-	
2	Ph-III (10)	Outlet	7.6	8	6	28	1.6	1.2	0.5	79	Meeting the standards.
		OLMS	7.6	6.5	4.1	19.4	-	1.1	-	-	
		Total 30									

Dr. Shweta Gupta
Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/317/1706

Dated 09/04/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2025

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of sampling : 17.03.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	70 MGD	Inlet	7.3	228	140	392	14.4	9.7	10.9	-	Meeting the standards.
		Outlet	7.2	7	5	24	1.6	0.7	0.8	64	
		OLMS	7.3	7.0	5.1	24.9	-	1.9	-	-	
Total 70											

I/C Water Laboratory

Shweta Gupta

Dr. Shweta Gupta
Incharge (Water Laboratory)

SSA/Analyst

Shweta Gupta



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/318/1707

Dated 09/04/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2025

1. Name of STP : Keshopur STP (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 17.03.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	12	Inlet	7.9	262	180	428	14	12.6	11.5	-	Meeting the standards.
		Outlet	7.5	9	10	44	0.8	0.9	0.7	140	
		OLMS	-	-	-	-	-	-	-	-	
Total 12											OLMS was non-functional

I/C Water Laboratory

Dr. Shweta Gupta

Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/319/1708

Dated 09/04/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2025

1. Name of STP : Keshopur
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 17.03.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	40	Inlet	7.7	240	120	312	19.2	11.2	11.9	-	Not meeting the Standards wrt TSS & Fecal Coliform.
		Outlet	7.4	13	8	32	1.6	1.3	0.3	1400	
		OLMS	-	-	-	-	-	-	-	-	
		Outlet	7.2	24	14	60	1.2	0.7	0.4	1800	
2	20	OLMS	-	-	-	-	-	-	-	-	Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform.
Total 60											OLMS was non functional

I/C Water Laboratory

Dr. Shweta Gupta

Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/320/1309

Dated 09/04/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2025

1. Name of STP : Yamuna Vihar Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 18.03.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	25	Inlet	7.5	280	160	360	16.8	10.7	9.6	-	Not meeting the Standards wrt TSS, BOD, COD & fecal coliform.
		Outlet	7.1	25	16	60	1.2	0.8	0.8	1600	
		OLMS	7.7	19.3	50.2	16.0	-	27.8	-	-	
Total 25											

I/C Water Laboratory

Dr. Shweta Gupta

Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocemms.nic.in>)



Report Number: DPCC/W/STP/24-25/321/1710

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2025

Dated 09/04/2025

1. Name of STP : Yamuna Vihar
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 18.03.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results:

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	10 Ph-1	Inlet	7.6	264	140	408	13.2	9.6	9.8	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform
		Outlet	7.7	26	12	64	1.2	0.7	0.5	920	
		OLMS	7.4	26.0	18.4	93.6	-	11.2	-	-	
		Inlet	7.2	226	150	336	16.4	9.6	8.3	-	
2	10 Ph-2	Outlet	7.8	14	8	48	0.8	0.6	0.6	79	Not meeting the standards wrt TSS
		OLMS	7.3	11.4	10.0	25.4	-	10.9	-	-	
Total 20											

I/C Water Laboratory

Dr. Shweta Gupta

Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/24-25/322/1711

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2025

Dated 09/04/2025

1. Name of STP : Sonia Vihar
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 18.03.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	7	Inlet	6.5-9.0 7.5	10 256	10 140	50 380	10 12	5 9.8	2 9.8	230 -	Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.2	34	15	76	1.2	0.6	0.7	350	
		OLMS	7.0	9.3	7.3	36.7	-	6.0	-	-	
Total 7											

I/C Water Laboratory

Dr. Shweta Gupta

Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmmms.nic.in>)



Report Number: DPCC/W/STP/24-25/323/1712

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2025

Dated 09/04/2025

1. Name of STP : Okhla
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 25.03.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
16		Inlet	7.6	230	160	432	13.2	11.8	10.3	-	Not meeting the Standards wrt TSS, BOD & Fecal coliform.
		Outlet	8.1	24	14	48	2.4	0.7	0.9	1600	
		OLMS	7.5	11.2	6.1	38.6	-	6.2	-	-	
Total 16											

I/C Water Laboratory

Dr. Shweta Gupta

Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/24-25/324/1713

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2025

Dated 09/04/2025

1. Name of STP : Okhla
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 25.03.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	124 MGD	Inlet	6.5-9.0 7.6	10 230	10 160	50 432	10 13.2	5 11.8	2 10.3	-	Not meeting the Standards wrt TSS, BOD & COD & Fecal coliform. OLMS Not installed
		Outlet	7.9	42	16	72	1.2	0.8	0.8	920	
		OLMS	-	-	-	-	-	-	-	-	
Total 124											

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccnms.mtc.in>)



Report Number: DPCC/W/STP/24-25/325/1714

Dated 09/04/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2025

1. Name of STP : Okhla New
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 25.03.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	30	Inlet	7.6	290	90	292	20.4	8.4	10.1	-	Not meeting the Standards w/t BOD & COD.
		Outlet	7.9	10	12	52	1.6	0.8	0.4	13	
		OLMS	7.6	6.5	4.7	24.0	-	1.5	-	-	
Total 30											

I/C Water Laboratory

Dr. Shweta Gupta

Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/326/1715

Dated 09/04/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2025

1. Name of STP : Molarband (Mini STP)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 25.03.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	0.66	Inlet	7.6	118	96	388	15.6	12.1	9.3	-	Not meeting the standard wrt TSS, BOD, COD & Fecal Coliform. OLMS was non functional
		Outlet	8	35	39	144	0.8	1.2	1.0	2400	
		OLMS	-	-	-	-	-	-	-	-	
Total 0.66											

I/C Water Laboratory

Dr. Shweta Gupta

Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/24-25/327/1716

Dated 09/04/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2025

1. Name of STP : Delhi Gate (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 28.03.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results :											Remarks
S. No.	Installed Capacity (MGD)	STP Standard	Parameters								
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	Phase-I & II (15)	Inlet	7.3	176	150	340	17.6	11.6	10.7	-	Meeting the standards.
		Outlet	7.3	5	6	24	1.2	0.9	0.6	130	
		OLMS	7.4	6.6	2.7	22.5	-	4.0	-	-	
Total 15											

I/C Water Laboratory

Dr. Shweta Gupta

Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocms.nic.in>)



Report Number: DPCC/W/STP/24-25/328/1717

Dated 09/04/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2025

1. Name of STP : Delhi Gate (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 28.03.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	Ph-I & II (2.2)	Inlet	7.5	276	140	372	12.4	9.2	9.5	-	Meeting the standards.
		Outlet	7.8	6	6	28	0.8	0.8	0.6	170	
		OLMS	7.3	3.0	2.6	16.4	-	1.5	-	-	
Total 2.2											

I/C Water Laboratory

Dr. Shweta Gupta

Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocoms.nic.in>)



Report Number: DPCC/W/STP/24-25/329/1718

Dated 09/04/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2025

1. Name of STP : SEN Nursing Home (SNH)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 28.03.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and Results:											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	Phase-I,II (2.2)	Inlet	6.5-9.0	10	10	50	10	5	2	230	Meeting the Standards.
			7.4	212	160	468	15.2	8.9	8.9	-	
		Outlet	7.2	9	8	36	1.6	0.9	0.7	95	
		OLMS	8.0	6.0	5.5	23.1	-	1.8	-	-	
Total 2.2											

I/C Water Laboratory

SSA/Analyst

Dr. Shweta Gupta
Incharge (Water Laboratory)



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/24-25/330/1719

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2025

Dated 09/04/2025

1. Name of STP : Akshardham
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 28.03.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	1	Inlet	7.2	410	220	500	18	10.7	9.9	-	Not meeting the Standard wrt BOD, COD & Fecal Coliform.
		Outlet	7.8	8	12	64	1.2	0.8	0.5	900	
		OLMS	7.5	0.8	1.7	6.7	-	0.3	-	-	
Total 1											

I/C Water Laboratory

Dr. Shweta Gupta

Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocemms.nic.in>)



Report Number: DPCC/W/STP/24-25/331/1720

Dated 09/04/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2025

1. Name of STP : Chilla
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 28.03.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results:

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		Fecal Coliform MPN/100ml
1	9	Inlet	7.2	240	120	352	13.6	10.2	12.2	-	Not meeting the Standard wrt Fecal Coliform.
		Outlet	7.7	8	10	36	1.6	0.8	0.9	1300	
		OLMS	7.7	7.9	5.3	31.6	-	5.4	-	-	
Total 9											

I/C Water Laboratory

Dr. Shweta Gupta

Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocms.nic.in>)



Report Number: DPCC/W/STP/24-25/332/1721

Dated 09/04/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2025

1. Name of STP : Kondli New
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 28.03.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	Ph-IV (45)	Inlet	7.2	176	240	544	17.2	9.1	10.1	-	Not meeting the Standard wrt TSS BOD, COD & Fecal Coliform.
		Outlet	7.5	12	12	52	2	0.9	0.6	4600	
		OLMS	-	-	-	-	-	-	-	-	
Total 45											OLMS was non functional.

I/C Water Laboratory

Dr. Shweta Gupta

Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/333/1722

Dated 09/04/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2025

1. Name of STP : Kondli
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 28.03.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)		Fecal Coliform MPN/100ml
1	Ph-I (10)	Inlet	7.3	356	190	432	12.8	9.8	9.8	-	Not meeting the Standard wrt TSS & Fecal Coliform
		Outlet	7.5	18	8	32	1.6	0.7	0.7	9200	
		OLMS	7.6	9.3	13.6	42.2	-	4.1	-	-	
2	Ph-II & III (25+10)	Outlet	7.6	10	14	48	1.2	0.7	0.5	5400	Not meeting the Standard wrt BOD & Fecal Coliform. OLMS was non-functional.
		OLMS	-	-	-	-	-	-	-	-	
Total 45											

[Signature]

I/C Water Laboratory
Dr. Shweta Gupta

Incharge (Water Laboratory)

SSA/Analyst

[Signature]



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocemms.nic.in>)



Report Number: DPCC/W/STP/24-25/334/1723

Dated 09/04/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2025

1. Name of STP : Nilothi
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 28.03.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters											Remarks
Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	40	Inlet	7.3	500	225	628	14.4	10.6	9.1	-	Not meeting the standards wrt TSS & Fecal Coliform.
		Outlet	7.1	13	10	32	0.8	0.9	0.7	720	
		OLMS	8.0	27.8	15.8	123	-	9.4	-	-	
Total 40											

I/C Water Laboratory
Dr. Shweta Gupta

Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocoms.nic.in>)



Report Number: DPCC/W/STP/24-25/335/1724

Dated 09/04/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2025

1. Name of STP : Nilothi New
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 28.03.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	20	Inlet	7.8	348	215	484	20.8	11.6	9.3	-	Not meeting the Standard wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.7	16	28	68	1.2	0.5	0.4	1600	
		OLMS	7.4	5.8	3.8	37.0	-	4.5	-	-	
Total 20											

Shweta

I/C Water Laboratory
Dr. Shweta Gupta

Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number DPCC/W/STP/24-25/336/1725

Dated 09/04/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2025

1. Name of STP : Najafgarh
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 28.03.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Fecal Coliform MPN/100ml	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)			
1	5	Inlet	6.5-9.0	10	10	50	10	5	2	230	Not meeting the Standard wrt BOD & Fecal Coliform.	
		7.2	460	225	628	20	9.1	8.3	-			
		Outlet	7.9	6	12	48	0.8	0.7	0.9	490		
		OLMS	7.9	10.7	9.7	33.8	-	3.0	-	-		
Total 5												

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/337/1726

Dated 09/04/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2025

1. Name of STP : Pappankalan (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 28.03.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	20	Inlet	7.8	540	210	616	19.2	9.7	8.6	-	Not meeting the Standards wrt TSS & Fecal Coliform.
		Outlet	7.3	32	8	48	1.2	0.8	0.8	9200	
		OLMS	7.6	13.6	8.3	58.2	-	5.5	-	-	
Total 20											

I/C Water Laboratory
Dr. Shweta Gupta

Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/338/1723

Dated 09/04/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2025

1. Name of STP : Pappankalan Ph-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 28.03.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
20		Inlet	6.5-9.0	10	10	50	10	5	2	230	Meeting the standards.
		Outlet	7.8	540	210	616	19.2	9.7	8.6	-	
		OLMS	7.4	8	10	40	1.6	0.9	0.5	150	
		OLMS	7.6	8.2	6.2	36.2	-	1.9	-	-	
Total 20											

I/C Water Laboratory

Dr. Shweta Gupta

Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/24-25/339/1728

Dated 09/04/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2025

1. Name of STP : Kapasahera
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 31.03.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results:

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	5	Inlet	7.5	442	235	632	18.4	9.1	10.9	-	Not meeting the Standard wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.2	51	34	104	0.8	1.3	1.2	3500	
		OLMS	7.5	8.7	5.4	40.1	-	3.8	-	-	
Total 5											

I/C Water Laboratory
Dr. Shweta Gupta

Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/340/1729

Dated 09/04/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2025

1. Name of STP : Vasant Kunj
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 31.03.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	2.2	Inlet	7.8	524	105	356	16.8	10.1	10.5	-	Not meeting the standards wrt TSS, BOD & Fecal Coliform.
		Outlet	7.2	24	16	48	2	1.1	0.5	9200	
		OLMS	7.0	10.0	6.6	32.7	-	6.3	-	-	
		Inlet	7.6	480	215	604	16.4	10.7	9.9	-	
2	3	Outlet	7.3	27	14	48	1.6	0.9	0.8	24000	Not meeting the standards wrt TSS, BOD & Fecal Coliform.
		OLMS	6.5	7.3	4.9	35.0	-	6.1	-	-	
		Total 5.2									

Shweta Gupta

I/C Water Laboratory
Dr. Shweta Gupta

Incharge (Water Laboratory)

SSA/Analyst

Shweta Gupta



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocems.nic.in>)



Report Number: DPCC/W/STP/24-25/341/1730

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2025

Dated 09/04/2025

1. Name of STP : Ghitorini
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 31.03.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	5	Inlet	7.6	460	225	640	18	10.1	10.1	-	Not meeting the Standards wrt TSS, BOD & Fecal Coliform.
		Outlet	7.1	14	12	40	1.2	0.8	0.8	24000	
		OLMS	7.6	28.2	18.7	71.7	-	6.9	-	-	
Total 5											

I/C Water Laboratory

Dr. Shweta Gupta

Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/342/1731

Dated 09/04/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2025

1. Name of STP : Mehrauli
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 31.03.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	15	Inlet	7.8	440	215	804	15.6	10.2	9.5	-	Not meeting the standards wrt TSS, BOD & Fecal Coliform.
		Outlet	7.2	26	16	48	2	0.8	0.6	2400	
		OLMS	6.9	8.2	7.3	41.1	-	14.6	-	-	
Total 15											

[Signature]

I/G Water Laboratory
Dr. Shweta (Water Laboratory)
Incharge

SSA/Analyst

[Signature]



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/313/1702

Dated: 09/04/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2025

1. Name of STP : Rithala
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 04.03.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters									Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml		
1	Ph-I(40)	Inlet	6.5-9.0	10	10	50	10	5	2	230	Meeting the standards	
		Outlet	7.6	256	160	388	21.2	9.3	8.9	-		
		OLMS	7.1	9	8	36	0.8	0.9	0.5	72		
		OLMS	7.6	7.6	5.7	27.6	-	2.8	-	-		
2	Ph-II(40)	Inlet	7.4	282	180	448	19.2	5.9	8.1	-	Meeting the standards	
		Outlet	7.7	8	6	28	0.4	1.1	0.7	110		
		OLMS	7.6	9.8	6.5	38.2	-	5.5	-	-		
		Total 80										

I/C Water Laboratory

Dr. Shweta Gupta

Incharge (Water Laboratory)

SSA/Analyst