

DELHI POLLUTION CONTROL COMMITTEE (Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/06 | 2762

Dated 11/12/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2020

1. Name & Address of Ind./Unit : Molarband Mini STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 12.11.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	0.66	Inlet	7.4	468	295	640	34.4	36.4	6.8	Not meeting the Standards w.r.t TSS, BOD, COD.
		Outlet	7.4	30	22	76	2.8	3.6	1.6	
		OLMS*	7.35	27.26	16.36	45.68	-	3.16	-	
Total 0.66										

N. Mitta
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/440

2763

dated 11/11/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2020

1. Name & Address of Ind./Unit : DELHI GATE STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 03.11.2020
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	Phase I,II(2.2)	Inlet	6.8	124	60	164	14.4	17.6	6.6	Meeting the Standards.
		Outlet	6.9	4	2	12	0.4	1.2	0.2	
		OLMS*	5.76	8.03	5.02	12.19	-	2.3	-	
Total 2.2										

M. Mitta
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/441

2767

Dated 11/11/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2020

1. Name & Address of Ind./Unit : Delhi Gate STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 03.11.2020
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	Phase-I,II(15)	Inlet	6.6	68	40	96	12.0	14.2	5.8	Meeting the Standards.
		Outlet	6.8	8	6	28	0.8	1.6	0.4	
		OLMS*	7.48	3.68	7.36	38.17	-	1.86	-	
Total 15										

N. Mittal
I/C LABORATORY

SR. Scientific Assistant
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/442

2765

dated 11/14/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2020

1. Sampling location : Inlet and Outlet of STP
2. Name & Address of Ind./Unit : SEN Nursing Home (SNH)
3. Date of Inspection : 03.11.2020
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	Phase-I,II (2.2)	Inlet	6.9	168	95	240	19.6	22.3	6.8	Meeting the Standards.
		Outlet	7.0	6	4	16	0.4	1.6	0.3	
		OLMS*	6.12	8.34	3.0	17	-	1.30	-	
Total 2.2										

N. Mehta
I/C LABORATORY

P. S. Arora
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE (Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/443 / 2766

Date 11/11/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2020

1. Name & Address of Ind./Unit : Akshardham STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 03.11.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	AmmonicalNitr ogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	1	Inlet	7.1	176	110	260	16.4	17.8	5.4	Meeting the Standards.
		Outlet	7.0	4	2.4	16	0.4	0.6	0.1	
		OLMS*	7.6	0.87	1.56	9.56	-	0.2	-	
Total 1										
Remarks: OLMS was not working.										

Remarks: OLMS was not working.

Mishra
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/444

12767

Dated 11/11/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2020


1. Name & Address of Ind./Unit : Chilla STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 04.11.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters and Test Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	9	Inlet	6.8	108	65	144	12.4	13.6	6.0	Meeting the Standards.
		Outlet	6.9	10	7	28	0.8	1.6	0.4	
		OLMS*	7.23	6.01	4.01	20.16	-	1.31	-	
Total 9										

I-Increase & D-Decrease


I/C LABORATORY


SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/445

2768

Dated 11/14/20

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2020


1. Name & Address of Ind./Unit : Kondli STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 04.11.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Annual Test Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	45	Inlet	7.0	212	165	412	20.4	22.3	6.7	Not Meeting the Standards w.r.t TSS, BOD & COD.
		Outlet	7.1	64	36	96	2.0	4.2	1.3	
		OLMS*	-	-	-	-	-	-	-	
Total 45										

Remarks: OLMS was found locked

N. Mishra
I/C LABORATORY

SR. Scientific Assistant
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/446

2769

dated 11/12/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2020

1. Name & Address of Ind./Unit : Kondli STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 04.11.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Remarks
				10	10	50	10	5	2	
1	25	Inlet	7.2	256	190	472	26.4	29.4	7.6	Not meeting the Standards w.r.t TSS, BOD, COD .
		Outlet	7.3	24	14	56	0.4	2.8	0.3	
		OLMS*	7.59	22.09	6.80	37.87	-	1.53	-	
Total 25										

M. K. Mittal
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/447 / 2770

dated 11/12/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2020

1. Name & Address of Ind./Unit : Yamuna Vihar STP Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 05.11.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	25	Inlet	7.1	316	260	640	28.8	29.8	7.4	Not meeting the Standards w.r.t TSS,BOD,COD, A.N.
		Outlet	7.3	30	18	84	2.0	5.6	1.4	
		OLMS*	7.83	27.87	15.99	83.42	-	4.22	-	
Total 25										

Mukta
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/448

2771

Dated 11/12/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2020

1. Name & Address of Ind./Unit : Yamuna Vihar STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 05.11.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results :										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	10 Ph-1	Inlet	7.1	476	290	724	32.4	34.6	7.7	Not meeting the standards w.r.t TSS BOD COD.
		Outlet	7.2	20	16	68	0.8	2.6	0.7	
		OLMS*	7.64	33.4	11.40	51.11	-	4.60	-	
2	10 Ph-2	Inlet	6.9	204	160	400	24.4	26.4	6.7	Not Meeting the Standards w.r.t TSS, BOD, COD.
		Outlet	7.0	36	22	96	2.8	3.4	1.2	
		OLMS*	-	-	-	-	-	-	-	
Total 20										

Mitla
I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/449 | 2772

dated 11/11/2020


ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2020

1. Name & Address of Ind./Unit : Narela STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 06.11.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
						COD (mg/l)				
				10	10	50	10	5	2	
1	10	Inlet	7.2	252	175	436	26.4	28.8	7.1	Not Meeting the Standards w.r.t TSS, BOD & COD.
		Outlet	7.4	24	16	64	2.0	3.2	0.9	
		OLMS*	7.1	23.26	17.48	50.0	-	2.41	-	
Total 10										

N. Mittal
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/450

2773

Dated 11/12/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2020


1. Name & Address of Ind./Unit : Okhla STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 12.11.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
1	12	Inlet	7.2	84	50	144	12.0	16.4	5.8	Not meeting the Standards w.r.t TSS & BOD, COD.
		Outlet	7.3	24	16	64	1.6	2.8	0.6	
		OLMS	6	36.84	13	82.17	-	0.85	-	
	16	Outlet	7.4	24	18	68	1.2	2.3	0.5	Not meeting the Standards w.r.t TSS, BOD & COD.
		OLMS	7.48	11.41	7.68	37	-	1.90	-	
	37	Outlet	7.4	48	22	76	2.0	2.6	0.8	Not meeting the Standards w.r.t TSS, BOD, COD.
		OLMS	-	-	-	-	-	-	-	
	45	Outlet	7.5	32	20	76	1.2	2.0	0.6	Not meeting the Standards w.r.t TSS, BOD, COD.
		OLMS	7.2	27.69	23.98	83.65	-	2.02	-	
	Total 110									

Remarks: OLMS (37 MGD) was not working.

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE (Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/451 / 2774

Dated 11/12/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2020


1. Name & Address of Ind./Unit : Okhla STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 12.11.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	AmmonicalNi trogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
1	30			10	10	50	10	5	2	
		Inlet	7.4	136	70	176	13.6	16.7	6.4	Meeting the Standards
		Outlet	7.5	4	2.8	16	0.4	0.8	0.1	
		OLMS*	7.88	4.24	3.21	23.8	-	-	-	
Total 30										

Mukherjee
I/C LABORATORY

R. Sharma
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/452

2775

Dated 11/14/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2020


1. Name & Address of Ind./Unit : Coronation Pillar STP
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 17.11.2020
4. Samples collected by : DPCC, Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	Parameters						Remarks
				TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	Ph-I,II(20)	Inlet	7.5	164	90	296	16.0	29.4	9.1	Not meeting the Standards w.r.t BOD, TSS ,COD, A.N & D.P.
		Outlet	7.2	84	50	164	4.0	17.0	2.3	
		OLMS*	-	-	-	-	-	-		
2	Ph-III(10)	Inlet	7.2	224	130	380	19.6	39.4	13.7	Not meeting the standards w.r.t TSS, BOD, COD, A.N.
		Outlet	7.2	64	40	136	4.0	5.8	1.8	
		OLMS*	7.4	50.02	37.85	99.19	-	1.50	-	
Total 30										

Remarks: Ph-I & II OLMS was not working

Mukta
I/C LABORATORY

A. B. Sharma
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/453

2776

Dated 11/12/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2020

1. Name & Address of Ind./Unit : Rithala STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.11.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

STP Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	Phase-I(40)	Inlet	7.2	164	110	340	26.4	29.6	6.8	Not meeting the standards w.r to TSS,BOD,COD.A.N.
		Outlet	7.2	62	36	124	4.0	11.8	1.6	
		OLMS*	7.22	51.16	32.97	169.71	-	28.83	-	
2	Ph-II(40)	Inlet	7.2	164	110	340	26.4	29.6	6.8	Meeting the standards
		Outlet	7.3	10	6	24	0.8	1.6	0.4	
		OLMS*	6.3	19.05	12.37	42.65	-	1.86	-	
Total 80										164

N. Mishra
I/C LABORATORY

SR. SCIENTIFIC ASSISTANT
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/20-21/454

2777

Dated 11/14/2020


ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2020

1. Name & Address of Ind./Unit : Rohini STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.11.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	15	Inlet	7.2	348	295	640	36.4	38.2	8.1	
		Outlet	7.4	14	10	36	1.6	3.8	0.8	Not meeting the Standards w.r.t TSS.
		OLMS*	7.51	5.09	6.80	38.08	-	1.93		
Total 15										

N. Mittal
I/C LABORATORY

P. B. Sharma
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/455

2778

Dated 11/12/2020


ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2020

1. Name & Address of Ind./Unit : Keshopur STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.11.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
						COD (mg/l)				
				10	10	50	10	5	2	
1	12	Inlet	7.3	232	165	412	28.4	29.8	7.7	Meeting the standars.
		Outlet	7.4	10	6	24	1.6	2.6	0.9	
		OLMS*	6.74	7	2.00	21.0	-	6.99	-	
Total 12										

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/456

2779

dated 11/14/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2020

1. Name & Address of Ind./Unit : Keshopur STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.11.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	Parameters COD (mg/l) 50	Oil & Grease (mg/l) 10	AmmonicalN itrogen (mg/l) 5	Dissolved Phosphate as P(mg/l) 2	Remarks
1	40	Inlet	7.1	100	60	188	10.8	14.6	5.3	Not meeting the Standards w.r.t TSS,BOD,COD, A.N & D.P.
		Outlet	7.1	68	44	136	4.4	8.4	2.4	
		OLMS*	7.65	156.84	82.94	31.41	-	0.15	-	
2	20	Inlet	7.1	100	60	188	10.8	14.6	5.3	Not meeting the Standards w.r.t TSS,BOD, COD, A.N & D.P.
		Outlet	7.2	56	32	108	6.4	6.4	2.5	
		OLMS*	-	--	-	-	--	-	-	
Total 60										

M. M. M. M.
I/C LABORATORY

R. K. S. S.
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/457 / 2780

Dated 11/12/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2020

1. Name & Address of Ind./Unit : Nilothe STP-II
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.11.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	20	Inlet	6.4	164	85	244	15.2	18.6	5.9	Meeting the Standards.
		Outlet	6.8	8	5	28	0.4	1.6	0.3	
		OLMS*	6.75	4.86	4.42	30.75	-	1.93	-	
Total 20										

N. Mitha
I/C LABORATORY

R. S. Sharma
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/458 / 278/

Dated 11/11/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2020

1. Name & Address of Ind./Unit : Nilothi STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.11.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Water Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	40	Inlet	-	-	-	-	-	-	--	Plant was non-operational in absence of Flow.
		Outlet	-	-	-	-	-	-	--	
		OLMS*	-	-	-	-	-	-	-	
Total 40										

N. Mehta
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/459 / 2782

Dated 11/12/20


ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2020

1. Name & Address of Ind./Unit : Pappankalan STP(Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.11.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	20	Inlet	7.1	268	210	620	29.6	33.4	7.6	Not meeting the Standards w.r.t TSS, BOD, A.N & COD.
		Outlet	7.2	44	28	72	3.6	8.7	1.3	
		OLMS*	7.23	33.51	25.68	140.46	-	20	-	
Total 20										

N. Mehta
I/C LABORATORY

A. K. Sharma
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/460

2783

Dated 11/12/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2020

1. Name & Address of Ind./Unit : Pappankalan STP-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.11.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
				10	10	50	10	5	2	
1	20	Inlet	7.3	240	170	440	26.4	29.6	6.3	Meeting the Standards.
		Outlet	7.5	8	6	28	0.4	2.4	0.9	
		OLMS*	-	-	-	-	-	-	-	
Total 20										

Remarks-OLMS was under maintenance.

Remarks-OLMS was under maintenance.

M. K. Mittal
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/20-21/461

2784

Dated 11/14/2020


ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2020

1. Name & Address of Ind./Unit : Najafgarh STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.11.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	5	Inlet	7.3	104	60	184	12.4	16.8	5.7	Not meeting the standards w.r.t to TSS, BOD, COD.
		Outlet	7.4	26	18	56	1.6	3.8	0.9	
		OLMS*	7.3	21.99	37.22	113.38	-	4.57	-	
Total 5										

N. Mittal
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/462

2985

Dated 11/11/2020


ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2020

1. Name & Address of Ind./Unit : Kapasahera STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 23.11.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
1	5	Inlet	7.1	368	260	620	32.4	34.6	8.1	Meeting the Standards.
		Outlet	7.2	10	6	36	2.4	3.8	1.2	
		OLMS*	7.28	21.70	15.20	6.63	-	0.48	-	
Total 5										

N Mehta
I/C LABORATORY

Abraham
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/463

2786

Dated 11/12/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2020

1. Name & Address of Ind./Unit : Vasant Kunj STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 23.11.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	2.2	Inlet	7.3	252	165	412	28.4	32.6	6.9	Not Meeting the Standards w.r.t TSS, BOD & COD
		Outlet	7.4	26	18	60	1.6	4.6	0.4	
2	3	OLMS*	7.27	13.49	6.49	29.38	-	3.36	-	
		Inlet	7.3	372	290	680	30.4	33.4	7.8	
		Outlet	7.3	62	40	120	4.0	6.8	1.4	
		OLMS*	7.68	11.22	7.39	32.56	-	1.93	-	
Total 5.2										

Misha
I/C LABORATORY

Shreyan
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/464

2787

Dated 11/14/20

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2020

1. Name & Address of Ind./Unit : Mehrauli STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 23.11.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	15	Inlet	7.2	252	190	460	28.8	30.4	6.8	Not meeting the standards w.r.t TSS, BOD.
		Outlet	7.3	20	12	48	1.6	3.8	0.9	
		OLMS*	-	-	-	--	-	-	-	
Total 15										

Remarks: OLMS was non-functional due to technical fault.

M. K. Mishra
I/C LABORATORY

R. K. Mishra
SR. SCIENTIFIC ASSISTANT