

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)**LIFE**

Lifestyle for Environment

ANALYSIS REPORT OF WAZIRPUR CETP (24 MLD) FOR THE MONTH OF FEBRUARY-2025

Report Number: DPCC/W/CETP/24-25/131/1636

Dated: 11/3/2025

1. Name & Address of Ind. / Unit : WAZIRPUR CETP (24 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 13.02.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.5	5.5-9.0	7.1	6-9	8.2
2	TSS	332	600	68	100	57.0
3	COD	272	750	104	250	100.0
4	BOD (3 days at 27° C)	120	300	22	30	11.2
5	Ni	-	3.0	-	3.0	-
6	Cu	-	3.0	-	3.0	-
7	Zn	-	15.0	-	5.0	-
8	Cr (Total)	-	2.0	-	2.0	-
9	Chromium (Hexavalent)	-	2.0	-	...	-
10	Pb	-	1.0	-	0.1	-
11	Cd	-	1.0	-	0.05	-
12	Oil & Grease	12	20.0	1.2	10.0	-
13	Ammonical Nitrogen as N	10.5	50	1.1	50	-
14	Sulphide	3.2	5.0	1.5	2.0	-
15	Phenolic Compounds	-	5.0	-	...	-
16	Cyanide (CN)	-	2.0	-	...	-
17	Arsenic	-	0.2	-	...	-
18	Mercury	-	0.01	-	...	-
19	Selenium	-	0.05	-	...	-
20	Fluoride	-	15.0	-	...	-
21	Boron	-	2.0	-	...	-
22	Phosphate	6.0	15.0	1.1	5.0	-

All values are in mg/l except pH

...No Standards

Flow: - 3.9 MLD

I/C Water Laboratory

SSA/Analyst/SLA

Dr. Shweta Gupta
Incharge (Water Laboratory)

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)

**ANALYSIS REPORT OF SMA CETP (12 MLD) FOR THE MONTH OF FEBRUARY-2025**

Report Number: DPCC/W/CETP/24-25/132/1637

Dated: 11/3/2025

1. Name & Address of Ind. / Unit : SMA CETP (12 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 13.02.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.7	5.5-9.0	7.2	6-9	7.4
2	TSS	324	600	52	100	15.0
3	COD	360	750	92	250	44.0
4	BOD (3 days at 27° C)	160	300	24	30	12.9
5	Ni	-	3.0	-	3.0	-
6	Cu	-	3.0	-	3.0	-
7	Zn	-	15.0	-	5.0	-
8	Cr (Total)	-	2.0	-	2.0	-
9	Chromium (Hexavalent)	-	2.0	-	...	-
10	Pb	-	1.0	-	0.1	-
11	Cd	-	1.0	-	0.05	-
12	Oil & Grease	10	20.0	2.4	10.0	-
13	Ammonical Nitrogen as N	9.7	50	1.7	50	-
14	Sulphide	4.6	5.0	1.8	2.0	-
15	Phenolic Compounds	-	5.0	-	...	-
16	Cyanide (CN)	-	2.0	-	...	-
17	Arsenic	-	0.2	-	...	-
18	Mercury	-	0.01	-	...	-
19	Selenium	-	0.05	-	...	-
20	Fluoride	-	15.0	-	...	-
21	Boron	-	2.0	-	...	-
22	Phosphate	10.9	15.0	4.2	5.0	-

All values are in mg/l except pH

...No Standards

Flow: 3.31 MLD

I/C Water Laboratory

SSA/Analyst/SLA

Dr. Shweta Gupta
Incharge (Water Laboratory)



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



ANALYSIS REPORT OF OKHLA CETP (24 MLD) FOR THE MONTH OF FEBRUARY-2025

Report Number: DPCC/W/CETP/24-25/133/1638

Dated: 11/3/2025

1. Name & Address of Ind. / Unit : OKHLA CETP (24 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 17.02.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.6	5.5-9.0	7.3	6-9	7.3
2	TSS	380	600	60	100	51.2
3	COD	368	750	92	250	103.6
4	BOD (3 days at 27° C)	160	300	20	30	26.7
5	Ni	-	3.0	-	3.0	-
6	Cu	-	3.0	-	3.0	-
7	Zn	-	15.0	-	5.0	-
8	Cr (Total)	-	2.0	-	2.0	-
9	Chromium (Hexavalent)	-	2.0	-	...	-
10	Pb	-	1.0	-	0.1	-
11	Cd	-	1.0	-	0.05	-
12	Oil & Grease	10	20.0	1.6	10.0	-
13	Ammonical Nitrogen as N	10.3	50	2.3	50	-
14	Sulphide	3.9	5.0	1.4	2.0	-
15	Phenolic Compounds	-	5.0	-	...	-
16	Cyanide (CN)	-	2.0	-	...	-
17	Arsenic	-	0.2	-	...	-
18	Mercury	-	0.01	-	...	-
19	Selenium	-	0.05	-	...	-
20	Fluoride	-	15.0	-	...	-
21	Boron	-	2.0	-	...	-
22	Phosphate	11.6	15.0	1.9	5.0	-

All values are in mg/l except pH

... No Standards

Flow: 1.81 MLD

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



ANALYSIS REPORT OF NARELA CETP (24 MLD) FOR THE MONTH OF FEBRUARY-2025

Report Number: DPCC/W/CETP/24-25/134/1639

Dated: 11/3/2025

1. Name & Address of Ind. / Unit : NARELA CETP (22.5 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 18.02.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.8	5.5-9.0	7.4	6-9	7.5
2	TSS	396	600	68	100	4.4
3	COD	248	750	96	250	27.9
4	BOD (3 days at 27° C)	90	300	25	30	5.3
5	Ni	-	3.0	-	3.0	-
6	Cu	-	3.0	-	3.0	-
7	Zn	-	15.0	-	5.0	-
8	Cr (Total)	-	2.0	-	2.0	-
9	Chromium (Hexavalent)	-	2.0	-	...	-
10	Pb	-	1.0	-	0.1	-
11	Cd	-	1.0	-	0.05	-
12	Oil & Grease	15.6	20.0	1.2	10.0	-
13	Ammonical Nitrogen as N	9.2	50	5.4	50	-
14	Sulphide	3.7	5.0	1.6	2.0	-
15	Phenolic Compounds	-	5.0	-	...	-
16	Cyanide (CN)	-	2.0	-	...	-
17	Arsenic	-	0.2	-	...	-
18	Mercury	-	0.01	-	...	-
19	Selenium	-	0.05	-	...	-
20	Fluoride	-	15.0	-	...	-
21	Boron	-	2.0	-	...	-
22	Phosphate	8.7	15.0	1.6	5.0	-

All values are in mg/l except pH

... No Standards

Flow: 7.70 MLD

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



ANALYSIS REPORT OF NANGLOI CETP (12 MLD) FOR THE MONTH OF FEBRUARY-2025

Report Number: DPCC/W/CETP/24-25/135/1640

Dated: 11/3/2025


1. Name & Address of Ind. / Unit : NANGLOI CETP (12 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 11.02.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.6	5.5-9.0	7.3	6-9	7.5
2	TSS	392	600	70	100	19.1
3	COD	312	750	92	250	58.0
4	BOD (3 days at 27° C)	110	300	28	30	11.4
5	Ni	-	3.0	-	3.0	-
6	Cu	-	3.0	-	3.0	-
7	Zn	-	15.0	-	5.0	-
8	Cr (Total)	-	2.0	-	2.0	-
9	Chromium (Hexavalent)	-	2.0	-	...	-
10	Pb	-	1.0	-	0.1	-
11	Cd	-	1.0	-	0.05	-
12	Oil & Grease	8.8	20.0	1.2	10.0	-
13	Ammonical Nitrogen as N	11.2	50	2.8	50	-
14	Sulphide	2.2	5.0	1.2	2.0	-
15	Phenolic Compounds	-	5.0	-	...	-
16	Cyanide (CN)	-	2.0	-	...	-
17	Arsenic	-	0.2	-	...	-
18	Mercury	-	0.01	-	...	-
19	Selenium	-	0.05	-	...	-
20	Fluoride	-	15.0	-	...	-
21	Boron	-	2.0	-	...	-
22	Phosphate	10.8	15.0	3.4	5.0	-


All values are in mg/l except pH

... No Standards

Flow: 3.40 MLD


I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)


SSA/Analyst/SLA

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)**ANALYSIS REPORT OF NARAINA CETP (21.6 MLD) FOR THE MONTH OF FEBRUARY-2025**

Report Number: DPCC/W/CETP/24-25/136/1641

Dated: 11/3/2025


1. Name & Address of Ind. / Unit : **NARAINA CETP (21.6 MLD)**
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 11.02.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :


S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.8	5.5-9.0	7.2	6-9	7.1
2	TSS	364	600	62	100	29.7
3	COD	360	750	96	250	100.0
4	BOD (3 days at 27° C)	200	300	26	30	21.2
5	Ni	-	3.0	-	3.0	-
6	Cu	-	3.0	-	3.0	-
7	Zn	-	15.0	-	5.0	-
8	Cr (Total)	-	2.0	-	2.0	-
9	Chromium (Hexavalent)	-	2.0	-	...	-
10	Pb	-	1.0	-	0.1	-
11	Cd	-	1.0	-	0.05	-
12	Oil & Grease	10.4	20.0	1.6	10.0	-
13	Ammonical Nitrogen as N	8.7	50	4.1	50	-
14	Sulphide	2.5	5.0	1.2	2.0	-
15	Phenolic Compounds	-	5.0	-	...	-
16	Cyanide (CN)	-	2.0	-	...	-
17	Arsenic	-	0.2	-	...	-
18	Mercury	-	0.01	-	...	-
19	Selenium	-	0.05	-	...	-
20	Fluoride	-	15.0	-	...	-
21	Boron	-	2.0	-	...	-
22	Phosphate	6.9	15.0	1.5	5.0	-

All values are in mg/l except pH

... No Standards

FLOW: 4.77 MLD


 I/C Water Laboratory


 SSA/Analyst/SLA

Dr. Shweta Gupta
 Incharge (Water Laboratory)



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



LIFE
Lifestyle for
Environment

ANALYSIS REPORT OF MANGOLPURI CETP (2.4 MLD) FOR THE MONTH OF FEBRUARY-2025

Report Number: DPCC/W/CETP/24-25/137/1642

Dated: 11/3/2025

1. Name & Address of Ind. / Unit
2. Sampling location
3. Date of Sampling
4. Sample analyzed and results
5. Parameters analyzed and result

MANGOLPURI CETP (2.4 MLD)

Inlet and Outlet of CETP

11.02.2025


DPCC LAB

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.9	5.5-9.0	7.2	6-9	7.2
2	TSS	390	600	78	100	19.4
3	COD	400	750	80	250	118.3
4	BOD (3 days at 27° C)	180	300	26	30	20.2
5	Ni	-	3.0	-	3.0	-
6	Cu	-	3.0	-	3.0	-
7	Zn	-	15.0	-	5.0	-
8	Cr (Total)	-	2.0	-	2.0	-
9	Chromium (Hexavalent)	-	2.0	-	...	-
10	Pb	-	1.0	-	0.1	-
11	Cd	-	1.0	-	0.05	-
12	Oil & Grease	14.8	20.0	2.4	10.0	-
13	Ammonical Nitrogen as N	8.8	50	4.6	50	-
14	Sulphide	3.5	5.0	1.4	2.0	-
15	Phenolic Compounds	-	5.0	-	...	-
16	Cyanide (CN)	-	2.0	-	...	-
17	Arsenic	-	0.2	-	...	-
18	Mercury	-	0.01	-	...	-
19	Selenium	-	0.05	-	...	-
20	Fluoride	-	15.0	-	...	-
21	Boron	-	2.0	-	...	-
22	Phosphate	12.9	15.0	1.6	5.0	-

All values are in mg/l except pH

... No Standards

Flow: 1.55 MLD


I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)


SSA/Analyst/SLA

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)**ANALYSIS REPORT OF LAWRENCE ROAD CETP (12 MLD) FOR THE MONTH OF FEBRUARY-2025**

Report Number: DPCC/W/CETP/24-25/138/1643

Dated: 11/3/2025

- | | |
|-----------------------------------|-------------------------------|
| 1. Name & Address of Ind. / Unit | LAWRENCE ROAD (12 MLD) |
| 2. Sampling location | Inlet and Outlet of CETP |
| 3. Date of Sampling | 13.02.2025 |
| 4. Sample analyzed and results | DPCC LAB |
| 5. Parameters analyzed and result | |

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.7	5.5-9.0	7.1	6-9	8.7
2	TSS	340	600	64	100	25.8
3	COD	368	750	100	250	78.0
4	BOD (3 days at 27° C)	160	300	25	30	0
5	Ni	-	3.0	-	3.0	-
6	Cu	-	3.0	-	3.0	-
7	Zn	-	15.0	-	5.0	-
8	Cr (Total)	-	2.0	-	2.0	-
9	Chromium (Hexavalent)	-	2.0	-	...	-
10	Pb	-	1.0	-	0.1	-
11	Cd	-	1.0	-	0.05	-
12	Oil & Grease	9.2	20.0	1.6	10.0	-
13	Ammonical Nitrogen as N	7.2	50	2.7	50	-
14	Sulphide	3.4	5.0	1.7	2.0	-
15	Phenolic Compounds	-	5.0	-	...	-
16	Cyanide (CN)	-	2.0	-	...	-
17	Arsenic	-	0.2	-	...	-
18	Mercury	-	0.01	-	...	-
19	Selenium	-	0.05	-	...	-
20	Fluoride	-	15.0	-	...	-
21	Boron	-	2.0	-	...	-
22	Phosphate	8.5	15.0	2.4	5.0	-

All values are in mg/l except pH

... No Standards

Flow: 1.73 MLD

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

SSA/Analyst/SLA

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)**LIFE**
Lifestyle for
Environment**ANALYSIS REPORT OF JHILMIL CETP (16.8 MLD) FOR THE MONTH OF FEBRUARY-2025**

Report Number: DPCC/W/CETP/24-25/139/1644

Dated: 11/3/2025


- | | |
|-----------------------------------|--------------------------------|
| 1. Name of CETP | JHILMIL CETP (16.8 MLD) |
| 2. Sampling location | Inlet and Outlet of CETP |
| 3. Date of Sampling | 21.02.2025 |
| 4. Sample analyzed and results | DPCC LAB |
| 5. Parameters analyzed and result | |

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.6	5.5-9.0	7.1	6-9	6.7
2	TSS	392	600	76	100	49.9
3	COD	392	750	88	250	159.6
4	BOD (3 days at 27° C)	160	300	24	30	13.9
5	Ni	-	3.0	-	3.0	-
6	Cu	-	3.0	-	3.0	-
7	Zn	-	15.0	-	5.0	-
8	Cr (Total)	-	2.0	-	2.0	-
9	Chromium (Hexavalent)	-	2.0	-	...	
10	Pb	-	1.0	-	0.1	-
11	Cd	-	1.0	-	0.05	
12	Oil & Grease	10	20.0	2	10.0	
13	Ammonical Nitrogen as N	14.8	50	3.2	50	-
14	Sulphide	3.1	5.0	1.6	2.0	-
15	Phenolic Compounds	-	5.0	-	...	-
16	Cyanide (CN)	-	2.0	-	...	-
17	Arsenic	-	0.2	-	...	-
18	Mercury	-	0.01	-	...	-
19	Selenium	-	0.05	-	...	-
20	Fluoride	-	15.0	-	...	-
21	Boron	-	2.0	-	...	-
22	Phosphate	12.5	15.0	3.1	5.0	-

All values are in mg/l except pH

... No Standards

Flow: 3.16 MLD


I/C Water Laboratory

SSA/Analyst/SLA
Dr. Shweta Gupta
 Incharge (Water Laboratory)

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)**Life**
Lifestyle for
Environment**ANALYSIS REPORT OF BAWANA CETP (35 MLD) FOR THE MONTH OF FEBRUARY-2025**

Report Number: DPCC/W/CETP/24-25/140/1645

Dated: 11/3/2025

- | | | |
|----|--------------------------------|-----------------------------|
| 1. | Name & Address of Ind. / Unit | BAWANA CETP (35 MLD) |
| 2. | Sampling location | Inlet and Outlet of CETP |
| 3. | Date of Sampling | 18.02.2025 |
| 4. | Sample analyzed and results | DPCC LAB |
| 5. | Parameters analyzed and result | |

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.8	5.5-9.0	7.3	6-9	7.4
2	TSS	404	600	78	100	17.8
3	COD	256	750	84	250	29.7
4	BOD (3 days at 27° C)	110	300	24	30	7.4
5	Ni	-	3.0	-	3.0	-
6	Cu	-	3.0	-	3.0	-
7	Zn	-	15.0	-	5.0	-
8	Cr (Total)	-	2.0	-	2.0	-
9	Chromium (Hexavalent)	-	2.0	-	...	-
10	Pb	-	1.0	-	0.1	-
11	Cd	-	1.0	-	0.05	-
12	Oil & Grease	12.4	20.0	2	10.0	-
13	Ammonical Nitrogen as N	13.8	50	3.5	50	-
14	Sulphide	2.8	5.0	1.3	2.0	-
15	Phenolic Compounds	-	5.0	-	...	-
16	Cyanide (CN)	-	2.0	-	...	-
17	Arsenic	-	0.2	-	...	-
18	Mercury	-	0.01	-	...	-
19	Selenium	-	0.05	-	...	-
20	Fluoride	-	15.0	-	...	-
21	Boron	-	2.0	-	...	-
22	Phosphate	9.7	15.0	2.1	5.0	-

All values are in mg/l except pH

... No Standards

Flow: 24.17 MLD

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



ANALYSIS REPORT OF BADLI CETP (12 MLD) FOR THE MONTH OF FEBRUARY-2025

Report Number: DPCC/W/CETP/24-25/141/1646

Dated: 11/3/2025

- | | |
|-----------------------------------|--------------------------|
| 1. Name & Address of Ind. / Unit | BADLI CETP (12 MLD) |
| 2. Sampling location | Inlet and Outlet of CETP |
| 3. Date of Sampling | 13.02.2025 |
| 4. Sample analyzed and results | DPCC LAB |
| 5. Parameters analyzed and result | |

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.5	5.5-9.0	7.2	6-9	8.4
2	TSS	328	600	60	100	7.4
3	COD	248	750	88	250	11.6
4	BOD (3 days at 27° C)	100	300	18	30	4.7
5	Ni	-	3.0	-	3.0	-
6	Cu	-	3.0	-	3.0	-
7	Zn	-	15.0	-	5.0	-
8	Cr (Total)	-	2.0	-	2.0	-
9	Chromium (Hexavalent)	-	2.0	-	...	-
10	Pb	-	1.0	-	0.1	-
11	Cd	-	1.0	-	0.05	-
12	Oil & Grease	14	20.0	3.2	10.0	-
13	Ammonical Nitrogen as N	11.7	50	2.8	50	-
14	Sulphide	3.7	5.0	1.5	2.0	-
15	Phenolic Compounds	-	5.0	-	...	-
16	Cyanide (CN)	-	2.0	-	...	-
17	Arsenic	-	0.2	-	...	-
18	Mercury	-	0.01	-	...	-
19	Selenium	-	0.05	-	...	-
20	Fluoride	-	15.0	-	...	-
21	Boron	-	2.0	-	...	-
22	Phosphate	7.2	15.0	1.5	5.0	-

All values are in mg/l except pH

... No Standards

Flow: - 2.0 MLD

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



ANALYSIS REPORT OF GTK CETP (6 MLD) FOR THE MONTH OF FEBRUARY-2025

Report Number: DPCC/W/CETP/24-25/142/ 1647

Dated: 11/3/2025

1. Name & Address of Ind. / Unit **GTK CETP (6 MLD)**
2. Sampling location **Inlet and Outlet of CETP**
3. Date of Sampling **13.02.2025**
4. Sample analyzed and results **DPCC LAB**
5. Parameters analyzed and result


S. No	Parameter	Inlet		Final Outlet		OLMS*
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.4	5.5-9.0	7.1	6-9	-
2	TSS	316	600	68	100	-
3	COD	352	750	112	250	-
4	BOD (3 days at 27° C)	140	300	24	30	-
5	Ni	-	3.0	-	3.0	-
6	Cu	-	3.0	-	3.0	-
7	Zn	-	15.0	-	5.0	-
8	Cr (Total)	-	2.0	-	2.0	-
9	Chromium (Hexavalent)	-	2.0	-	...	-
10	Pb	-	1.0	-	0.1	-
11	Cd	-	1.0	-	0.05	-
12	Oil & Grease	13.6	20.0	2.8	10.0	-
13	Ammonical Nitrogen as N	10.3	50	2.2	50	-
14	Sulphide	2.6	5.0	1.7	2.0	-
15	Phenolic Compounds	-	5.0	-	...	-
16	Cyanide (CN)	-	2.0	-	...	-
17	Arsenic	-	0.2	-	...	-
18	Mercury	-	0.01	-	...	-
19	Selenium	-	0.05	-	...	-
20	Fluoride	-	15.0	-	...	-
21	Boron	-	2.0	-	...	-
22	Phosphate	7.4	15.0	1.8	5.0	-

*Remarks: OLMS was Non-functional

All values are in mg/l except pH

... No Standards

Flow: 2.24 MLD


I/C Water Laboratory


SSA/Analyst/SLA

Dr. Shweta Gupta
Incharge (Water Laboratory)



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



ANALYSIS REPORT OF MAYAPURI CETP (12 MLD) FOR THE MONTH OF FEBRUARY-2025

Report Number: DPCC/W/CETP/24-25/143/1648

Dated: 11/3/2025

1. Name & Address of Ind. / Unit
2. Sampling location
3. Date of Sampling
4. Sample analyzed and results
5. Parameters analyzed and result

MAYAPURI CETP (12 MLD)

Inlet and Outlet of CETP

11.02.2025

DPCC LAB

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.8	5.5-9.0	7.2	6-9	7.8
2	TSS	308	600	56	100	20.9
3	COD	344	750	108	250	127.6
4	BOD (3 days at 27° C)	160	300	22	30	14.8
5	Ni	-	3.0	-	3.0	-
6	Cu	-	3.0	-	3.0	-
7	Zn	-	15.0	-	5.0	-
8	Cr (Total)	-	2.0	-	2.0	-
9	Chromium (Hexavalent)	-	2.0	-	...	-
10	Pb	-	1.0	-	0.1	-
11	Cd	-	1.0	-	0.05	-
12	Oil & Grease	15.6	20.0	2.4	10.0	-
13	Ammonical Nitrogen as N	15.5	50	2.6	50	-
14	Sulphide	4.2	5.0	1.7	2.0	-
15	Phenolic Compounds	-	5.0	-	...	-
16	Cyanide (CN)	-	2.0	-	...	-
17	Arsenic	-	0.2	-	...	-
18	Mercury	-	0.01	-	...	-
19	Selenium	-	0.05	-	...	-
20	Fluoride	-	15.0	-	...	-
21	Boron	-	2.0	-	...	-
22	Phosphate	7.6	15.0	1.5	5.0	-

All values are in mg/l except pH

... No Standards

Flow: 3.93 MLD

Shweta

I/C Water Laboratory

Deepa

SSA/Analyst/SLA

Dr. Shweta Gupta
Incharge (Water Laboratory)