



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/76 4022

Date: 07/07/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2021

1. Name & Address of Ind./Unit : Coronation Pillar STP
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 17.06.2021
4. Samples collected by : DPCC, Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	Parameters COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P(mg/l) 2	Remarks
1	Ph-I,II(20)	Inlet	6.62	80	132	364	24.0	14.47	18.91	Not meeting the Standards w.r.t TSS, BOD, COD, A.N. & DP
		Outlet	7.14	32	42	198	5.6	7.39	8.71	
		OLMS*	-	-	-	-	-	-	-	
2	Ph-III(10)	Inlet	6.96	88	140	424	19.6	17.89	14.55	Not meeting the standards w.r.t TSS, BOD & COD
		Outlet	6.58	40	48	268	8	3.62	1.86	
		OLMS*	7.03	75.11	65.29	217.87	-	30.34	-	
Total 30										

Remarks: Ph-I OLMS was not working

Remarks: Ph-I OLMS was not working

N. Mishra
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/77 4023

dated: 07/07/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2021

1. Name & Address of Ind./Unit : Delhi Gate STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.06.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
						COD (mg/l)				
				10	10	50	10	5	2	
1	Phase-I,II(15)	Inlet	6.97	112	62	128	22.8	14.68	50.21	meeting the Standards
		Outlet	7.14	8	6	36	0.8	2.50	1.4	
		OLMS*	7.19	7.06	3.53	15.07	-	0.66	-	
Total 15										

N. Mitra
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/78 14024

Dated: 07/07/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2021

1. Name & Address of Ind./Unit : **DELHI GATE STP (Old)**
2. Sampling location : **Inlet and Outlet of STP**
3. Date of Inspection : **14.06.2021**
4. Samples collected by : **DPCC Lab**
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
						COD (mg/l)				
				10	10	50	10	5	2	
1	Phase-I,II(2.2)	Inlet	7.39	116	160	408	38.4	24.54	30.51	Meeting the Standards.
		Outlet	6.86	6	8	44	1.2	1.07	1.6	
		OLMS*	7.39	6.45	6.88	21.31	-	2.96	-	
Total 2.2										


I/C LABORATORY


SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE (Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/79/4025

Dated: 07/07/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2021

1. Name & Address of Ind./Unit : Keshopur STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.06.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :


Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
						COD (mg/l)				
				10	10	50	10	5	2	
1	12	Inlet	7.18	328	100	224	19.61	38.69	13.68	Not meeting the standards w.r.t TSS.
		Outlet	7.36	14	10	44	3.4	2.19	1.46	
		OLMS*	-	-	-	-	-	-	-	
Total 12										

Remarks: OLMS was found non-operational

I/C LABORATORY

Scientist, C

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/80 4626

dated: 07/07/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2021

1. Name & Address of Ind./Unit : SEN Nursing Home (SNH)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.06.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	Phase-I,II (2.2)	Inlet	7.04	148	110	458	22	32.32	16.81	Meeting the Standards.
		Outlet	6.95	8	4	32	3.8	3.16	1.86	
		OLMS*	7.42	6.79	1.82	23.80	-	2.31	-	
Total 2.2										

Mishra
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE (Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/81/4027

Dated : 07/07/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2021

1. Name & Address of Ind./Unit : Niloti STP-II
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 21.06.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	20	Inlet	7.31	256	170	240	15.64	28.83	15.96	Meeting the Standards.
		Outlet	7.32	8	10	32	1.86	4.81	1.90	
		OLMS*	7.78	4.51	4.06	13.89	-	5.86	-	
Total 20										

Mitra
I/C LABORATORY

AB. Sharma
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/21-22/83 / 4028

Dated: 07/07/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2021

1. Name & Address of Ind./Unit : Najafgarh STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 22.06.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Analysis and Results										
S. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
				10	10	50	10	5	2	
1	5	Inlet	7.26	256	96	208	16.31	16.96	15.68	Not meeting the standards w.r.t to TSS, BOD, COD & A.N.
		Outlet	7.64	42	28	80	5.86	10.68	1.80	
		OLMS*	-	-	-	-	-	-	-	
Total 5										
Remarks: OLMS was found non-operational										

Remarks: OLMS was found non-operational

Mishra
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/82/4029

Dated: 07/07/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2021

1. Name & Address of Ind./Unit : Nilothi STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 21.06.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	40	Inlet	7.37	144	218	228	15.8	32.49	18.46	Not meeting the standards w.r.t to TSS, BOD, COD & A.N.
		Outlet	7.35	30	52	148	7.0	10.11	1.78	
		OLMS*	7.23	128.62	106.94	365.19	-	31.55	-	
Total 40										

N. Mitra
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE (Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/84 / 4030

Dated: 07/07/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2021

1. Name & Address of Ind./Unit : Rithala STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.06.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

Parameters analysis and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	Phase-I(40)	Inlet	-	-	-	-	-	-	-	OLMS & plant was found closed.
		Outlet	-	-	-	-	-	-	-	
		OLMS*	-	-	-	-	-	-	-	
2	Ph-II(40)	Inlet	7.1	108	135	400	18.11	46.23	18.16	Meeting the standards
		Outlet	7.2	6	10	36	2.8	3.4	1.8	
		OLMS*	7.36	12.16	12.47	64.24	-	15.74	-	
Total 80										

Mitla
I/C LABORATORY

SR. Scientific Assistant
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/85 | 4031

Dated: 07/07/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2021

1. Name & Address of Ind./Unit : Pappankalan STP(Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 22.06.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	20	Inlet	7.30	348	230	352	22.12	35.41	19.68	Not meeting the Standards w.r.t TSS, BOD, A.N, COD & DP.
		Outlet	7.60	76	58	152	3.80	6.86	9.47	
		OLMS*	7.57	37.02	31.50	223.43	-	13.7	-	
Total 20										

Mitra
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE (Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/86/4032

Dated: 07/07/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2021

1. Name & Address of Ind./Unit : Pappankalan STP-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 22.06.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	AmmonicalNitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	20	Inlet	6.94	336	280	512	12.68	36.81	12.80	Meeting the Standards.
		Outlet	7.60	6	10	48	2.0	4.06	1.68	
		OLMS*	7.67	14.18	10.51	8.82	-	1.58	-	
Total 20										

Mitra
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE (Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/21-22/87/4033

Dated: 07/07/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2021

1. Name & Address of Ind./Unit : Rohini STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.06.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	15	Inlet	7.60	118	205	816	10.0	40.27	19.64	
		Outlet	7.40	18	12	48	3.6	4.27	1.90	Not meeting the Standards w.r.t TSS & BOD
		OLMS*	7.09	23.37	7.45	43.56	-	13.77	-	
Total 15										

Maitra
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/88/4034

D

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2021

1. Name & Address of Ind./Unit : Narela STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.06.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	10	Inlet	7.30	224	106	632	1.2	42.41	14.28	Meeting the Standards.
		Outlet	7.50	10	8	36	1.0	3.02	1.62	
		OLMS*	-	-	-	-	-	-	-	
Total 10										
Remarks: OLMS was found within the limit.										

Remarks: OLMS was found non-operational at the time of DPCC monitoring.

Mitra
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/89/4035

Date: 07/07/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2021

1. Name & Address of Ind./Unit : Okhla STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 23.06.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

3. Parameters Analysis and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	AmmonicalNi trogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	30	Inlet	7.06	104	220	388	18.6	36.68	10.68	Meeting the Standards.
		Outlet	7.46	8	10	38	0.8	1.64	0.91	
		OLMS*	7.63	6.77	6.48	20.89	-	2.49	-	
Total 30										

Mitka
I/C LABORATORY

SR. SCIENTIFIC ASSISTANT
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/90/4036

Dated: 07/07/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2021

1. Name & Address of Ind./Unit : Kondli STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.06.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	25	Inlet	7.03	180	206	416	16.1	29.93	15.61	Not meeting the Standards w.r.t TSS, BOD, COD & A.N.
		Outlet	7.40	12	16	72	4.8	11.90	1.68	
		OLMS*	7.52	19.20	11.97	43.59	-	12.60	-	
Total 25										

M. Mitta
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/91/4037


Dated: 07/07/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2021


1. Name & Address of Ind./Unit : Kondli STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.06.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	45	Inlet	6.83	118	260	616	14.6	29.27	8.36	Not Meeting the Standards w.r.t TSS, BOD, COD, A.N.
		Outlet	7.07	86	30	107	5.4	13.27	1.90	
		OLMS*	-	-	-	-	-	-	-	
Total 45										

Remarks: OLMS was found non functional


I/C LABORATORY


SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/92/4038

Dated: 07/07/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2021

1. Name & Address of Ind./Unit : Kapasahera STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 16.06.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	5	Inlet	6.87	340	280	1500	4.6	46.78	18.69	Meeting the Standards.
		Outlet	7.0	6	10	40	2.8	1.35	1.86	
		OLMS*	7.21	6.25	2.37	31.03	-	6.92	-	
Total 5										

Mitra
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/93 | 4039

Dated: 07/07/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2021

1. Name & Address of Ind./Unit : Yamuna Vihar STP Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.06.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
				10	10	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	25	Inlet	6.90	820	340	1024	30.66	28.87	18.66	Not meeting the Standards w.r.t TSS, BOD & COD.
		Outlet	7.40	33	22	68	1.31	4.75	1.31	
		OLMS*	-	34.82	23.09	159.22	-	-	-	
Total 25										

Mitra
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/21-22/94)4040

Dated : 07/07/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2021

1. Name & Address of Ind./Unit : Chilla STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.06.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	9	Inlet	7.01	168	100	332	4.6	27.86	21.11	Meeting the Standards.
		Outlet	7.10	8	6	38	1.2	1.60	1.29	
		OLMS*	7.13	7.99	6.14	34.74	-	1.95	-	
Total 9										

N. Mitra
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/95/4041

Dated: 07/07/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2021


1. Name & Address of Ind./Unit : Akshardham STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.06.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
				10	10	50	10	5	2	
1	1	Inlet	6.97	218	122	388	26.2	3.52	18.18	Meeting the Standards.
		Outlet	7.20	2	3	16	0.6	1.99	0.40	
		OLMS*	7.81	0.57	0.78	7.60	-	0.62	-	
Total 1										

Mittra
I/C LABORATORY

Scientist 'C'

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/96/1042

Dated : 07/07/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2021


1. Name & Address of Ind./Unit : Mehrauli STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 16.06.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
m	15	Inlet	6.90	24	120	350	20.6	12.56	11.60	Not Meeting the standards w.r.t. BOD, COD, A.N. & DP.
		Outlet	7.20	10	18	58	2.4	7.06	3.81	
		OLMS*	8.10	13.25	11.60	88.10	-	3.13	-	
Total 15										

I/C LABORATORY

Scientist 'C'

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/97/4043

Dated: 07/07/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2021

1. Name & Address of Ind./Unit : Vasant Kunj STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 16.06.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Remarks
				10	10	50	10	5	2	
1	2.2	Inlet	6.60	280	308	800	15.14	3.84	12.6	Not Meeting the Standards w.r.t TSS, BOD, COD & DP.
		Outlet	7.20	14	18	76	1.82	1.78	3.4	
		OLMS*	6.91	7.07	5.28	40.36	-	9.88	-	
2	3	Inlet	6.90	248	260	530	2.68	7.85	8	Not Meeting the Standards w.r.t TSS, BOD, COD & DP.
		Outlet	7.0	16	26	70	1.86	2.20	3.8	
		OLMS*	7.17	8.02	3.19	24.46	-	10.09	-	
Total 5.2										

M. Mitta
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/98 | 4044

Dated : 07/07/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2021


1. Name & Address of Ind./Unit : Yamuna Vihar STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.06.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	10 Ph-1	Inlet	7.10	360	256	800	20.16	29.93	31.61	Not meeting the standards w.r.t TSS, BOD, COD & DP.
		Outlet	7.40	18	16	62	4.8	4.10	4.0	
		OLMS*	7.38	24.53	15.44	66.98	-	13.96	-	
2	10 Ph-2	Inlet	7.10	400	152	480	24.86	27.83	18.60	Not meeting the standards w.r.t TSS, BOD, COD, A.N. & DP
		Outlet	7.30	42	28	96	5.6	7.87	2.6	
		OLMS*	-	-	-	-	-	-	-	
Total 20										
Remarks: Ph-1 OLMS reported as 11										

Remarks: Ph-II OLMS was not working.

N. Mishra
I/C LABORATORY
NANDITA MOITRA
Scientist 'C'

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/99/4045

Dated : 07/07/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2021

1. Name & Address of Ind./Unit : Okhla STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 23.06.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	12	Inlet	7.10	88	170	352	17.81	28.94	10.6	Not meeting the Standards w.r.t TSS & BOD, COD & D.P.
		Outlet	7.50	18	20	68	2.86	3.80	5.8	
		OLMS	7.22	32.49	16.61	101.15	-	13.13	-	
	16	Outlet	7.63	32	24	120	2.11	3.19	3.2	Not meeting the Standards w.r.t TSS, BOD, COD & DP.
		OLMS	7.43	35.97	17.74	89.09	-	18.41	-	
	37	Outlet	7.36	16	26	96	1.91	3.28	2.4	Not meeting the Standards w.r.t TSS, BOD, COD & DP.
		OLMS	7.67	24.48	12.18	41.36	-	11.43	-	
	45	Outlet	7.56	16	22	98	2.86	4.9	5.2	Not meeting the Standards w.r.t TSS, BOD, COD & DP.
		OLMS	7.67	28	24	96	-	3.84	-	
	Total 110									

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Dated : 07/07/2021

Report Number: DPCC/W/STP/21-22/100/4046

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2021


1. Name & Address of Ind./Unit : Keshopur STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 21.06.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	40	Inlet	7.01	276	133	256	16.4	42.32	8	Not meeting the Standards w.r.t TSS,BOD,COD, A.N & D.P.
		Outlet	7.25	64	56	176	4.8	15	3.0	
		OLMS*	-	-	-	-	-	-	-	
2	20	Inlet	7.01	276	133	256	16.4	42.32	8	Not meeting the Standards w.r.t TSS, BOD, COD, A.N & D.P.
		Outlet	7.33	76	50	165	3.0	17.2	3.4	
		OLMS*	-	-	-	-	-	-	-	
Total 60										

Remarks: OLMS (20 MGD) was found not working & OLMS (40 MGD) was locked.

Mitra
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/4 /4047

Dated: 07/07/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2021

1. Name & Address of Ind./Unit : Molarband Mini STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 23.06.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analysed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	0.66	Inlet	7.26	188	236	432	28.6	14.16	30.4	Not meeting the Standards w.r.t TSS, BOD, COD & DP.
		Outlet	7.73	28	32	144	4.6	1.47	4.2	
		OLMS*	-	-	-	-	-	-	-	
Total 0.66										

Remarks: OLMS was found non-functional

M. Mitra
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT