



DELHI POLLUTION CONTROL COMMITTEE
WATER LABORATORY
4thFLOOR, ISBT BUILDING, KASHMERE GATE, DELHI-06
visit us at : <http://dpcc.delhigovt.nic.in>

WASTE WATER QUALITY STATUS OF DRAIN

REPORT NO: DPCC/W/D/2025/ 1565
Date of Sampling: - 10/01/2025

Dated: - 30/01/2025

S. No.	Sampling location	pH	TSS (mg/l)	COD (mg/l)	BOD (mg/l)
	Standards	5.5- 9.0	100	250	30
1.	Najafgarh Drain	7.53	92	195	64
2.	Metcalf House Drain	NO FLOW			
3.	Khyber Pass Drain				
4.	Sweeper Colony Drain				
5.	Magazine Road Drain				
6.	ISBT Drain	7.18	98	215	80
7.	Tonga Stand Drain	NO FLOW			
8.	Civil Mill Drain				
9.	SEN Nursing Home Drain	7.23	108	205	70
10.	Drain No. 14				
11.	Power House Drain	6.91	110	195	63
12.	Indrapuri Drain	7.97	94	235	93
13.	Sonia Vihar Drain	7.24	100	210	73
14.	Kailash Nagar Drain	7.62	104	185	57
15.	Shastri Park Drain	6.81	84	165	53
16.	Barapulla Drain	7.04	88	170	53
17.	Maharani Bagh Drain	7.49	112	230	90
18.	Old Agra Canal Drain	NO FLOW			
19.	Jaitpur Drain	6.71	82	200	67
20.	Sarita Vihar Pool	7.17	90	180	53
21.	Tuglakabad Drain	8.13	96	190	60
22.	Drain Near LPG Bottling Plant	NO FLOW			
23.	Drain Near Sarita Vihar Bridge (Mathura Road)	8.32	92	220	83
24.	Shahdara Drain	7.79	120	360	127
25.	Sahibabad Drain	7.25	104	320	117
26.	Molarband Drain	NO FLOW			
27.	Abul Fazal Drain				

I/C WATER LAB

Dr. NANDITA MOITRA
Scientist-D

SSA/Analyst/SLA