



DELHI POLLUTION CONTROL COMMITTEE
WATER LABORATORY
4thFLOOR, ISBT BUILDING, KASHMERE GATE, DELHI-06
visit us at : <http://dpcc.delhigovt.nic.in>

WASTE WATER QUALITY STATUS OF DRAIN

REPORT NO: DPCC/W/D/2025/190-217/2483
Date of Sampling: - 12/11/2025

DT - 22/12/2025

S.No.	Sampling location	pH	TSS (mg/l)	COD (mg/l)	BOD (mg/l)
	Standards	5.5- 9.0	100	250	30
1.	Najafgarh Drain	7.2	48	88	34
2.	Metcalf House Drain	NO FLOW			
3.	Khyber Pass Drain	7.1	110	128	48
4.	Sweeper Colony Drain	7.3	64	116	44
5.	Magazine Road Drain	NO FLOW			
6.	ISBT Drain	7.0	52	176	76
7.	Tonga Stand Drain	NO FLOW			
8.	Civil Mill Drain				
9.	SEN Nursing Home Drain	7.6	186	316	140
10.	Drain No. 14	NO FLOW			
11.	Power House Drain	7.4	100	360	160
12.	Indrapuri Drain	7.8	260	344	170
13.	Sonia Vihar Drain	7.6	292	132	56
14.	Kailash Nagar Drain	7.4	248	656	240
15.	Shastri Park Drain	6.9	210	192	90
16.	Barapulla Drain	7.8	76	112	46
17.	Maharani Bagh Drain	7.1	82	132	58
18.	Old Agra Canal Drain	NO FLOW			
19.	Jaitpur Drain	7.3	138	256	105
20.	Sarita Vihar Pool	7.5	36	72	24
21.	Tuglakabad Drain	7.7	106	76	30
22.	Drain Near LPG Bottling Plant	NO FLOW			
23.	Drain Near Sarita Vihar Bridge (Mathura Road)	7.3	180	240	95
24.	Shahdara Drain	7.5	240	352	150
25.	Sahibabad Drain	7.2	280	488	235
26.	Molarband Drain	TAPPED			
27.	Abul Fazal Drain	7.3	54	76	26
28.	Drain No. 08	7.8	55	76	30

I/C WATER LAB

Scientist B