

DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/201/4468

Dated: 9/12/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2021

1. Name & Address of Ind./Unit : Coronation Pillar STP
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 11.11.2021
4. Samples collected by : DPCC, Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	Parameters COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P(mg/l) 2	Remarks
1	Ph-I,II(20)	Inlet	6.7	340	155	496	26	28.4	12.2	Not meeting the Standards w.r.t TSS, BOD, COD, A.N& DP.
		Outlet	7.3	42	20	72	2.8	10.1	3.0	
		OLMS*	-	-	-	-	-	-	-	
2	Ph-III(10)	Inlet	7.4	252	110	464	14	39.8	34.2	Not meeting the standards w.r.t. TSS, BOD, COD, A.N & DP.
		Outlet	7.5	44	22	90	4	10	4	
		OLMS*	-	-	-	-	-	-	-	
Total 30										


Remarks: Ph-I & II OLMS was stolen FIR has been filed as informed.
Ph-III OLMS was found non-operational

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT

6039/ITC/11
10/12/2021

O/C



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/202/4469

Dated: 9/12/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2021

1. Name & Address of Ind. /Unit : Delhi Gate STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.11.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
						COD (mg/l)				
				10	10	50	10	5	2	
1	Phase-I,II(15)	Inlet	7.1	200	90	320	24.4	34.4	6.2	Meeting the Standards
		Outlet	7.4	8	6	40	0.4	2.2	1.2	
		OLMS*	7.6	8.55	6.32	33.46	-	0.43	-	
Total 15										

M. K. Mittal
I/C LABORATORY

SR. Scientific Assistant
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/203/4470

Dated: 9/12/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2021

1. Name & Address of Ind./Unit : DELHI GATE STP (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.11.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
						COD (mg/l)				
				10	10	50	10	5	2	
1	Phase-I,II(2.2)	Inlet	7.0	224	95	352	15.2	33.6	16.8	Meeting the Standards
		Outlet	7.2	10	8	40	1.2	2.2	1.4	
		OLMS*	6.6	6.75	2.72	20.26	-	0.63	-	
Total 2.2										

Mita
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/204/4471

Dated: 9/12/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2021


1. Name & Address of Ind./Unit : Keshopur STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.11.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
						COD (mg/l)				
				10	10	50	10	5	2	
1	12	Inlet	7.2	192	90	336	14.8	32.34	16.0	Not meeting the Standards w.r.t TSS, BOD, COD& phosphate.
		Outlet	7.4	14	12	69	02	4.0	3.1	
		OLMS*	-	-	-	-	-	-	-	
Total 12										

Remarks: OLMS was non-operational at the time of sampling.

Mita
I/C LABORATORY

SR. SCIENTIFIC ASSISTANT
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/205/4472

Date: 9/12/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2021

1. Name & Address of Ind./Unit : SEN Nursing Home (SNH)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.11.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	Phase-I,II (2.2)	Inlet	7.4	256	90	304	18	34.1	14.2	Not meeting the Standards
		Outlet	7.2	10	08	48	0.8	2.8	1.8	
		OLMS*	7.4	22.19	1.60	33.45	-	0.48	-	
Total 2.2										

N. Mitra
I/C LABORATORY

SR. Scientific Assistant
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/206 | 4473

Dated: 9/12/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2021

1. Name & Address of Ind./Unit : Nilothi STP-II
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.11.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	20	Inlet	7.1	188	90	288	14.8	20.1	16.1	Meeting with the standards.
		Outlet	7.2	08	10	42	1.6	4.1	1.0	
		OLMS*	7.2	8.39	4.45	29.37	-	2.99	-	
Total 20										

Mintu
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/207/4474

Dated: 9/12/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2021

1. Name & Address of Ind./Unit : Nilothi STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.11.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results :										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
1	40			10	10	50	10	5	2	Not meeting the standards w.r.t to TSS, BOD & COD.
		Inlet	7.1	300	140	336	15.2	26.6	13.9	
		Outlet	7.2	32	25	80	3.2	2.9	2	
		OLMS*	7.3	52.82	30.86	149.96	-	22.17	-	
Total 40										

Mitra
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/21-22/208

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2021

1. Name & Address of Ind./Unit : Najafgarh STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.11.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	5	Inlet	7.2	200	80	352	19.2	48.2	21.1	Not meeting the standards w.r.t to TSS BOD, COD, & DP.
		Outlet	7.4	30	25	84	1.6	4.9	4.6	
		OLMS*	-	-	-	-	-	-	-	
Total 5										

Remarks: OLMS was found non-functional at the time of DPCC Monitoring

Mitha
I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/222


ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2021

1. Name & Address of Ind./Unit : Vasant Kunj STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.11.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	2.2	Inlet	7.3	224	110	446	22.8	18.2	28.6	Not Meeting the Standards w.r.t TSS, BOD, COD & DP.
		Outlet	7.2	20	14	64	3.6	4.1	6.1	
		OLMS*	7.7	4.94	4.97	21.55	-	2.82	-	
2	3	Inlet	7.5	228	120	512	8.4	20.4	29.7	Not Meeting the Standards w.r.t TSS & COD.
		Outlet	7.1	12	10	80	2	3.9	1.7	
		OLMS*	6.0	6.05	3.01	25.20	-	4.02	-	
Total 5.2										

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/209/4476

Dated: 9/12/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2021

1. Name & Address of Ind./Unit : Rithala STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.11.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
1	Phase-I(40)	Inlet	-	-	10	50	10	5	2	Plant was under Rehabilitation
		Outlet	-	-	-	-	-	-	-	
		OLMS*	-	-	-	-	-	-	-	
2	Ph-II(40)	Inlet	7.2	228	110	416	15.2	17.8	14.1	Meeting the standards
		Outlet	7.3	10	8	40	1.2	3.6	1.2	
		OLMS*	6.9	10.98	8.86	26	-	11.14	-	
Total 80										

Mitha
I/C LABORATORY

A. B. Khan
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/210/4477

Dated: 9/12/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2021

1. Name & Address of Ind./Unit : Pappankalan STP(Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.11.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
1	20			10	10	50	10	5	2	Not meeting theStandards w.r.t TSS, BOD & COD.
		Inlet	7.3	100	46	176	21.6	34.1	10.1	
		Outlet	7.2	28	26	80	4.4	4.2	1.6	
		OLMS*	6.8	43.05	23.65	194.50	-	15.3	-	
Total 20										

N. Mitra
I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/211 / 11178

Date: 9/12/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2021

1. Name & Address of Ind./Unit : Pappankalan STP-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.11.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Remarks
				10	10	50	10	5	2	
	20	Inlet	7.1	132	95	224	18.4	30.1	10.9	Not Meeting the Standards W.r.t BOD.
		Outlet	7.3	8	12	42	3.52	4.1	1.9	
		OLMS*	7.2	8.39	4.45	29.37	-	2.99	-	
Total 20										

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/21-22/212 / 4479

Dated: 9/12/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2021


1. Name & Address of Ind./Unit : Rohini STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.11.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	15	Inlet	7.2	308	140	528	20.8	37.1	20.4	Not meeting the Standards w.r.t TSS, BOD, COD & DP.
		Outlet	7.8	14	11	64	2	5	3.1	
		OLMS*	7.4	21	17.07	99.86	-	11.97	-	
Total 15										

Remarks: OLMS was found non-operational at the time of DPCC Monitoring.

Mishra
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/213/4480

Dated: 9/12/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2021

1. Name & Address of Ind./Unit : Narela STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 15.11.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	10	Inlet	7.3	220	95	336	15.2	29.6	16.9	
		Outlet	7.4	22	14	64	1.6	5	2.9	
		OLMS*	7.3	26.88	11.35	140.17	-	10.29	-	Not Meeting the Standards w.r.t TSS, BOD, COD & DP.
Total 10										

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/214/4481

Dated: 9/12/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2021

1. Name & Address of Ind./Unit : Okhla STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.11.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results :										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	AmmonicalNi trogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
1	30	Inlet	7.2	216	100	50	10	5	2	Meeting the Standards.
		Outlet	7.4	8	7	352	14	14.8	20.9	
		OLMS*	6.37	3.43	6.22	48	0.4	2.1	1.2	
	Total 30						39.46	-	6.30	

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/215/4482

Dated: 9/12/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2021

1. Name & Address of Ind./Unit : Kondli STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.11.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Remarks
				10	10	50	10	5	2	
1	25	Inlet	7.3	224	100	400	16.4	37.2	40.0	Not Meeting the Standards w.r.t TSS & COD.
		Outlet	7.2	12	9	64	1.4	3.9	1.8	
		OLMS*	7.0	11.32	8.83	71.51	-	4.77	-	
Total 25										

Misha
I/C LABORATORY

SR. SCIENTIFIC ASSISTANT
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/216/4483

Dated: 9/12/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2021


1. Name & Address of Ind./Unit : Kondli STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.11.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
1	45	Inlet	7.2	212	100	352	15.2	33.6	36.0	Not Meeting the Standards w.r.t TSS, BOD, COD & DP.
		Outlet	7.4	42	35	124	1.6	5	4.30	
		OLMS*	-	-	-	-	-	-	-	
		Total 45								

Remarks: OLMS was found locked

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/217/4484

Dated: 9/12/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2021

1. Name & Address of Ind./Unit : Kapasahera STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.11.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
1	5	Inlet	7.0	108	80	320	3.6	28.9	14.6	Meeting the standards
		Outlet	7.1	8	10	40	1.2	4.6	1.4	
		OLMS*	7.4	6.55	3.99	33.93	-	3.22	-	
		Total 5								

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/218/4485

Dated: 9/12/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2021

1. Name & Address of Ind./Unit : Yamuna Vihar STP Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 02.11.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	25	Inlet	7.3	316	170	416	24.4	27.8	32.7	Not meeting the Standards w.r.t TSS, BOD, DP & COD.
		Outlet	7.1	34	28	96	1.4	3.5	3.9	
		OLMS*	6.3	49.08	27.83	131.71	-	3.93	-	
Total 25										

N. Mittal
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/219/4486

Dated: 9/12/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2021

1. Name & Address of Ind./Unit : Chilla STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.11.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	9	Inlet	7.3	164	90	320	20.8	16.6	22.6	Not meeting the Standards w.r.t TSS.
		Outlet	7.0	14	10	40	0.8	2.3	1.6	
		OLMS*	7.2	6.8	7.84	57.54	-	1.68	-	
Total 9										

Mukta
I/C LABORATORY

R. B. Arora
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/220/4487

Dated: 9/12/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2021

1. Name & Address of Ind./Unit : Akshardham STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.11.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	1	Inlet	7.4	164	80	272	19.2	36.0	20.6	Meeting the Standards.
		Outlet	7.1	4	5	32	0.4	0.8	1.2	
		OLMS*	7.0	0.84	1.42	9.83	-	0.28	-	
Total 1										

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/221/4488

Dated: 9/12/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2021

1. Name & Address of Ind./Unit : Mehrauli STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.11.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	15	Inlet	7.3	180	80	320	18.6	14.7	36.7	Not meeting the standards w.r.t TSS BOD & COD.
		Outlet	7.2	22	12	64	1.2	4.1	1.8	
		OLMS*	6.8	40.83	10.47	67.16	-	3.21	-	
Total 15										

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/223) 4490

Dated: 9/12/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2021

1. Name & Address of Ind./Unit : Yamuna Vihar STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 02.11.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :


Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
1	10 Ph-1	Inlet	7.4	184	90	50	10	5	2	Not meeting the standards w.r.t BOD, COD & DP.
		Outlet	7.0	10	12	64	0.8	4.2	3.2	
		OLMS*	7.4	18.44	11.80	76.39	-	15.08	-	
2	10 Ph-2	Inlet	6.8	272	120	416	18	24.2	18.0	Not meeting the standard w.r.t TSS, BOD, COD & DP.
		Outlet	7.3	22	18	80	1.2	1.98	3.7	
		OLMS*	-	-	-	-	-	-	-	
Total 20										

Remarks: Ph-II OLMS was not analyzed.

Remarks: Ph-II OLMS was not working.

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/224/4491

Dated: 9/12/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2021


1. Name & Address of Ind./Unit : Okhla STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.11.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
1	12	Inlet	6.9	172	90	50	10	5	2	Not meeting the Standards w.r.t TSS, BOD & COD.
		Outlet	7.3	28	16	300	18.4	26.9	30.1	
		OLMS	-	-	-	80	3.2	4.6	1.6	
	16	Outlet	7.1	18	15	-	-	-	-	Not meeting the Standards w.r.t TSS, BOD & COD.
		OLMS	7.4	20.95	11.89	68	2	3.2	1.1	
	37	Outlet	7.2	26	16	47.84	-	6.06	-	Not meeting the Standards w.r.t TSS, BOD & COD.
		OLMS	7.3	28.49	22.61	74	0.8	4.1	1.7	
	45	Outlet	7.3	30	22	71.62	-	22.16	-	Not meeting the Standards w.r.t TSS, BOD & COD.
		OLMS	7.3	22.6	15.82	84	1.2	4	1.2	
	Total 110					56.5	-	12.28	-	Not meeting the Standards w.r.t TSS, BOD & COD.

Remarks: 12 MGD OLMS was found non-operational at the time of DPCC Monitoring.

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/225/4492

Dated: 9/12/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2021


1. Name & Address of Ind./Unit : Keshopur STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.11.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

3. Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	40	Inlet	7.2	212	90	416	14.8	13.08	19.0	Not meeting the Standards w.r.t TSS,BOD,COD, A.N & D.P.
		Outlet	7.5	52	38	140	2.4	6.4	2.6	
		OLMS*	7.5	74.66	58.67	199.49	-	27.77	-	
2	20	Inlet	7.2	212	90	416	14.8	13.08	19.0	Not meeting the Standards w.r.t TSS, BOD, COD, A.N & D.P.
		Outlet	7.4	58	40	122	4	5.2	5.6	
		OLMS*	7.0	98.62	69.04	411.36	-	18.54	-	
Total 60										

I/C LABORATORY

Mitra

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE (Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/9/4493

Dated: 9/12/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2021

1. Name & Address of Ind./Unit : Molarband Mini STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.11.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	0.66	Inlet	7.2	264	110	432	18.4	20.3	15.1	Not meeting the Standards w.r.t TSS, BOD & COD.
		Outlet	7.4	30	22	76	1.6	2.5	2	
		OLMS*	7.3	18.55	12.74	64.50	-	3.71	-	
Total 0.66										

Mishra
I/C LABORATORY

SR. SCIENTIFIC ASSISTANT
SR. SCIENTIFIC ASSISTANT