



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/1/SS90

Dated: 4/5/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2023

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 25.04.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	Ph-I,II (20)	Inlet	7.2	260	120	384	16	24.2	11.4	Not meeting the standards wrt TSS, BOD & Dissolved Phosphate.
		Outlet	7.5	24	18	48	3.2	3.8	2.4	
		OLMS	7.5	18.01	11.53	71.86	-	10.03	-	
2	Ph-III (70)	Inlet	7.4	288	160	320	18.4	30.5	34.7	Meeting the standards.
		Outlet	7.5	8	6	24	4	2.8	0.9	
		OLMS	7.4	8.19	21.37	38.42	-	0.52	-	
Total 90										

Dr. Nandini Mittal
4/5/2023

Dr.



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/2 / 5591

Dated: 4/5/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2023

1. Name of STP : Delhi Gate (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.04.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	Phase-I,II(15)	Inlet	7.1	220	120	256	18.8	33.6	14.2	Meeting the Standards.
		Outlet	7.3	10	6	16	2.4	3.2	1.1	
		OLMS	7.3	6.42	4.60	20.94	-	3.67	-	
Total 15										

N. Mitra
Dr. N. Mitra
WATER LABORATORY
Scientist



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/3/5592

Dated: 4/5/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2023

1. Name of STP : Delhi Gate (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.04.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
	Phase-I,II(2.2)	Inlet	7.3	212	170	320	15.2	29.6	14.9	Meeting the Standard.
		Outlet	7.5	10	7	20	2.4	3.6	1.5	
		OLMS	7.7	5.67	3.73	19.05	-	2.24	-	
Total 2.2										

Mittra
I/C LABOATORY
Dr. Naita Mittra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/4/5593

Date: 4/5/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2023

1. Name of STP : Keshopur STP (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.04.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	12	Inlet	7.1	228	110	352	11.6	38.6	27.5	Not Meeting the standards wrt TSS, BOD & COD.
		Outlet	7.6	22	12	56	2.4	2.1	1.6	
		OLMS	7.6	9.34	6.69	30.36	-	4.67	-	
Total 12										

N. Mitra
Dr. Nandita Moitra
SCIENTIST D
I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/5/5594

Date: 4/5/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2023

1. Name of STP : SEN Nursing Home (SNH)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.04.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	Phase-I, II (2.2)	Inlet	7.4	224	117	352	14.4	30.2	25.1	Meeting the Standards
		Outlet	7.3	8	5	24	2	3.5	1.5	
		OLMS	7.3	2.56	5.39	25.23	-	6.36	-	
Total 2.2										

Nandita
I/C LABORATORY
Dr. Nandita Moitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Dated: 4/5/2023

Report Number: DPCC/W/STP/23-24/6/5595

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2023

1. Name of STP : Nilothi New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.04.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results :										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	20	Inlet	7.3	196	82	272	11.2	15.4	20.1	Meeting the standards
		Outlet	7.4	8	6	40	1.2	3.7	1.3	
		OLMS	7.7	102.47	55.45	276.46	-	-	-	
Total 20										

N. Mishra
I/C LABORATORY
Dr. Nandita Mishra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Dated: 4/5/2023

Report Number: DPCC/W/STP/23-24/7/5596

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2023

1. Name of STP : Nilothi
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.04.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

3. Date of Inspection :			DPCC Lab							Remarks
4. Samples collected by :										
5. Parameters analyzed and results :										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	40	Inlet	7.6	132	78	240	11.2	18.1	28.9	Not meeting the standards w.r.t TSS & BOD.
		Outlet	7.4	38	20	48	3.2	2.8	1.4	
		OLMS	7.6	20.42	11.28	52.44	-	-	-	
Total 40										

N. Mitta
I/C LABORATORY
Dr. Nandita Mitta
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Dated: 4/5/2023

Report Number DPCC/W/STP/23-24/8/5597

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2023

1. Name of STP : Najafgarh
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.04.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

4. Samples collected by : DPCC Lab

5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	5	Inlet	7.4	212	120	432	13.6	41.9	24.1	Not meeting the standards wrt TSS, BOD, COD, Dissolved Phosphate.
		Outlet	7.2	42	26	88	1.6	4.1	4.2	
		OLMS	7.7	19.40	14.40	77.50	-	12.25	-	
Total 5										

N. Mitra
I/C LABORATORY

Dr. Nandita Moitra
Scientist D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/9/5598

Dated: 4/5/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2023

1. Name of STP : Rithala
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.04.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	Phase-I(40)	Inlet	-	-	-	-	-	-	-	Plant was under Rehabilitation
		Outlet	-	-	-	-	-	-	-	
		OLMS	-	-	-	-	-	-	-	
2	Ph-II(40)	Inlet	7.5	22.4	110	256	11.2	11.6	19.4	Not Meeting the Standards wrt TSS, BOD, COD & Dissolved phosphate.
		Outlet	7.1	26	20	56	2	2.8	2.4	
		OLMS	7.4	11.23	7.49	32.78	-	11.03	-	
Total 80										

N. Mishra
I/C LABORATORY
Dr. Nandita Moitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/10/5599

Dated: 4/5/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2023

1. Name of STP : Pappankalan (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.04.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	20	Inlet	7.6	164	92	288	15.2	18.1	31.9	Not meeting the Standards w.r.t TSS, BOD & Dissolved phosphate.
		Outlet	7.3	36	22	48	2.8	4.2	3.1	
		OLMS	7.5	38.89	30.86	147.96	-	7.7	-	
Total 20										

Nandita
I/C LABORATORY
Dr. Nandita Moitra
Scientist D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/11/5600

Dated: 4/5/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2023

1. Name of STP : Pappankalan Ph-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.04.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results :										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
	20	Inlet	7.6	164	92	288	15.2	18.1	31.9	Meeting the Standards.
Outlet		7.5	6	4	24	0.4	1.9	1.1		
OLMS		7.7	7.20	5.52	39.80	-	1.75	-		
Total 20										

N. Mitra
I/C LABORATORY

Dr. Nandita Moitra
Scientist D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/23-24/12/5601

Dated: 4/5/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2023

1. Name of STP : Rohini
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.04.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results :										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	15	Inlet	7.2	300	145	336	13.2	25.4	21.6	Not meeting the Standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.4	28	20	56	2	4.5	2.4	
		OLMS	7.06	21.36	17.52	146.88	-	9.92	-	
Total 15										

Nandita
I/C LABORATORY

Dr. Nandita Mohan
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>


Report Number: DPCC/W/STP/23-24/13/5602

Dated: 4/5/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2023

1. Name of STP : Narela
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.04.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	10	Inlet	7.4	216	90	176	8.8	20.6	16.9	Not meeting the standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.5	34	19	64	3.6	1.2	2.2	
		OLMS	7.4	17.64	12.20	73.50	-	14.83	-	
Total 10										


I/C LABORATORY
Dr. Nandita Mohan
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/14/5603

Dated: 4/5/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2023

1. Name of STP : Okhla New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.04.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	30	Inlet	7.5	172	90	288	11.6	22.8	20.9	Meeting the Standards.
		Outlet	7.2	8	6	20	0.8	2	1.1	
		OLMS	-	-	-	-	-	-	-	OLMS was found non-operational
Total 30										

Nandita

I/C LABORATORY

Dr. Nandita Mishra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/15/5604

Date: 4/5/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2023

1. Name of STP : Kondli
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 24.04.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	Ph-I (10)	Inlet	7.2	180	86	224	24	41.5	34.8	Meeting the standards.
		Outlet	7.1	6	4	24	1.6	2.8	2	
		OLMS	-	-	-	-	-	-	-	OLMS was found non-operational
2	Ph-III (10)	Outlet	7.4	8	6	31	2.4	2.6	1.9	Meeting the standards.
		OLMS	-	-	-	-	-	-	-	OLMS was found locked
Total 20										

Nandita
I/C LABORATORY
Dr. Nandita Moitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/16/5605

Date: 4/5/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2023

1. Name of STP : Kondli New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 24.04.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	45	Inlet	7.1	244	135	272	18.8	30.5	27.2	Not Meeting the Standards wrt TSS, BOD, COD, Ammonical nitrogen & Dissolved Phosphate.
		Outlet	7.3	60	36	144	5.6	6.2	3.4	
		OLMS	-	-	-	-	-	-	-	OLMS was found non-functional
Total 45										

N. Moitra

I/C LABORATORY

Dr. Nandita Moitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/17/5606

Dated: 4/5/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2023

1. Name of STP : Kapasahera
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 20.04.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	5	Inlet	7.5	184	80	272	4.4	26.4	19.5	Meeting the standards
		Outlet	7.4	8	5	32	2	3.2	1.5	
		OLMS	7.5	8.13	5.99	40.17	-	3.33	-	
Total 5										

N. Moitra
I/C LABORATORY

Dr. Nandita Moitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/18/5607

Dated: 4/5/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2023

1. Name of STP : Yamuna Vihar Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 06.04.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	25	Inlet	6.5-9.0	10	10	50	10	5	2	Not meeting the Standards wrt TSS, BOD & Dissolved Phosphate.
		Outlet	7.3	356	175	272	14.8	23.9	28.6	
		OLMS	7.4	26	13	32	2.4	3.9	3.1	
Total 25			7.7	14.98	6.98	32.81	-	12.72	-	

N. Mitra
I/C LABORATORY
Dr. Nandita Moitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/19/5608

Dated: 4/5/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2023

1. Name of STP : Chilla
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 24.04.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	9	Inlet	7.5	184	66	160	12.8	24.3	17.2	Meeting the Standards.
		Outlet	7.4	8	6	32	2.4	2.9	0.8	
		OLMS	7.4	7.0	4.02	30.0	-	3.48	-	
Total 9										

Nandita

I/C LABORATORY

Dr. Nandita Moitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/20/5609

Dated: 4/5/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2023

1. Name of STP : Akshardham
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.04.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	1	Inlet	7.4	120	47	160	13.6	17.1	19.6	Meeting the Standards.
		Outlet	7.1	4	3	12	0.4	1.6	0.8	
		OLMS	7.7	0.71	1.1	6.2	-	0.03	-	
Total 1										

Nandita
I/C LABORATORY
Dr. Nandita Motra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/21/5610

Dated: 4/5/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2023

1. Name of STP : Mehrauli
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 20.04.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/i)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	15	Inlet	7.3	176	130	320	8.4	15.4	29.6	Not meeting the standards wrt TSS, BOD & COD.
		Outlet	7.2	28	18	64	2	3.5	1.2	
		OLMS	7.5	16.20	14.77	78.90	-	11.83	-	
Total 15										

N. Nandita
I/C LABORATORY
Dr. Nandita Moitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/22/5611

Dated: 4/5/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2023

1. Name of STP : Vasant Kunj
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 20.04.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	2.2	Inlet	7.3	244	130	304	10.4	23.6	28.1	Not meeting the standards wrt TSS, BOD & Dissolved Phosphate.
		Outlet	7.1	30	17	48	2	3.5	4.2	
		OLMS	7.7	6.63	4.46	23.29	-	11.76	-	
2	3	Inlet	7.4	212	145	288	7.2	20.7	29.8	Not meeting the standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.2	46	29	88	1.2	4.4	2.5	
		OLMS	8.1	7.80	4.38	17.23	-	13.16	-	
Total 5.2										

N. Mitta
I/C LABORATORY
Dr. Nandita Mitta
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/24/5612

Dated: 4/5/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2023

1. Name of STP : Okhla
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.04.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	12	Inlet	7.3	276	165	336	12.4	30.4	22.6	Not meeting the Standards wrt TSS, BOD & COD.
		Outlet	7.6	46	26	80	3.6	2.1	2	
		OLMS	-	-	-	-	-	-	-	
	16	Outlet	7.3	8	6	32	2	3.6	1.7	OLMS was under maintenance. Meeting the Standards.
		OLMS	7.7	7.70	12.85	59.98	-	-	-	
	37	Outlet	7.5	36	22	64	3.2	3.9	1.9	Not meeting the Standards wrt TSS, BOD & COD.
		OLMS	-	-	-	-	-	-	-	
	45	Outlet	7.2	42	23	72	2.4	4.2	1.2	OLMS was non functional Not meeting the Standards wrt TSS, BOD & COD.
		OLMS	8.0	22.85	12.85	59.98	-	-	-	
	Total 110									

I/C LABORATORY

Dr. Nandita Moitra

Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/15613

Dated: 4/5/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2023

1. Name of STP : Molarband (Mini STP)
2. Sampling location : Inlet and Outlet of STP
3. Date of inspection : 18.04.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	0.66	Inlet	7.6	260	90	352	16.8	21.2	19.5	Not meeting the Standards wrt TSS, BOD, COD & Dissolved phosphate.
		Outlet	7.2	28	19	64	2.8	2.3	3	
		OLMS	7.6	25.84	9.2	106.1	-	13.38	-	
Total 0.66										

I/C LABORATORY

Dr. Nandita Moitra

Signature



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/23 /5614

Dated: 4/5/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2023

1. Name of STP : Yamuna Vihar
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 06.04.2023
4. Samples collected by : DPCC.Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	10 Ph-1	Inlet	7.2	176	85	272	6.8	12.1	29.2	Not meeting the standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.3	36	15	64	2	3.1	2.7	
		OLMS	7.5	6.75	5.85	37.75	-	10.50	-	
2	10 Ph-2	Inlet	7.5	228	125	224	8.8	21.8	23.9	Not meeting the standard wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.4	30	12	56	2.8	2.1	3.3	
		OLMS	7.7	12.55	8.61	39.36	-	9.84	-	
Total 20										

N. Mishra
I/C LABORATORY
Dr. Nandita Motra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/25] 5615

Dated: 4/5/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2023

1. Name of STP : Keshopur
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.04.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	40	Inlet	7.4	132	100	336	14.8	23.5	16.8	Not meeting the Standards wrt TSS, BOD & COD.
		Outlet	7.3	44	27	104	3.6	4.2	1.5	
		OLMS	7.4	96.0	73.0	288.0	-	20.33	-	
2	20	Inlet	7.4	132	100	336	14.8	23.5	16.8	Not meeting the Standards wrt TSS, BOD, COD, Ammonical nitrogen & Dissolved phosphate.
		Outlet	7.6	36	25	80	4	21.3	14.3	
		OLMS	8.4	94.62	83.25	306.56	-	25.08	-	
Total 60										


I/C LABORATORY
Dr. Nandita Moitra
Scientist



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Dated: 4/5/2023

Report Number: DPCC/W/STP/23-24/26/5616

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2023

1. Name of STP : Ghitorini
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 20.04.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	5	Inlet	7.3	188	54	176	6	24.6	36.5	Not meeting the Standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.1	48	16	56	2.4	2.3	3.9	
		OLMS	7.4	17.51	13.90	40.87	-	10.56	-	
Total 5										

N. Mitra
I/C LABORATORY
Dr. Nandita Moitra
Scientist 'D'