



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/211 / 243

Dated - 17/12/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER -2025

1. Name of STP : Akshardham
2. Sampling location : Inlet and Outlet of STP=
3. Date of sampling : 14.11.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	1		6.5-9.0	10	10	50	10	5	2	230	Meeting the Standards.
		Inlet	7.5	138	100	252	12.8	9.5	10.8		
		Outlet	7.3	2	2	12	0.8	1.6	0.3	140	
		OLMS	7.55	0.69	1.38	6.35	-	0.43			
Total 1											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/212/2414

Dated 17/12/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER -2025

1. Name of STP : Chilla
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 14.11.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results:

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	9	Inlet	7.1	156	120	268	13.6	8.2	6.7		Meeting the Standards.
		Outlet	7.4	6	5	24	2.4	3.2	0.4	170	
		OLMS	7.20	5.36	3.37	19.2	-	1.39			
Total 9											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/213/2415

Dated 17-12-2025

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER -2025

1. Name of STP : SEN Nursing Home (SNH)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 14.11.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Phase-I,II (2.2)	Inlet	7.6	160	140	288	14.8	9.0	10.2		Not meeting the standard wrt Fecal Coliform..
		Outlet	7.2	7	6	36	3.2	3.4	1.8	430	
		OLMS	6.82	4.00	3.34	20.52	-	0.96			
Total 2.2											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/ 214 / 2416

Dated 17-12-2025

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER -2025

1. Name of STP : Delhi Gate (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 14.11.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Phase-I & II (15)	Inlet	7.3	214	133	316	13.2	9.6	9.1		Meeting the standards.
		Outlet	7.1	6	5	16	1.6	3.5	0.5	180	
		OLMS	7.45	6.55	4.35	22.28	-	2.19			
Total 15											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/ **252417**

Dated **17/12/2025**

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER -2025

1. Name of STP : **Delhi Gate (Old)**
2. Sampling location : **Inlet and Outlet of STP**
3. Date of sampling : **14.11.2025**
4. Samples collected by : **DPCC Lab**
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Ph-I & II (10)	Inlet	7.2	228	140	336	12.8	8.8	6.9		Not meeting the standard wrt. Faecal coliform
		Outlet	7.5	9	8	40	1.6	2.7	0.5	640	
		OLMS	7.70	5.62	3.25	17.02	-	1.24			
Total 2.2											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/216/2418

Dated 17-12-2025

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER -2025

1. Name of STP : Kapasahera
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 15.11.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results:

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	5	Inlet	7.4	180	160	432	8.8	11.5	5.4		Not meeting wrt Fecal Coliform
		Outlet	7.3	8	7	28	2.4	3.2	0.7	1100	
		OLMS	5.64	6.10	5.68	27.96	-	3.24			
Total 5											

1
Shukla
I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/2172419

Dated 17-12-2025

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER -2025

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of sampling : 17.11.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Ph-I,II (20)	Inlet	7.8	192	150	352	9.2	11.2	6.4		Meeting the standards.
		Outlet	7.5	7	6	24	3.2	3.5	1.0	180	
		OLMS	7.61	5.59	4.10	18.92	-	1.65			
2	Ph-III (10)	Inlet	7.6	264	170	364	4.8	9.7	7.4		Meeting the standards.
		Outlet	7.5	9	8	32	2.4	3.1	0.6	130	
		OLMS	6.62	5.92	4.34	18.06	-	1.06			
Total 30											

I/C Water Laboratory

Scientist 'B' /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/218/29480

Dated 17-12-2025

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER -2025

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of sampling : 17.11.2025
4. Samples collected by : DPCC Lab
5. Parameters Analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	70 MGD	Inlet	7.6	204	130	296	8	9.8	8.5		Meeting the standards.
		Outlet	7.5	6	7	24	2.4	3.2	0.8	110	
		OLMS	5.57	6.87	3.31	24.44	-	1.17			
Total 70											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/219/2421

Dated: 17-12-2025

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER -2025

1. Name of STP : Rithala
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 17.11.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

5. Parameters analyzed and results											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Ph-I(40)	Inlet	7.9	184	110	312	8.8	11.0	4.2		Meeting the standards
		Outlet	7.5	7	8	32	1.6	2.1	0.9	170	
		OLMS	6.50	6.75	5.40	24.76	-	1.58			
2	Ph-II(40)	Inlet	7	236	140	360	5.2	11.5	6.9		Meeting the standards
		Outlet	7.5	9	6	20	2.4	3.5	0.5	180	
		OLMS	6.50	6.27	5.54	26.99	-	2.41			
Total 80											

I/C Water Laboratory

Scientist 'B'/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number DPCC/W/STP/25-26/ 220 / 2422

Dated 17-12-2025

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER -2025

1. Name of STP : Rohini
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 17.11.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN /100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	25	Inlet	7.2	280	160	484	8	10.4	11.3		Meeting the standards.
		Outlet	7.4	7	8	32	1.6	2.5	1.2	150	
		OLMS	7.09	7.09	4.86	25.24	-	1.05			
Total 25											

I/C Water Laboratory

Scientist 'B'/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/221/2423

Dated 17-12-2025

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER -2025

1. Name of STP : Molarband (Mini STP)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 17.11.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	0.66	Inlet	7.6	168	170	404	20.4	10.3	7.7		Not meeting the standard wrt TSS, BOD & fecal coliform.
		Outlet	7.4	15	13	32	2.4	3.0	1.3	54000	
		OLMS	7.54	27.43	23.03	67	-	2.51			
Total 0.66											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/2242424

Dated 17-12-2025

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER -2025

1. Name of STP : Okhla
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 17.11.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
16		Inlet	7.3	146	135	316	23.6	11.1	10.6		Not meeting the standard wrt Fecal Coliform
		Outlet	7.1	6	7	24	3.2	2.1	1.0		
		OLMS	7.04	5.88	5.08	17.37	-	2.75		540	
Total 16											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/223/2425

Dated 17-12-2025

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER -2025

1. Name of STP : Okhla
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 17.11.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	124 MGD	Inlet	7.3	146	135	316	23.6	11.1	10.6	230	Meeting the Standards.
		Outlet	7.2	5	4	28	1.6	2.0	0.9	180	
		OLMS	7.11	4.89	6.76	31.92	-	0.98			
Total 124											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/224/2426

Dated 17-12-2025

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER -2025

1. Name of STP : Okhla New
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 17.11.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	30	Inlet	7.5	158	140	364	16.8	10.0	10.7		Meeting the Standards.
		Outlet	7.3	6	5	28	2.4	2.5	1.0	130	
		OLMS	7.61	6.06	4.72	30.49	-	1.23			
Total 30											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/225/2427

Dated 17-12-2025

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER -2025

1. Name of STP : Mehrauli
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 18.11.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	15	Inlet	7.3	204	180	460	20.4	11.3	8.7		Not meeting wrt TSS,BOD & Fecal Coliform.
		Outlet	7.5	18	15	44	1.2	3.2	1.0	3500	
		OLMS	7.57	9.71	6.57	34.39	-	3.42			
Total 15											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/226/2423

Dated 17-12-2025

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER -2025

1. Name of STP : Vasant Kunj
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 18.11.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	2.2	Inlet	7.5	244	120	404	8.8	10.3	6.9		Not meeting wrt TSS,BOD,COD &Fecal Coliform
		Outlet	7.4	17	14	56	2.8	4.2	1.2	9200	
		OLMS	7.57	5.76	5.08	25.70	-	2.95			
2	3	Inlet	7.6	196	180	420	13.6	11.9	8.9		Not meeting wrt TSS,BOD,COD &Fecal Coliform
		Outlet	7.4	24	18	52	2.4	2.9	1.4	16000	
		OLMS	7.66	6.69	5.97	29.73	-	3.42			
Total 5.2											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/227/2429

Dated 17-12-2025

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER -2025

1. Name of STP : Ghtorini
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 18.11.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	5	Inlet	7.3	148	120	284	11.6	12.8	10.8		Not meeting wrt TSS,BOD,COD &Fecal Coliform.
		Outlet	7.2	18	12.5	52	2.8	3.9	1.0	17000	
		OLMS	7.92	13.26	8.36	39.78	-	3.26			
Total 5											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/228/2430

Dated 17-12-2025

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER -2025

1. Name of STP : Kondli
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 21.11.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Ph-I (10)	Inlet	7.8	260	150	388	12.8	11.2	5.2		Meeting the Standards.
		Outlet	7.2	10	8	28	2.4	3.1	1.3	140	
		OLMS	7.55	6.20	6.80	23.10		3.43			
2	Ph-II & III (25+10)	Outlet	7.3	9	6	40	1.6	3.9	1.0	180	
		OLMS	7.57	6.30	6.50	23.10		3.44			
Total 45											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/229/243/

Dated 17-12-2025

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER -2025

1. Name of STP : Kondli New
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 21.11.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Ph-IV (45)	Inlet	7.3	9	6	40	1.6	3.9	1.0	180	Meeting the Standards.
		Outlet	7.57	6.30	6.50	23.10		3.44			
		OLMS	7.3	9	6	40	1.6	3.9	1.0	180	
Total 45											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/25-26/230/2432

Dated 17-12-2025

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER -2025

1. Name of STP : Pappankalan (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 24.11.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	30	Inlet	7.4	204	140	360	16.8	9.6	9.1		Meeting the Standards.
		Outlet	7.2	10	8	24	2.4	2.5	0.8	150	
		OLMS	7.11	8.90	6.39	29.21		1.39			
Total 30											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/23/2433

Dated 17-12-2025

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER -2025

1. Name of STP : Pappankalan Ph-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 24.11.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
	20	Inlet	7.8	204	140	360	16.8	9.6	9.1		Meeting the standards.
		Outlet	7.9	8	6	32	1.2	3.7	0.6	110	
		OLMS	7.05	5.65	5.53	29.01		1.78			
Total 20											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number DPCC/W/STP/25-26/232/2434

Dated 17-12-2025

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER -2025

1. Name of STP : Najafgarh
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 24.11.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Fecal Coliform MPN/100ml	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)		
			6.5-9.0	10	10	50	10	5	2		
1	5	Inlet	7.7	259	170	388	16.8	10.7	11.2	95	Meeting the Standards.
		Outlet	7.4	9	8	44	2	2.2	1.1		
		OLMS	7.42	7.30	6.20	28.30		1.94			
Total 5											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/25-26/233/2435

Dated 17-12-2025

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER -2025

1. Name of STP : Yamuna Vihar Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 26.11.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	25	Inlet	7.5	176	150	332	8.4	11.7	5.9		Not meeting the Standards wrt TSS, BOD & COD.
		Outlet	7.7	27	15	64	2.8	3.5	1.1	2400	
		OLMS	7.33	18.90	14.74	57.92		15.59			
Total 25											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



LIFE
Lifestyle for
Environment

Report Number: DPCC/W/STP/25-26/234/2436

Dated 17-12-2025

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER -2025

1. Name of STP : Yamuna Vihar
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 26.11.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results:

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	10 Ph-1	Inlet	7.2	268	170	388	4.8	9.9	8.0		Not meetings wrt TSS, BOD & Fecal Coliform.
		Outlet	7.3	36	16	36	2	2.4	1.1	1800	
		OLMS	7.53	12.29	8.08	37.15	-	23.18			
2	15 Ph-2	Inlet	7.4	188	160	348	6.4	11.0	6.1		Meeting the standards.
		Outlet	7.5	8	7	40	1.6	2.1	0.9	170	
		OLMS	7.80	5.34	2.09	18.10	-	3.60			
Total 20											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/235/2437

Dated 17-12-2025

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2025

1. Name of STP : Sonia Vihar
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 26.11.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	7	Inlet	-	-	-	-	-	-	-	-	No sampling was conducted due to no flow at the time of DPCC inspection.
		Outlet	-	-	-	-	-	-	-	-	
		OLMS									
Total 7											

Shukla
I/C Water Laboratory

[Signature]
Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/2342438

Dated 17-12-2025

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER -2025

1. Name of STP : Narela
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 27.11.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	10	Inlet	7.6	180	140	324	18.8	11.8	9.4		Meeting the standards.
		Outlet	7.1	9	8	32	1.6	3.3	0.7	180	
		OLMS	7.00	6.32	5.01	19.84		0.84			
Total 10											

I/C Water Laboratory

Scientist 'B' /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/25-26/2378439

Dated 17-12-2025

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER -2025

1. Name of STP : Keshopur STP (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 28.11.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	12	Inlet	7.5	182	130	292	11.2	10.7	12.4		Meeting the standards.
		Outlet	7.6	8	7	24	1.6	1.4	1.0	210	
		OLMS	7.49	5.64	4.52	20.84		1.71			
Total 12											

I/C Water Laboratory

Scientist B/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/25-26/238/2440

Dated 17-12-2025

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER -2025

1. Name of STP : Keshopur
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 28.11.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	60	Inlet	7.3	244	160	380	12.4	10.9	8.7		Meeting the Standards.
		Outlet	7.3	8	6	28	1.2	3.7	0.8		
		OLMS	7.42	7.52	5.60	24.10		2.35		150	
2	20	Outlet	7.7	7	6	32	2.4	2.2	0.9		Meeting the Standards..
		OLMS	7.31	7.72	6.34	26.59		2.29		220	
Total 60											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/239/244/

Dated 17-12-2025

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2025

1. Name of STP : Nilothi New, Phase-I
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 28.11.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	40	Inlet	7.2	168	160	372	12	12.4	11.6		Not meeting the standards wrt. Fecal coliform.
		Outlet	7.1	9	8	28	2.4	2.8	0.8	350	
		OLMS	7.43	11.85	7.33	51.56	-	2.96	-	-	
Total 20											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/240/2442

Dated 17-12-2025

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER -2025

1. Name of STP : Nilothi Phase-II
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 28.11.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results :											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	20	Inlet	7.4	214	140	312	13.6	11.2	9.2		Meeting the standards.
		Outlet	7.3	8	6	28	1.6	2.4	0.8	110	
		OLMS	7.10	7	5.09	37.41	-	3.23	-	-	
Total 40											

I/C Water Laboratory

Scientist B /Analyst