



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/212/S31

Dated 05/01/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2023

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 14.12.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters										Remarks
Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	70 MGD	Inlet	7.4	236	150	352	12.4	20.1	24.5	Meeting the standards.
		Outlet	7.1	8	4	20	1.6	2.1	1.4	
		OLMS	-	8.5	4.8	34.9	-	-	-	pH & Ammonical Nitrogen readings not shown in OLMS
Total 70										

I/C LABORATORY

M. Mohan

Dr. Nandita Moitra
Scientist D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/213/532

Dated 05/01/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2023

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 14.12.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	Ph-I,II (20)	Inlet	7.7	228	105	384	10.8	24.1	19.2	Not meeting the standards wrt TSS, BOD & COD.
		Outlet	7.4	34	23	68	4.4	2.5	1.7	
		OLMS	7.5	14.5	8.3	49.7	-	8.0	-	
		Inlet	-	-	-	-	-	-	-	
2	Ph-III (10)	Outlet	-	-	-	-	-	-	-	OLMS was non-functional
		OLMS	-	-	-	-	-	-	-	
Total 30										

I/C LABORATORY

N. Mohita

Dr. Mandita Mohita

Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/214/S33

Dated

05/01/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2023

1. Name of STP : Delhi Gate (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.12.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	Phase-I,II(15)	Inlet	6.5-9.0	10	10	50	10	5	2	Meeting the Standards.
		Outlet	7.3	140	80	96	6.8	19.1	9	
		OLMS	7.46	8	5	24	0.8	1.3	1.1	
Total 15			7.5	7.4	4.3	27.0	-	3.0	-	

Maitra
I/C LABORATORY

Dr. Nandita Maitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccnctms.nctc.in>)



Report Number: DPCC/W/STP/23-24/215/534

Dated: 05/01/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2023

1. Name of STP : Delhi Gate (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.12.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
Phase-1,II(2.2)		Inlet	7.6	176	105	144	4.4	23.2	11.9	Meeting the Standard.	
		Outlet	7.4	8	6	44	2.4	2.3	1.6		
		OUMS	7.3	5.0	2.0	15.0	-	1.1	-		
Total 2.2											

Mukta
I/C LABORATORY

Dr. Nandita Moitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccrms.nic.in>)



Report Number: DPCC/W/STP/23-24/216/535

Dated: 05/01/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2023

1. Name of STP : Keshopur STP (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.12.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Anmonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	12	Inlet	7.7	232	160	352	13.2	21.1	20.1	Not Meeting the standards wrt TSS, BOD & COD.
		Outlet	7.6	22	14	52	2	1.1	1.1	
		OLMS	8.5	7.9	5.5	34.2	-	1.9	-	
Total 12										

Mitra
I/C LABORATORY

Dr. Nandita Moitra
Secretary



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/217/536

Dated 05/01/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2023

1. Name of STP : SEN Nursing Home (SNH)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.12.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	Phase-I,II (2.2)		6.5-9.0	10	10	50	10	5	2	
		Inlet	7.4	248	160	224	5.6	19.9	19.9	Meeting the Standards
		Outlet	7.2	10	7	36	2.4	1.6	1.5	
		OLMS	7.8	6.2	4.2	25.3	-	1.1	-	
Total 2.2										

I/C LABORATORY

Signature

Dr. Nandita Moitra
Scientist 'B'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccnms.nic.in>)



Report Number: DPCC/W/STP/23-24/218/537

Dated

05/01/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2023

1. Name of STP : Nilothi New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 15.12.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	20	Inlet	7.1	152	115	352	12.8	11.1	10.1	Meeting the standards
		Outlet	7.2	6	5	28	1.6	1.3	1.2	
		OLMS	7.6	8.4	6.1	37.8	-	2.4	-	
Total 20										

I/C LABORATORY

M. Nandita

Dr. Nandita Meotra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccnmns.nic.in>)



Report Number: DPCC/W/STP/23-24/219/538

Dated 05/01/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2023

1. Name of STP : Nilothi
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 15.12.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
1	40	Inlet	7.2	192	90	208	13.2	24.8	28.5	Not meeting the standards wrt TSS, BOD & COD.	
		Outlet	7.5	22	14	56	2.9	1.6	1.8		
		OLMS	7.5	24.5	19.3	100.6	-	15.2	-		
		Total 40									

I/C LABORATORY

M. K. Sharma

Lt. Mandita Mehta
Deputy Engineer



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISRT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocnms.nic.in>)



Report Number DPCC/W/STP/23-24/220/539

Dated 05/01/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2023

1. Name of STP : Najafgarh
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 15.12.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	5	Inlet	6.5-9.0	10	10	50	10	5	2	Not meeting the standards wrt TSS, BOD and COD
			7.3	232	95	272	12.8	20.5	9.1	
		Outlet	7.7	28	16	72	1.2	2.2	1.2	
		OLMS	6.7	21.7	15.7	93.3	-	12.2	-	
Total 5										

Nandita
I/C LABORATORY

Dr. Nandita Moitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

((Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccnmcs.nic.in>)



Report Number: DPCC/W/STP/23-24/221/540

Dated: 08/01/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2023

1. Name of STP : Rithala
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.12.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	Ph-1(40)	Inlet	6.5-9.0	10	10	50	10	5	2	Plant was under Rehabilitation
		Outlet	-	-	-	-	-	-	-	
		GLMS	-	-	-	-	-	-	-	
2	Ph-II(40)	Inlet	7.3	188	120	304	10	10.1	6.1	Meeting the standards
		Outlet	7.8	10	8	36	2.8	2.4	1.4	
		OLMS	7.8	7.8	5.6	21.6	-	7.8	-	
Total 80										

I/C LABORATORY

Alkanta

Dr. Nandita Moura



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kushnere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/222/541

Dated

05/01/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2023

1. Name of STP : Pappankalan (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 15.12.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	20	Inlet	7.6	216	115	320	17.2	22.1	23.1	Not meeting the Standards wrt TSS, BOD COD & Dissolved Phosphate.
		Outlet	7.5	34	19	92	4.4	2.3	2.5	
		OLMS	-	-	-	-	-	-	-	
Total 20										OLMS was non functional

I/C LABORATORY

M. Mohita

Dr. Mandita Mohita



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/23-24/223/542

Date: 08/01/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2023

1. Name of STP : Pappankalan Ph-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 15.12.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
20		Inlet	6.5-9.0	10	10	50	10	5	2	Meeting the Standards.
		Outlet	7.3	152	150	192	12.4	20.1	19.1	
		OLMS	7.9	8	4	28	2.8	1.6	1.1	
Total 20			-	-	-	-	-	-	-	OLMS was non-functional

OLMS was non-functional

I/C LABORATORY

Murli

Dr. Nandita Prabha
Scientist IV



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number DPCC/W/STP/23-24/224/543

Dated

05/01/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2023

1. Name of STP : Rohini
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.12.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	15	Inlet	7.6	296	175	296	8.4	20.7	1.1	Not meeting the Standards wrt TSS, BOD & COD.
		Outlet	7.8	24	12	52	4.4	3.1	1.3	
		OLMS	7.6	19.5	12.8	72.7	-	12.2	-	
Total 15										

I/C LABORATORY

M. K. Sharma

Dr. Nandita Moltra

Scientist IV



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nct.in>)



Report Number: DPCC/W/STP/23-24/225/544

Dated 05/01/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2023

1. Name of STP : Narela
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.12.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	10	Inlet	6.5-9.0	10	10	50	10	5	2	Not meeting the standards wrt TSS, BOD & COD.
		Outlet	7.4	176	70	160	7.6	15.4	9.4	
		OLMS	7.2	28	14	52	1.6	1.3	1.1	
Total 10			7.0	8.6	4.7	37.3	-	6.3	-	

Mukherjee

I/C LABORATORY

Dr. Nandita Mohita

Senior Scientist



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/226/545

Dated 05/01/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2023

1. Name of STP : Okhla New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.12.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	30	Inlet	6.5-9.0	10	10	50	10	5	2	Meeting the Standards.
		Outlet	7.3	180	80	232	8	14.1	21.1	
		OLMS	7.2	8	6	32	0.8	1.1	1.2	
Total 30			6.8	5.6	3.5	23.3	-	0.9	-	

I/C LABORATORY

N. Mohita

Dr. Nandita Mohita
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccnctm.nic.in>)



Report Number: DPCC/W/STP/23-24/227/546

Dated 05/01/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2023

1. Name of STP : Kondli
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.12.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	Ph-I (10)	Inlet	6.5-9.0	10	10	50	10	5	2	Meeting the standards.
		Outlet	7.3	228	98	304	4.8	27.6	25.4	
		OLMS	7.5	10	6	40	1.6	2.1	1.5	
2	Ph-II (25)	Outlet	7.6	6.7	4.4	25.3	-	4.8	-	Meeting the standards
		Outlet	7.1	8	5	32	1.2	1.5	1.3	
		OLMS	-	-	-	-	-	-	-	
3	Ph-III (10)	Outlet	7.5	8	4	16	1.6	1.4	1.4	Meeting the standards.
		OLMS	7.3	18.4	5.0	41.6	-	0.2	-	
		Total 45								

I/C LABORATORY

NMishra



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/228/547

Dated 05/01/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2023

1. Name of STP : Kondli New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.12.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	Ph-IV (45)	Inlet	7.3	204	175	224	5.2	18.9	23.5	Not Meeting the Standards wrt TSS, BOD & COD.
		Outlet	7.5	30	16	88	2.4	1.1	1.3	
		OLMS	-	-	-	-	-	-	-	
Total 45										OLMS was non-functional

W/C LABORATORY

Dr. Mandira Motra

Signature



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/229/548

Dated 05/01/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2023

1. Name of STP : Kapasahera
2. Sampling location : Inlet and Outlet of STP
3. Date of inspection : 16.12.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	5	Inlet	7.2	240	80	256	4.8	22.1	10.2	Meeting the standards
		Outlet	7.6	8	6	40	2.8	2.3	1.6	
		OLMS	7.4	9.6	4.7	23.2	-	2.0	-	
Total 5										

I/C LABORATORY

M. N. Maitra

Dr. Nandita Maitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, JSPT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/230/549

Dated 05/01/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2023

1. Name of STP Yamuna Vihar Ph-III
2. Sampling location Inlet and Outlet of STP
3. Date of Inspection 07.12.2023
4. Samples collected by DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	25	Inlet	7.1	196	120	176	4.8	16.4	24.1	Not meeting the Standards wrt TSS & BOD.
		Outlet	7.4	28	16	40	1.2	1.6	1.9	
		OUMS	7.2	22.8	11.3	57.8	-	8.9	-	
Total 25										

LIFE LABORATORY

Maita

Dr. Nandita Moitra
Scientist TP



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccnmcs.nic.in>)



Report Number: DPCC/W/STP/23-24/231/SSO

Dated 05/01/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2023

1. Name of STP : Chilla
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.12.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	9	Inlet	7.3	216	70	192	6.8	22.5	14.3	Meeting the Standards.
		Outlet	7.7	10	7	48	2.8	1.9	1.5	
		OLMS	7.1	4.1	2.4	17.3	-	0.9	-	
Total 9										

W/C LABORATORY

Signature

Dr. Mandita Mohita
Secretary



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/232/551

Dated 05/01/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2023

1. Name of STP : Akshardham
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.12.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
1	1	Inlet	7.6	224	105	240	5.2	14.3	16.6	Meeting the Standards.	
		Outlet	7.2	8	6	32	2	1.4	1.7		
		OLMS	7.6	0.8	1.5	0.7	-	0.1	-		
Total 1										OLMS was non-functional	

WATER LABORATORY

M. Nautia

Dr. Nautia Mohita
Scientist 'B'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccnctms.nic.in>)



Report Number: DPCC/W/STP/23-24/233/SS2

Dated 05/01/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2023

1. Name of STP : Mehrauli
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 16.12.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	15	Inlet	6.5-9.0	10	10	50	10	5	2	Not meeting the standards wrt TSS & BOD .
		7.2	140	85	208	3.6	10.3	20.3		
		Outlet	7.4	26	19	48	1	1.5	1.3	
		OLMS	6.9	18.8	5.4	36.1	-	7.7	-	
Total 15										

W/C LABORATORY

N. Nautia

Dr. Nandita Nautia
Senior IIT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccommittee.in>)



Report Number: DPCC/W/STP/23-24/234 | 553

Dated 05/01/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2023

1. Name of STP : Vasant Kunj
2. Sampling location : Inlet and Outlet of STP
3. Date of inspection : 16.12.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	2.2	Inlet	7.4	200	175	352	14.8	17.3	23.1	Not meeting the standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.7	20	17	56	1.2	1.4	2.4	
		OLMS	7.2	7.4	4.5	27.0	-	2.3	-	
2	3	Inlet	7.7	272	140	288	2.4	16.5	2.6	Not meeting the standards wrt TSS& BOD .
		Outlet	7.6	26	19	32	0.4	1.9	1.4	
		OLMS	7.7	9.6	7.7	43.5	-	2.5	-	
Total 5.2										

Mudra

Dr. Nandita Mohita
Secretary



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccommittee.nic.in>)



Report Number: DPCC/W/STP/23-24/235

SS 4

Dated 05/01/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2023

1. Name of STP : Yamuna Vihar
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 07.12.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	10 Ph-1	Inlet	6.5-9.0	10	10	50	10	5	2	Not meeting the standards wrt TSS & BOD .
			7.3	172	90	80	3.2	13.5	12.4	
		Outlet	7.1	22	12	44	1.6	2.6	1.8	
2	10 Ph-2	OLMS	7.2	-	5.9	41.8	-	7.5	-	TSS reading not shown in OLMS
		Inlet	7.2	132	95	160	6.4	12.2	17.7	
		Outlet	7.6	14	11	46	0.8	1.6	7	
		OLMS					-		-	
Total 20										Not meeting the standard wrt TSS,BOD, & Dissolved Phosphate..

I/C LABORATORY

M. K. Singh

Dr. Tejashwini Mishra

Secretary



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISRT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccnms.nic.in>)



Report Number: DPCC/W/STP/23-24/9/555

Dated 05/01/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2023

1. Name of STP : Molarband (Mini STP)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.12.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	0.66	Inlet	7.8	320	160	336	5.2	24.8	22.1	Not meeting the Standards wrt TSS, BOD & COD.
		Outlet	7.6	30	21	64	0.8	1.2	1.2	
		OLMS	7.6	22.67	15.8	73.6	-	7.4	-	
Total 0.66										

W/C LABORATORY

Mukta

Dr. Nandita Moitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccrinis.nic.in>)



Report Number: DPCC/W/STP/23-24/236 | **SS6**

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2023

Dated **05/01/2024**

1. Name of STP : **Okhla**
2. Sampling location : **Inlet and Outlet of STP**
3. Date of Inspection : **13.12.2023**
4. Samples collected by : **DPCC Lab**
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	12	Inlet	7.4	224	125	240	6	15.7	12.8	Not meeting the Standards wrt TSS & BOD.
		Outlet	7.6	26	12	48	2	1.3	1.6	
		OLMS	7.2	29.5	14.5	66.9	-	16.8	-	
	16	Outlet	7.7	10	6	40	2	1.9	1.5	Meeting the Standards.
		OLMS	6.8	6.2	4.2	17.6	-	2.4	-	
		Outlet	7.5	26	17	32	2.4	2.5	1.5	
	37	OLMS	7.2	18.3	11.4	55.0	-	6.7	-	Not meeting the Standards wrt TSS & BOD.
		Outlet	7.6	34	21	64	3.2	2.4	1.4	
		OLMS	7.2	21.9	10.3	60.0	-	9.0	-	
	Total 110									

Mishra
I/C LABORATORY

Dr. Vandana Mishra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/23-24/237/557

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2023

Dated 08/01/2024

1. Name of STP : Keshopur
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.12.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	40	Inlet	6.5-9.0	10	10	50	10	5	2	Not meeting the Standards wrt TSS, BOD & COD.
		7.6	176	115	192	20.8	25.5	19.9		
		Outlet	7.4	32	20	56	3.6	1.3	1.9	
		OLMS	-	-	-	-	-	-	-	
2	20	Inlet	7.6	176	115	192	20.8	25.5	19.9	Not meeting the Standards wrt TSS & BOD.
		Outlet	7.5	28	13	48	4	3.6	2.5	
		OLMS	7.2	86	68	273	-	17.7	-	
Total 60										

I/C LABORATORY

Mude

Dr. Manjula Mohita
Scientist 'B'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building,

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/238/558

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2023

Dated 05/01/2024

1. Name of STP : Ghitorni
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 16.12.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	5	Inlet	6.5-9.0	10	10	50	10	5	2	Not meeting the Standards wrt TSS & BOD.
		Outlet	7.6	124	62	160	3.6	10.6	19.9	
		OLMS	7.8	28	14	48	1.6	1.5	1.6	
Total 5			7.4	8.2	6.5	19.2	-	4.9	-	

I/C LABORATORY

Alvina

Dr. Mandita Mohita
Scientist IV