



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/01/1801

Dated 01/05/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2025

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of sampling : 04.04.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Fecal Coliform MPN/100ml	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
1	Ph-I,II (20)	Inlet	6.9	216	270	680	24	12.0	2	230	Not meeting the standards wrt COD & Fecal coliform.
		Outlet	7	7	10	60	2.4	1	0.9	540	
		OLMS	7.7	7.8	5.6	22.9	-	1.5	-	-	
2	Ph-III (10)	Inlet	7.1	236	260	656	21.2	9.9	3.7	-	Not meeting the standard wrt Fecal coliform.
		Outlet	7.2	7	8	48	1.2	0.9	0.8	460	
		OLMS	8.5	6.9	3.3	16.2	-	0.5	-	-	
Total 30											

I/C Water Laboratory

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



LIFE
Lifestyle for
Environment

Report Number: DPCC/W/STP/25-26/02/1802

Dated 01/05/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2025

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of sampling : 04.04.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and Results											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		Fecal Coliform MPN/100ml
1	70 MGD		6.5-9.0	10	10	50	10	5	2	230	Meeting the standards.
		Inlet	7.3	320	140	440	31.6	10.6	4.9	-	
		Outlet	7.2	9	10	48	2.8	0.9	0.9	62	
		OLMS	7.7	5.4	9.3	54.9	-	1.9	-	-	
Total 70											

I/C Water Laboratory

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/25-26/03/1803

Dated 01/05/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2025

1. Name of STP : Keshopur STP (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 04.04.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	12	Inlet	7.1	256	260	624	17.2	11.9	6.9	-	Meeting the standards.
		Outlet	7.4	8	10	40	1.2	0.7	0.5	130	
		OLMS	7.7	39	26	145	-	17.1	-	-	
Total 12											

I/C Water Laboratory

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



LIFE
Lifestyle for
Environment

Report Number: DPCC/W/STP/25-26/04/1804

Dated 01/05/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2025

1. Name of STP : Keshopur
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 04.04.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	40	Inlet	6.5-9.0	10	10	50	10	5	2	230	Meeting the standards.
			6.8	230	100	256	10	11.2	9.8	-	
		Outlet	6.8	3	8	12	2	0.6	1.4	110	
2	20	OLMS	7.4	10.4	6.1	17.6	-	2.5	-	-	Meeting the standards.
		Outlet	7.6	7	8	36	1.6	0.7	1.8	170	
		OLMS	-	-	-	-	-	-	-	-	
Total 60											

[Signature]

I/C Water Laboratory

[Signature]

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/05/1805

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2025

Dated 01/05/2025

1. Name of STP : Okhla
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 09.04.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
	16	Inlet	7.5	164	190	516	22.8	9.9	11.0	-	
		Outlet	7.3	14	12	36	0.8	1.1	0.8	350	
		OLMS	8.2	12.2	6.7	42.1	-	6.8	-	-	
Total 16											
Not meeting the Standards wrt TSS, BOD & Fecal coliform.											

I/C Water Laboratory

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/25-26/06/1806

Dated 01/05/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2025

1. Name of STP : Okhla New
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 09.04.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)		Fecal Coliform MPN/100ml
1	30	Inlet	6.5-9.0	10	10	50	10	5	2	230	Meeting the Standards.
			7.5	196	120	408	16.8	10.3	9.1	-	
		Outlet	7.8	8	4	28	1.2	0.7	0.9	180	
		OLMS	7.9	6.6	5.3	24.6	-	1.6	-	-	
Total 30											

I/C Water Laboratory

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/25-26/07/1807

Dated 01/05/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2025

1. Name of STP : Okhla
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 09.04.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	124 MGD	Inlet	6.5-9.0	10	10	50	10	5	2	230	Meeting the Standards.
			7.5	164	190	516	22.8	9.9	11.0	-	
		Outlet	7.4	5	6	32	0.8	0.7	0.7	130	
		OLMS	8.0	8.4	7.2	32.3	-	1.6	-	-	
Total 124											

I/C Water Laboratory

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/08/1808

Dated 01/05/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2025

1. Name of STP : Molarband (Mini STP)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 09.04.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	0.66	Inlet	6.5-9.0	10	10	50	10	5	2	230	Not meeting the standard wrt TSS, BOD, COD & Fecal Coliform.
			7.4	184	170	496	16.4	9.2	11.6	-	
		Outlet	6.9	34	36	120	2.8	1.6	1.1	2700	
		OLMS	7.5	27.0	13.8	93.0	-	7.8	-	-	
Total 0.66											

Signature

I/C Water Laboratory

Signature

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/25-26/09/1809

Dated 01/05/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2025

1. Name of STP : Kapasahera
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 10.04.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results:

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml		
1	5	Inlet	7.8	226	130	472	19.2	10	5	2	230	Meeting the Standard.
		Outlet	6.9	9	8	36	1.6		0.8	1.6	210	
		OLMS	7.6	8.7	5.4	40.1	-		3.9	-	-	
Total 5												

I/C Water Laboratory

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



LIFE
Lifestyle for
Environment

Report Number: DPCC/W/STP/25-26/10/1810

Dated 01/05/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2025

1. Name of STP : Vasant Kunj
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 10.04.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml		
1	2.2	Inlet	6.5-9.0	10	10	50	10	5	2	230	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.	
			7.3	234	200	544	21.6	11.0	11.1	-		
			Outlet	7.6	45	36	136	1.2	0.9	0.6		9100
		OLMS	8.8	6.3	4.8	29.8	-	8.3	-	-		
2	3	Inlet	7.5	162	180	396	26	12.7	9.1	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.	
			Outlet	7.1	37	36	116	2.4	0.6	0.7		21000
			OLMS	8.7	12.5	8.2	40.8	-	7.9	-		-
		Total 5.2										

Signature

I/C Water Laboratory

Signature

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/11/(81)

Dated 01/05/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2025

1. Name of STP : Ghitorini
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 10.04.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	5	Inlet	6.5-9.0	10	10	50	10	5	2	230	Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform.
			6.9	156	150	424	5.6	12.8	11.7	-	
			7.1	28	40	160	2	1.0	1.1	22000	
		OLMS	7.5	31.1	20.7	79.2	-	7.7	-	-	
Total 5											

I/C Water Laboratory

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/25-26/12/1812

Dated 01/05/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2025

1. Name of STP : Mehrauli
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 10.04.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	15	Inlet	6.5-9.0	10	10	50	10	5	2	230	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
			7.6	226	220	712	14.8	9.4	11.0	-	
			7.8	39	16	60	2.8	0.7	0.9	2500	
		OLMS	8.1	9.8	8.6	48.0	-	7.2	-		
Total 15											

Signature

I/C Water Laboratory

Signature

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/25-26/13/1813

Dated: 01/05/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2025

1. Name of STP : Rithala
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 11.04.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

Parameters analyzed and results												
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml		
1	Ph-I(40)		6.5-9.0	10	10	50	10	5	2	230		
		Inlet	7.2	124	160	480	19.6	10.2	9.3	-	Meeting the standards	
		Outlet	7.1	10	8	40	0.8	0.8	0.7	81		
		OLMS	7.8	9.2	7.0	33.7	-	1.9	-	-		
2	Ph-II(40)	Inlet	7.7	188	190	520	20.8	8.5	8.9	-	Meeting the standards	
		Outlet	7.3	8	5	36	0.8	0.8	0.6	130		
		OLMS	7.9	9.0	6.9	33.8	-	3.0	-	-		
		Total 80										

Signature

I/C Water Laboratory

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number DPCC/W/STP/25-26/14/1814

Dated 01/05/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2025

1. Name of STP : Rohini
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 11.04.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	15	Inlet	6.5-9.0	10	10	50	10	5	2	230	Not meeting the standards wrt TSS, BOD & Fecal Coliform.
			168	100	288	14.4	9.3	9.0	-		
		Outlet	7.2	14	12	44	1.2	0.5	0.6	430	
		OLMS	7.7	9.5	5.7	22.9	-	2.5	-	-	
Total 15											

I/C Water Laboratory

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



LIFE

Lifestyle for Environment

Report Number: DPCC/W/STP/25-26/15/1815

Dated 01/05/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2025

1. Name of STP : Nilothi
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 17.04.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters									Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml		
1	40	Inlet	6.5-9.0	10	10	50	10	5	2	230	Not meeting the standards wrt Fecal Coliform.	
			7.2	170	110	356	13.2	10.3	6.5	-		
			7.5	10	8	36	3.2	0.3	0.8	540		
		OLMS	7.7	14.3	9.5	66.7	-	4.1	-	-		
Total 40												

I/C Water Laboratory

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Dated 01/05/2025

Report Number: DPCC/W/STP/25-26/16/1816

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2025

1. Name of STP : Nilothi New
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 17.04.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results :												
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters									Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml		
1	20	Inlet	6.5-9.0	10	10	50	26.8	12.8	6.0	230	Meeting the Standards.	
		Outlet	7.8	244	220	628	0.8	0.8	1.1	81		
		OLMS	7.2	6	8	36	-	4.8	-	-		
Total 20			7.5	16.8	10.7	57.2						

Signature

I/C Water Laboratory

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)

Report Number DPCC/W/STP/25-26/17/1817 Dated 01/05/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2025

1. Name of STP : Najafgarh
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 17.04.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results .											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Fecal Coliform MPN/ 100ml	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
1	5		6.5-9.0	10	10	50	10	5	2	230	
		Inlet	7.7	172	140	340	61.2	11.9	8.6	-	
		Outlet	7.4	7	8	40	1.6	0.6	1.4	220	Meeting the Standards.
		OLMS	7.7	7.0	7.0	30.4	-	3.0	-	-	
Total 5											

Signature

I/C Water Laboratory

Signature

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/25-26/18/1818

Dated 01/05/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2025

1. Name of STP : Pappankalan (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 17.04.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	20	Inlet	6.5-9.0	10	10	50	10	5	2	230	Not meeting the Standard wrt Fecal Coliform.
		Outlet	7.2	96	150	480	15.6	10.3	5.9	-	
		OLMS	7.8	9	8	48	7.2	0.9	1.2	9500	
Total 20			12.3	12.2	7.0	58.3	-	-	-		

I/C Water Laboratory

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/25-26/19/1814

Dated 01/05/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2025

1. Name of STP : Pappankalan Ph-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 17.04.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
	20	Inlet	6.5-9.0	10	10	50	10	5	2	230	Meeting the standards.
			7.2	96	150	480	15.6	10.3	5.9	-	
		Outlet	7.2	6	8	32	1.2	0.8	0.3	180	
		OLMS	7.7	6.2	6.5	32.5	-	1.8	-	-	
Total 20											

بھسائی

I/C Water Laboratory

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/25-26/20/1820

Dated 01/05/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2025

1. Name of STP : Yamuna Vihar Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 21.04.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	25	Inlet	6.5-9.0	10	10	50	10	5	2	230	Not meeting the Standard wrt TSS, BOD & fecal coliform.
		Outlet	6.9	164	120	400	11.6	12.8	4.3	-	
		OLMS	7.2	11	16	48	1.6	0.6	0.9	1200	
	Total 25		8.1	19.3	16.1	50.7	-	32.5	-		

[Signature]

I/C Water Laboratory

[Signature]

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)

Report Number: DPCC/W/STP/25-26/21/ (82)

Dated 01/05/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2025

1. Name of STP : Yamuna Vihar
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 21.04.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results:

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks		
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml			
1	10 Ph-1	Inlet	6.5-9.0	10	152	160	416	21.6	5	2	230	Not meeting the standards wrt TSS, BOD & Fecal Coliform	
			7.0								5.4		
		Outlet	7.4	14	16	48	1.6	1.3	0.6	930			
		OLMS	-	-	-	-	-	-	-	-			
2	10 Ph-2	Inlet	6.8	120	140	448	13.6	9.4	6.4			Meeting the Standards.	
		Outlet	7.2	8	8	44	1.6	0.9	1.0	72			
		OLMS	6.8	8.9	8.8	28.8	-	13.1	-	-			
		Total 20											

Signature

I/C Water Laboratory

Signature

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/25-26/22/1822.

Dated 01/05/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2025

1. Name of STP : Sonia Vihar
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 21.04.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	7	Inlet	6.5-9.0	10	10	50	10	5	2	230	Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform.
			7.2	218	190	480	28.8	10.2	2.7		
		Outlet	7.1	14	12	76	3.6	0.8	0.5	320	
		OLMS	7.2	9.1	13.2	63.9	-	1.8	-	-	
Total 7											

1/5/25

I/C Water Laboratory

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/25-26/23/1823

Dated 01/05/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2025

1. Name of STP : Narela
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 22.04.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	10	Inlet	6.5-9.0 7.2	10 168	10 140	50 440	10 16.8	5 10.2	2 9.2	230 -	Not meeting the standards wrt BOD & Fecal coliform.
		Outlet	7.6	10	12	36	1.2	0.6	0.6	350	
		OLMS	7.5	7.0	4.9	21.9	-	1.7	-	-	
Total 10											

I/C Water Laboratory

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/25-26/24/1824

Dated 01/05/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2025

1. Name of STP : Delhi Gate (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 23.04.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	Ph-I & II (2.2)	Inlet	6.5-9.0	10	10	50	10	5	2	230	Meeting the Standards.
			7.3	178	190	512	17.6	11.1	4.7		
		Outlet	7.1	5	4	32	0.8	0.9	0.5	190	
			OLMS	8.4	3.8	3.3	18.4	-	1.6	-	
Total 2.2											

I/C Water Laboratory

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/25-26/25/1825

Dated 01/05/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2025

1. Name of STP : Delhi Gate (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 23.04.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	Phase-I & II (15)	Inlet	6.5-9.0	10	10	50	10	5	2	230	Meeting the standards.
			6.9	172	160	496	18.8	12.1	5.0		
		Outlet	7.5	4	4	24	0.4	0.3	0.9	150	
		OLMS	7.9	6.6	2.3	22.2	-	4.6	-	-	
Total 15											

I/C Water Laboratory

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/26/1826

Dated 01/05/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2025

1. Name of STP : SEN Nursing Home (SNH)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 23.04.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	Phase-I,II (2.2)	Inlet	6.5-9.0	10	10	50	10	5	2	230	Meeting the Standards.
		Outlet	6.8	126	110	320	16.4	9.3	4.7	94	
		OLMS	7.3	4	5	28	0.4	0.8	0.6	-	
Total 2.2			5.6	6.1	7.2	2.3	-	23.1			

I/C Water Laboratory

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/25-26/27/1927

Dated 01/05/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2025

1. Name of STP : Akshardham
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 23.04.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	1	Inlet	6.5-9.0	10	10	50	10	5	2	230	Meeting the Standards.
		Outlet	7.1	128	120	364	18.8	12.9	4.2	110	
		OLMS	7.5	8	5	24	0.8	0.6	0.9	-	
Total 1											

I/C Water Laboratory

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for
Environment

Report Number: DPCC/W/STP/25-26/28/1828

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2025

Dated 01/05/2025

1. Name of STP : Chilla
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 23.04.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results:

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters									Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml		
1	9	Inlet	6.5-9.0	10	10	50	10	5	2	230	Meeting the Standards.	
		Outlet	6.9	174	150	456	22.4	11.9	5.8	180		
		OLMS	7.6	6	8	48	1.2	0.7	1.7	-		
Total 9			7.9	8.7	5.8	34.7	-	6.1	-			

Signature

I/C Water Laboratory

Signature
SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/25-26/29/1824

Dated 01/05/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2025

1. Name of STP : Kondli
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 23.04.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	Ph-I (10)		6.5-9.0	10	10	50	10	5	2	230	Meeting the Standards.
		Inlet	7.5	144	130	448	13.6	10.3	4.7		
		Outlet	7.2	7	7	36	1.2	0.8	1.0	180	
		OLMS	7.6	6.3	5.9	23.0	-	4.6	-	-	
2	Ph-II & III (25+10)	Outlet	7	8	10	32	0.8	0.8	0.9	210	Meeting the Standards.
		OLMS	7.6	6.2	5.0	24.2	-	4.5	-	-	
Total 45											

I/C Water Laboratory

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/25-26/30/1830

Dated 01/05/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2025

1. Name of STP : Kondli New
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 23.04.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	Ph-IV (45)	Inlet	6.5-9.0	10	10	50	10	5	2	230	Not meeting the Standard wrt TSS, BOD & Fecal Coliform.
			7.1	152	160	480	24	11.6	4.2		
		Outlet	7.4	12	13	44	2.4	1.2	0.7	3500	
		OLMS	7.5	15.6	18.9	46.10	-	5.5	-	-	
Total 45											

[Signature]

I/C Water Laboratory

[Signature]
SSA/Analyst