



DELHI POLLUTION CONTROL COMMITTEE
WATER LABORATORY
4th FLOOR, ISBT BUILDING, KASHMERE GATE, DELHI-06
visit us at : <http://dpcc.delhigovt.nic.in>

WASTE WATER QUALITY STATUS OF DRAIN

REPORT NO: DPCC/W/D/2025/01-27/1787
Date of Sampling: - 7/04/2025

dated: 23/4/2025

S.No.	Sampling location	pH	TSS (mg/l)	COD (mg/l)	BOD (mg/l)
	Standards	5.5- 9.0	100	250	30
1.	Najafgarh Drain	7.3	116	192	76
2.	Metcalfe House Drain	NO FLOW			
3.	Khyber Pass Drain				
4.	Sweeper Colony Drain				
5.	Magazine Road Drain				
6.	ISBT Drain	7.2	162	216	74
7.	Tonga Stand Drain	NO FLOW			
8.	Civil Mill Drain				
9.	SEN Nursing Home Drain	7.1	132	232	86
10.	Drain No. 14	NO FLOW			
11.	Power House Drain	7.2	166	240	90
12.	Indrapuri Drain	7.2	196	220	70
13.	Sonia Vihar Drain	7.0	146	144	60
14.	Kailash Nagar Drain	7.2	274	224	56
15.	Shastri Park Drain	NO FLOW			
16.	Barapulla Drain	7.0	107	332	110
17.	Maharani Bagh Drain	7.3	352	580	180
18.	Old Agra Canal Drain	NO FLOW			
19.	Jaitpur Drain				
20.	Sarita Vihar Pool	7.0	494	380	130
21.	Tuglakabad Drain	7.1	436	356	115
22.	Drain Near LPG Bottling Plant	NO FLOW			
23.	Drain Near Sarita Vihar Bridge (Mathura Road)				
24.	Shahdara Drain	7.0	384	268	92
25.	Sahibabad Drain	6.8	544	620	210
26.	Molarband Drain	TAPPED			
27.	Abul Fazal Drain	7.8	91	260	90

Shweta

I/C WATER LAB

Dr. Shweta Gupta
Incharge (Water Laboratory)

[Signature]
SSA/Analyst