



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)




Report Number: DPCC/W/STP/25-26/61/195


Dated : 30/06/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE -2025

1. Name of STP : Yamuna Vihar Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 05.06.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	25	Inlet	7.6	216	140	400	33.6	11.5	6.9		Not meeting the Standards wrt TSS, BOD & fecal coliform.
		Outlet	7.2	21	20	48	1.2	0.9	0.5	920	
		OLMS	7.55	34.30	25.88	69.09		26.43			
Total 25											


I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)


SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Dated 30-06-2025

Report Number: DPCC/W/STP/25-26/62/1952

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2025

1. Name of STP : Yamuna Vihar Ph-I,II
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 05.06.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results:

5. Parameters analyzed and results.											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	10 Ph-1	Inlet	7	236	210	484	32	9.7	10.6		Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform
		Outlet	7.5	18	23	56	1.2	0.8	1.6	810	
		OLMS	7.49	25.25	-	44.02		24.48			
2	10 Ph-2	Inlet	7.2	280	230	460	33.6	10.4	11.3		. Meeting the standards.
		Outlet	7.4	7	8	24	2	0.6	1.2	140	
		OLMS	7.34	11.43	7.09	35.62		15.54			
Total 20											

Shweta

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

[Signature]

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number DPCC/W/STP/25-26/63/1953

Dated 30/06/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2025

1. Name of STP : Najafgarh
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 06.06.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and Results :												
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Fecal Coliform MPN/100ml	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)			
			6.5-9.0	10	10	50	10	5	2	230		
1	5	Inlet	7.1	156	120	300	47.2	11.0	4.5		Meeting the Standards.	
		Outlet	7.3	8	7	24	1.2	0.5	1.0	81		
		OLMS	7.53	8.40	8.20	30.70		2.62				
Total 5												

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

SSA/Analys



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/64/1954

Dated 30/06/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2025

1. Name of STP : Pappankalan (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 06.06.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	20	Inlet	7.4	230	160	368	19.2	10.9	4.7		Not meeting the Standards w.r.t. Fecal Coliform.
		Outlet	7.1	9	8	32	1.6	0.6	1.0	280	
		OLMS	7.76	12.67	9.98	60.31		1.85			
Total 20											

Shweta

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

[Signature]
SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/25-26/65/1955

Dated 30/06/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2025

1. Name of STP : Pappankalan Ph-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 06.06.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
	20	Inlet	7.4	230	160	368	19.2	10.9	4.7		Meeting the standards.
		Outlet	6.9	7	10	36	1.2	0.7	0.9	130	
		OLMS	7.68	5.63	4.33	26.06	-	1.47	-	-	
Total 20											

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/66/1956

Dated: 30/06/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2025

1. Name of STP : Rithala
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 09.06.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

5. Parameters analyzed and results											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Ph-I(40)	Inlet	7.5	164	150	340	12	9.8	8.3	-	Meeting the standards
		Outlet	7.3	5	8	24	2.4	0.8	0.8	81	
		OLMS	7.99	9.29	7.44	34.08		2.17			
2	Ph-II(40)	Inlet	7.8	182	140	324	23.2	10.6	8.7	-	Meeting the standards
		Outlet	7.1	8	6	32	1.6	3.2	0.6	180	
		OLMS	7.85	8.68	7.68	37.41		3.34			
Total 80											

Shweta
I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

[Signature]
SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number DPCC/W/STP/25-26/67/1957

Dated 30/06/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2025

1. Name of STP : Rohini
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 09.06.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	15	Inlet	7.6	198	150	368	12.8	10.0	8.2	-	Meeting the standards.
		Outlet	7.1	10	8	32	0.4	1.1	0.7	170	
		OLMS	7.89	8.14	4.64	26.34		2.15			
Total 15											

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/68/1958

Dated 30/06/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2025

1. Name of STP : Vasant Kunj
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 09.06.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	2.2	Inlet	7.8	198	150	408	11.2	9.4	11.2	-	Not meeting the standards wrt TSS, BOD,COD & Fecal Coliform.
		Outlet	7.5	19	18	76	1.6	1.5	0.6	5400	
		OLMS	-	-	-	-	-	-	-	-	OLMS is non -operational.
2	3	Inlet	7.6	174	160	428	21.2	9.9	9.4	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.3	26	13	52	1.2	1	0.7	24000	
		OLMS	-	-	-	-	-	-	-	-	OLMS is non -operational.
Total 5.2											

I/C Water Laboratory
Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/69/1959

Dated 30/06/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2025

1. Name of STP : Ghitorini
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 09.06.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	5	Inlet	7.1	208	170	464	16	10.9	10.3	-	Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.7	34	18	60	1.6	0.8	1.2	16000	
		OLMS	7.40	22.96	13.45	52.48	-	5.58	-	-	
Total 5											

Shweta

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

[Signature]

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/25-26/70/1960

Dated 30/06/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2025

1. Name of STP : Mehrauli
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 09.06.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	15	Inlet	7.4	256	130	428	17.6	12.4	12.4	-	Not meeting the standards wrt TSS, BOD,COD & Fecal Coliform.
		Outlet	7.3	19	16	44	1.6	0.8	1.0	2400	
		OLMS	7.99	14.50	8.28	47.29	-	5.36	-	-	
Total 15											

Shweta

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

[Signature]

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/25-26/71/1961

Dated 30/06/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2025

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of sampling : 10.06.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Ph-I,II (20)	Inlet	7.9	168	100	280	11.2	10.7	5.9	-	Meeting the standards.
		Outlet	7.7	7	8	28	2	1.1	0.8	110	
		OLMS	7.57	8.30	5.88	28.37		1.64			
2	Ph-III (10)	Inlet	7.4	176	80	192	12	11.2	9.2		Meeting the standards.
		Outlet	7.1	6	7	24	2	0.9	0.8	220	
		OLMS	7.96	8.30	5.64	24.95		1.30			
Total 30											

Shweta Gupta
I/C Water Laboratory
Incharge (Water Laboratory)

[Signature]
SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/72/1962

Dated 30/06/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE -2025

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of sampling : 10.06.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	70 MGD	Inlet	7.2	64	100	248	20.4	11.2	5.4	-	Not meeting the standards wrt. Fecal coliform.
		Outlet	7.6	10	8	28	1.2	1.0	0.7	280	
		OLMS	7.89	8.81	5.50	32.32		1.84			
Total 70											

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)




Report Number: DPCC/W/STP/25-26/73/1963

Dated 30/06/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2025

1. Name of STP : Delhi Gate (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 11.06.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results											
S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Ph-I & II (2.2)	Inlet	7.5	156	120	276	33.6	9.4	6.4		Meeting the standards.
		Outlet	7.8	6	6	20	1.2	0.9	1.0	150	
		OLMS	7.46	4.08	5.11	17.46		1.27			
Total 2.2											


I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)


SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/74/1964

Dated 30/06/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE - 2025

1. Name of STP : Delhi Gate (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 11.06.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Phase-I & II (15)	Inlet	7.7	184	140	312	32	10.5	7.4		Meeting the standards.
		Outlet	7.3	5	4	12	1.2	0.6	0.6	180	
		OLMS	7.42	6.65	5.92	22.90	-	2.01			
Total 15											

I/C Water Laboratory
Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/75/1965

Dated 30/06/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2025

1. Name of STP : SEN Nursing Home (SNH)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 11.06.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results.

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Phase-I,II (2.2)	Inlet	7.2	148	120	308	33.6	12	7.5		Meeting the Standards.
		Outlet	7.9	7	8	36	2	0.8	0.7	110	
		OLMS	6.35	6.45	2.98	20.62	-	2.52			
Total 2.2											

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/25-26/76/1966

Dated 30/06/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2025

1. Name of STP : Akshardham
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 11.06.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonica INitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	1	Inlet	7.4	216	160	388	47.2	10.5	4.2		Meeting the standards.
		Outlet	7.7	4	2	12	1.2	0.3	0.9	84	
		OLMS	7.54	0.97	1.68	8.07	-	0.52	-	-	
Total 1											

Shweta

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

[Signature]
SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/25-26/77/1967

Dated 30/06/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2025

1. Name of STP : Chilla
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 11.06.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results:

5. Parameters analyzed and results.											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	9	Inlet	7.2	112	120	270	12	11.9	8.5		Meeting the standards.
		Outlet	7.8	8	5	20	2.4	0.6	1.7	130	
		OLMS	7.40	9.60	6.40	38.40	-	6.58			
Total 9											

Shweta

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

[Signature]

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/78/1968

Dated 30/06/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2025

1. Name of STP : Kondli New
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 11.06.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Ph-IV (45)	Inlet	7.9	104	120	284	23.2	10.7	11.2		Meeting the standards.
		Outlet	7.3	10	9	32	1.6	0.9	1.4	190	
		OLMS	7.65	7.60	5.60	26.90	-	3.55	-	-	
Total 45											

Shweta
I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

[Signature]
SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/79/1969

Dated 30/06/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2025

1. Name of STP : Kondli
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 11.06.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Ph-I (10)	Inlet	7.4	96	120	280	20	10.3	10.1		Meeting the standards.
		Outlet	7.6	6	7	28	2	0.8	1.1	170	
		OLMS	7.87	6.20	3.20	14.50	-	3.63			
2	Ph-II & III (25+10)	Outlet	7.1	12	8	32	1.2	0.6	0.8	280	Not meeting the Standard wrt TSS & Fecal Coliform.
		OLMS	-	-	-	-	-	-			OLMS was non-functional.
Total 45											

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/80/1970

Dated 30/06/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2025

1. Name of STP : Narela
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 12.06.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	10	Inlet	7.1	202	140	320	17.6	10	9.4		Meeting the standards.
		Outlet	7.2	8	9	32	1.6	1.3	0.6	130	
		OLMS	-	-	-	-	-	-	-	-	OLMS was non-functional.
Total 10											

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/81/1971

Dated 30/06/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE -2025

1. Name of STP : Keshopur
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 13.06.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	40	Inlet	7.8	244	140	312	19.2	12.8	8.5	-	Meeting the standards.
		Outlet	7.1	8	6	24	0.8	0.8	0.9	84	
		OLMS									OLMS was non-functional.
2	20	Outlet	7.6	6	8	32	0.8	0.9	0.8	110	Meeting the standards.
		OLMS	7.16	8.41	11.16	51.73	-	3.37	-	-	
Total 60											

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/25-26/82/ 1972

Dated 30/06/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2025

1. Name of STP : Keshopur STP (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 13.06.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results											
S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	12	Inlet	7.8	170	140	332	14.4	11.2	12.2	-	Meeting the standards.
		Outlet	7.2	8	10	36	1.2	1.2	1	130	
		OLMS	7.9	22.12	13.16	63.46	-	4.11	-	-	
Total 12											

Shweta

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

[Signature]

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/44/83/1973

Dated 30/06/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2025

1. Name of STP : Nilothi
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 13.06.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	40	Inlet	7.7	172	120	288	15.6	9.9	10.1		Not meeting the standards w.r.t Fecal Coliform.
		Outlet	7.9	7	8	24	0.8	0.8	1.0	310	
		OLMS	7.64	14.34	8.90	66.21	-	3.06	-	-	
Total 40											

Shweta

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

[Signature]

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/45/84/1974

Dated 30/06/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2025

1. Name of STP : Nilothi New
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 13.06.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	20	Inlet	6.9	70	100	244	18.4	10.6	5.2		Meeting the standards.
		Outlet	7.1	6	8	28	1.6	0.7	0.8	142	
		OLMS	7.59	7.98	6.87	41.53	-	4.72	-	-	
Total 20											

Shweta

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

[Signature]
SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/25-26/85/1975

Dated 30/06/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2025

1. Name of STP : Okhla
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 16.06.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	124 MGD	Inlet	7.8	250	120	268	10.8	11.5	4.3	-	meeting the Standards
		Outlet	7.5	4	6	20	0.8	0.6	0.9	120	
		OLMS	8.13	8.86	6.56	36.74	-	3.80	-	-	
Total 124											

Shweta

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

[Signature]

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/86/1976

Dated 30/06/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2025

1. Name of STP : Okhla
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 16.06.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
	16	Inlet	7.5	228	140	316	16.8	12.1	5.4		Not meeting the Standards w.r.t. Fecal coliform.
		Outlet	7.1	9	8	32	1.2	1	0.6	270	
		OLMS	7.79	14.28	7.79	49.17	-	7.55			
Total 16											

Shweta
I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

[Signature]
SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/87/ 1977

Dated 30/06/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2025

1. Name of STP : Okhla New
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 16.06.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and Results .											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	30	Inlet	7.6	208	120	280	17.2	12.9	9.7	-	Meeting the Standards.
		Outlet	7.2	6	8	24	1.6	0.6	0.5	210	
		OLMS	7.52	4.67	4.73	24.20	-	1.90	-	-	
Total 30											

Shweta

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

[Signature]

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/88/1978

Dated 30/06/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2025

1. Name of STP : Molarband (Mini STP)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 16.06.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	0.66	Inlet	-	-	-	-	-	-	-	-	No Sampling was conducted due to no flow at the time of DPCC inspection.
		Outlet	-	-	-	-	-	-	-	-	
		OLMS	-	-	-	-	-	-	-	-	
Total 0.66											

Shweta

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

[Signature]

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/89/ 1979

Dated 30/06/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2025

1. Name of STP : Kapasahera
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 17.06.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results:

5. Parameters analyzed and results:

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	5	Inlet	7.6	228	160	320	12	10.5	12.2	-	Meeting the Standard.
		Outlet	7.1	9	6	20	0.8	0.8	0.6	210	
		OLMS	7.65	9.35	6.68	47.74	-	3.73	-	-	
Total 5											

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/90/1980

Dated 30/06/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2025

1. Name of STP : Sonia Vihar
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 18.06.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	7	Inlet	-	-	-	-	-	-	-	-	No Sampling was conducted due to no flow at the time of DPCC inspection.
		Outlet	-	-	-	-	-	-	-	-	
		OLMS	-	-	-	-	-	-	-	-	
Total 7											

Shruti
I/C Water Laboratory
Incharge (Water Laboratory)

[Signature]
SSA/Analyst