



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



LiFE
Lifestyle for
Environment

ANALYSIS REPORT OF OKHLA CETP (24 MLD) FOR THE MONTH OF APRIL-2025

Report Number: DPCC/W/CETP/25-26/01/4788


Dated: 01/05/2025


1. Name & Address of Ind. / Unit : OKHLA CETP (24 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 09.04.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS*
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.1	5.5-9.0	7.3	6-9	OLMS was non-functional
2	TSS	508	600	64	100	
3	COD	664	750	144	250	
4	BOD (3 days at 27° C)	210	300	36	30	
5	Oil & Grease	16.4	20.0	1.2	10.0	
6	Ammonical Nitrogen as N	12.8	50	3.3	50	
7	Sulphide	3.8	5.0	1.8	2.0	
8	Phosphate	10.3	15.0	2.0	5.0	

All values are in mg/l except pH

Flow: 1.864 MLD


I/C Water Laboratory


SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccemms.nic.in>)



ANALYSIS REPORT OF BADLI CETP (12 MLD) FOR THE MONTH OF APRIL-2025

Report Number: DPCC/W/CETP/25-26/02/1789

Dated: 01/05/2025

1. Name & Address of Ind. / Unit
2. Sampling location
3. Date of Sampling
4. Sample analyzed and results
5. Parameters analyzed and result

BADLI CETP (12 MLD)

Inlet and Outlet of CETP

11.04.2025

DPCC LAB

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.9	5.5-9.0	7.3	6-9	8.4
2	TSS	272	600	64	100	7.4
3	COD	424	750	112	250	21.5
4	BOD (3 days at 27° C)	140	300	27	30	8.2
5	Oil & Grease	14	20.0	7.6	10.0	-
6	Ammonical Nitrogen as N	3.9	50	0.5	50	-
7	Sulphide	3.8	5.0	1.6	2.0	-
8	Phosphate	0.8	15.0	0.1	5.0	-

All values are in mg/l except pH

Flow: - 2.59 MLD

[Signature]

I/C Water Laboratory

[Signature]

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



ANALYSIS REPORT OF MANGOLPURI CETP (2.4 MLD) FOR THE MONTH OF APRIL-2025

Report Number: DPCC/W/CETP/25-26/03/1790

Dated: 01/05/2025

- | | |
|-----------------------------------|---------------------------|
| 1. Name & Address of Ind. / Unit | MANGOLPURI CETP (2.4 MLD) |
| 2. Sampling location | Inlet and Outlet of CETP |
| 3. Date of Sampling | 15.04.2025 |
| 4. Sample analyzed and results | DPCC LAB |
| 5. Parameters analyzed and result | |

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.9	5.5-9.0	7.4	6-9	7.1
2	TSS	260	600	90	100	26.2
3	COD	440	750	96	250	166.8
4	BOD (3 days at 27° C)	140	300	27.5	30	27.0
5	Oil & Grease	19.2	20.0	9.6	10.0	-
6	Ammonical Nitrogen as N	11.9	50	1.6	50	-
7	Sulphide	2.5	5.0	1.6	2.0	-
8	Phosphate	7.6	15.0	0.6	5.0	-

All values are in mg/l except pH

Flow: 1.41 MLD

Shubli

I/C Water Laboratory

[Signature]

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



ANALYSIS REPORT OF MAYAPURI CETP (12 MLD) FOR THE MONTH OF APRIL-2025

Report Number: DPCC/W/CETP/25-26/04/1791

Dated: 01/05/2025

1. Name & Address of Ind. / Unit : MAYAPURI CETP (12 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 15.04.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7	5.5-9.0	7.4	6-9	7.8
2	TSS	272	600	76	100	42
3	COD	448	750	100	250	149
4	BOD (3 days at 27° C)	150	300	28	30	17.3
5	Oil & Grease	12	20.0	5.2	10.0	-
6	Ammonical Nitrogen as N	8.2	50	4	50	-
7	Sulphide	3	5.0	1.9	2.0	-
8	Phosphate	4.3	15.0	0.6	5.0	-

All values are in mg/l except pH

Flow: 3.84 MLD

I/C Water Laboratory

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



ANALYSIS REPORT OF NANGLOI CETP (12 MLD) FOR THE MONTH OF APRIL-2025

Report Number: DPCC/W/CETP/25-26/05/1792

Dated: 01/05/2025

1. Name & Address of Ind. / Unit : NANGLOI CETP (12 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 15.04.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.3	5.5-9.0	7.2	6-9	7.1
2	TSS	456	600	82	100	12.5
3	COD	480	750	116	250	40.3
4	BOD (3 days at 27° C)	160	300	28	30	7.8
5	Oil & Grease	10.4	20.0	1.6	10.0	-
6	Ammonical Nitrogen as N	15.2	50	6.5	50	-
7	Sulphide	3.2	5.0	1.4	2.0	-
8	Phosphate	8.6	15.0	0.5	5.0	-

All values are in mg/l except pH

Flow: 2.38 MLD

I/C Water Laboratory

SSA/Analyst

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)**LIFE**
Lifestyle for
Environment**ANALYSIS REPORT OF NARAINA CETP (21.6 MLD) FOR THE MONTH OF APRIL-2025**

Report Number: DPCC/W/CETP/25-26/06/1793

Dated: 01/05/2025

1. Name & Address of Ind. / Unit : **NARAINA CETP (21.6 MLD)**
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 15.04.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.8	5.5-9.0	7.3	6-9	7.6
2	TSS	160	600	50	100	24.1
3	COD	344	750	64	250	99.5
4	BOD (3 days at 27° C)	125	300	26	30	20.9
5	Oil & Grease	6.8	20.0	8.4	10.0	-
6	Ammonical Nitrogen as N	10.9	50	1.6	50	-
7	Sulphide	2.7	5.0	1.3	2.0	-
8	Phosphate	5.4	15.0	0.4	5.0	-

All values are in mg/l except pH

FLOW: 5.48 MLD

I/C Water Laboratory

SSA/Analyst

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)**ANALYSIS REPORT OF JHILMIL CETP (16.8 MLD) FOR THE MONTH OF APRIL-2025**

Report Number: DPCC/W/CETP/25-26/07/1794

Dated: 01/05/2025

1. Name of CETP : **JHILMIL CETP (16.8 MLD)**
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 16.04.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.4	5.5-9.0	7.2	6-9	7.4
2	TSS	532	600	32	100	49.0
3	COD	520	750	84	250	126.0
4	BOD (3 days at 27° C)	180	300	27.5	30	16.0
5	Oil & Grease	37.6	20.0	5.2	10.0	-
6	Ammonical Nitrogen as N	9.1	50	1.5	50	-
7	Sulphide	2.9	5.0	1.2	2.0	-
8	Phosphate	14.3	15.0	0.9	5.0	-

All values are in mg/l except pH

Flow: 2.29 MLD

I/C Water Laboratory

SSA/Analyst

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)**LIFE**
Lifestyle for
Environment**ANALYSIS REPORT OF GTK CETP (6 MLD) FOR THE MONTH OF APRIL-2025**

Report Number: DPCC/W/CETP/25-26/08/1795

Dated: 01/05/2025

1. Name & Address of Ind. / Unit : **GTK CETP (6 MLD)**
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 16.04.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.4	5.5-9.0	7.1	6-9	OLMS was Non-functional
2	TSS	412	600	72	100	
3	COD	424	750	124	250	
4	BOD (3 days at 27° C)	150	300	32	30	
5	Oil & Grease	28.8	20.0	4.8	10.0	
6	Ammonical Nitrogen as N	8.6	50	3.9	50	
7	Sulphide	4.5	5.0	1.6	2.0	
8	Phosphate	2.1	15.0	1.1	5.0	

All values are in mg/l except pH

Flow: 2.18 MLD

I/C Water Laboratory

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



ANALYSIS REPORT OF SMA CETP (12 MLD) FOR THE MONTH OF APRIL-2025

Report Number: DPCC/W/CETP/25-26/09/1796

Dated: 01/05/2025

1. Name & Address of Ind. / Unit : SMA CETP (12 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 16.04.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.2	5.5-9.0	7.1	6-9	7.1
2	TSS	504	600	44	100	15.3
3	COD	408	750	68	250	66.4
4	BOD (3 days at 27° C)	170	300	24	30	12.5
5	Oil & Grease	26.4	20.0	3.2	10.0	-
6	Ammonical Nitrogen as N	5.8	50	1.5	50	-
7	Sulphide	3.1	5.0	1.6	2.0	-
8	Phosphate	10.7	15.0	2	5.0	-

All values are in mg/l except pH

Flow: 2.71 MLD

I/C Water Laboratory

SSA/Analyst

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)**LIFE**
Lifestyle for
Environment**ANALYSIS REPORT OF BAWANA CETP (35 MLD) FOR THE MONTH OF APRIL-2025**

Report Number: DPCC/W/CETP/25-26/10/1797

Dated: 01/05/2025

1. Name & Address of Ind. / Unit : BAWANA CETP (35 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 22.04.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.6	5.5-9.0	7	6-9	7.6
2	TSS	508	600	50	100	25.8
3	COD	552	750	96	250	34.8
4	BOD (3 days at 27° C)	180	300	28	30	8.7
5	Oil & Grease	20.8	20.0	2	10.0	-
6	Ammonical Nitrogen as N	8.6	50	2.7	50	-
7	Sulphide	3.4	5.0	1.1	2.0	-
8	Phosphate	5.6	15.0	0.6	5.0	-

All values are in mg/l except pH

Flow: 31.41 MLD

I/C Water Laboratory

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



ANALYSIS REPORT OF NARELA CETP (24 MLD) FOR THE MONTH OF APRIL-2025

Report Number: DPCC/W/CETP/25-26/11/1798

Dated: 01/05/2025

1. Name & Address of Ind. / Unit : NARELA CETP (22.5 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 22.04.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.8	5.5-9.0	7.4	6-9	7.8
2	TSS	472	600	84	100	4.2
3	COD	528	750	104	250	25.1
4	BOD (3 days at 27° C)	170	300	32.5	30	4.7
5	Oil & Grease	29.6	20.0	6.4	10.0	-
6	Ammonical Nitrogen as N	9.4	50	1.8	50	-
7	Sulphide	2.5	5.0	1.4	2.0	-
8	Phosphate	1.6	15.0	0.2	5.0	-

All values are in mg/l except pH

Flow: 7.46 MLD

I/C Water Laboratory

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



ANALYSIS REPORT OF WAZIRPUR CETP (24 MLD) FOR THE MONTH OF APRIL-2025

Report Number: DPCC/W/CETP/25-26/12/1799

Dated: 01/05/2025

1. Name & Address of Ind. / Unit : **WAZIRPUR CETP (24 MLD)**
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 22.04.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS*
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.6	5.5-9.0	7.3	6-9	8.6
2	TSS	172	600	96	100	18.6
3	COD	408	750	140	250	42.1
4	BOD (3 days at 27° C)	130	300	34	30	4.8
5	Oil & Grease	18	20.0	3.6	10.0	-
6	Ammonical Nitrogen as N	7.5	50	2.9	50	-
7	Sulphide	2.4	5.0	1.2	2.0	-
8	Phosphate	2.3	15.0	0.3	5.0	-

All values are in mg/l except pH
Flow: - 3.77 MLD

I/C Water Laboratory

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



ANALYSIS REPORT OF LAWRENCE ROAD CETP (12 MLD) FOR THE MONTH OF APRIL-2025

Report Number: DPCC/W/CETP/25-26/13/1800

Dated: 01/05/2025

1. Name & Address of Ind. / Unit : LAWRENCE ROAD (12 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 22.04.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS*
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.7	5.5-9.0	7	6-9	7.9
2	TSS	264	600	94	100	34.6
3	COD	432	750	88	250	101.9
4	BOD (3 days at 27° C)	130	300	30	30	24.6
5	Oil & Grease	16.4	20.0	2.4	10.0	-
6	Ammonical Nitrogen as N	8.2	50	2.2	50	-
7	Sulphide	2.8	5.0	1.4	2.0	-
8	Phosphate	2.3	15.0	0.3	5.0	-

All values are in mg/l except pH

Flow: 1.54 MLD

I/C Water Laboratory

SSA/Analyst