



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



LIFE
Lifestyle for
Environment

ANALYSIS REPORT OF OKHLA CETP (24 MLD) FOR THE MONTH OF JUNE 2025

Report Number: DPCC/W/CETP/25-26/27/1940

Dated: 30/06/2025

1. Name & Address of Ind. / Unit : OKHLA CETP (24 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 04.06.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS*
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.4	5.5-9.0	7.0	6-9	7.3
2	TSS	540	600	58	100	51.67
3	COD	344	750	104	250	108.33
4	BOD (3 days at 27° C)	140	300	27	30	18.33
5	Oil & Grease	13.6	20.0	2	10.0	-
6	Ammonical Nitrogen as N	13.8	50	6.7	50	-
7	Sulphide	4.8	5.0	1.9	2.0	-
8	Phosphate	3.5	15.0	0.3	5.0	-

All values are in mg/l except pH

Flow: 2.30 MLD

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

SSA/Analyst

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)**ANALYSIS REPORT OF NARAINA CETP (21.6 MLD) FOR THE MONTH OF JUNE 2025**

Report Number: DPCC/W/CETP/25-26/28/1941

Dated: 30/06/2025

1. Name & Address of Ind. / Unit : **NARAINA CETP (21.6 MLD)**
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 04.06.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.7	5.5-9.0	7.3	6-9	7.09
2	TSS	120	600	58	100	18.8
3	COD	288	750	100	250	76.7
4	BOD (3 days at 27° C)	120	300	29	30	16.1
5	Oil & Grease	16.0	20.0	2.4	10.0	-
6	Ammonical Nitrogen as N	6.4	50	1.9	50	-
7	Sulphide	3.9	5.0	2.3	2.0	-
8	Phosphate	3.2	15.0	1.3	5.0	-

All values are in mg/l except pH

FLOW: 5.033 MLD

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



ANALYSIS REPORT OF MAYAPURI CETP (12 MLD) FOR THE MONTH OF JUNE 2025

Report Number: DPCC/W/CETP/25-26/29/1942

Dated: 30/06/2025

1. Name & Address of Ind. / Unit : MAYAPURI CETP (12 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 04.06.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.1	5.5-9.0	7.2	6-9	7.28
2	TSS	160	600	76	100	32.6
3	COD	384	750	96	250	85.5
4	BOD (3 days at 27° C)	150	300	27	30	11.2
5	Oil & Grease	10.8	20.0	2.4	10.0	-
6	Ammonical Nitrogen as N	15.8	50	1.8	50	-
7	Sulphide	4.5	5.0	1.8	2.0	-
8	Phosphate	2.8	15.0	0.7	5.0	-

All values are in mg/l except pH
Flow: 3.67 MLD

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

SSA/Analyst

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)**ANALYSIS REPORT OF MANGOLPURI CETP (2.4 MLD) FOR THE MONTH OF JUNE 2025**

Report Number: DPCC/W/CETP/25-26/30/1943

Dated: 30/06/2025

1. Name & Address of Ind. / Unit
2. Sampling location
3. Date of Sampling
4. Sample analyzed and results
5. Parameters analyzed and result

MANGOLPURI CETP (2.4 MLD)

Inlet and Outlet of CETP

04.06.2025

DPCC LAB

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.6	5.5-9.0	7.3	6-9	7.03
2	TSS	368	600	44	100	6.3
3	COD	472	750	104	250	54.5
4	BOD (3 days at 27° C)	130	300	27	30	9.3
5	Oil & Grease	11.6	20.0	2.0	10.0	-
6	Ammonical Nitrogen as N	9.5	50	4.3	50	-
7	Sulphide	3.5	5.0	1.4	2.0	-
8	Phosphate	3.6	15.0	0.6	5.0	-

All values are in mg/l except pH

Flow: 1.46 MLD

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



ANALYSIS REPORT OF NANGLOI CETP (12 MLD) FOR THE MONTH OF JUNE 2025

Report Number: DPCC/W/CETP/25-26/31/1944


Dated: 30/06/2025


1. Name & Address of Ind. / Unit : **NANGLOI CETP (12 MLD)**
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 04.06.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.8	5.5-9.0	7.1	6-9	7.04
2	TSS	208	600	72	100	29.4
3	COD	504	750	56	250	54.8
4	BOD (3 days at 27° C)	180	300	23	30	14.6
5	Oil & Grease	18.8	20.0	1.6	10.0	-
6	Ammonical Nitrogen as N	8.4	50	3.7	50	-
7	Sulphide	4.6	5.0	1.2	2.0	-
8	Phosphate	3.3	15.0	0.5	5.0	-

All values are in mg/l except pH

Flow: 3.35 MLD


I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)


SSA/Analyst

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)

**ANALYSIS REPORT OF JHILMIL CETP (16.8 MLD) FOR THE MONTH OF JUNE 2025**

Report Number: DPCC/W/CETP/25-26/32/1945


Dated: 30/06/2025

1. Name of CETP : **JHILMIL CETP (16.8 MLD)**
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 05.06.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.4	5.5-9.0	7.3	6-9	7.05
2	TSS	530	600	64	100	49.69
3	COD	544	750	72	250	127
4	BOD (3 days at 27° C)	200	300	27	30	16.69
5	Oil & Grease	14.4	20.0	1.6	10.0	-
6	Ammonical Nitrogen as N	9.5	50	4.2	50	-
7	Sulphide	4.8	5.0	1.9	2.0	-
8	Phosphate	4.3	15.0	0.9	5.0	-

All values are in mg/l except pH

Flow: 4.851 MLD


I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)


SSA/Analyst

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)**ANALYSIS REPORT OF GTK CETP (6 MLD) FOR THE MONTH OF JUNE 2025**

Report Number: DPCC/W/CETP/25-26/33/1946


Dated: 30/06/2025

1. Name & Address of Ind. / Unit : **GTK CETP (6 MLD)**
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 06.06.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.2	5.5-9.0	7.1	6-9	OLMS was Non-functional
2	TSS	336	600	114	100	
3	COD	520	750	108	250	
4	BOD (3 days at 27° C)	210	300	35	30	
5	Oil & Grease	13.2	20.0	1.6	10.0	
6	Ammonical Nitrogen as N	8.3	50	4.1	50	
7	Sulphide	4	5.0	1.8	2.0	
8	Phosphate	4.9	15.0	2.8	5.0	

All values are in mg/l except pH

Flow: 2.13 MLD


 I/C Water Laboratory
Dr. Shweta Gupta
 Incharge (Water Laboratory)


 SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



ANALYSIS REPORT OF SMA CETP (12 MLD) FOR THE MONTH OF JUNE 2025


Report Number: DPCC/W/CETP/25-26/34/1947

Dated: 30/06/2025

1. Name & Address of Ind. / Unit : SMA CETP (12 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 06.06.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.5	5.5-9.0	7.1	6-9	7.35
2	TSS	350	600	50	100	52.26
3	COD	408	750	100	250	120.23
4	BOD (3 days at 27° C)	150	300	23	30	14.49
5	Oil & Grease	12	20.0	2.4	10.0	-
6	Ammonical Nitrogen as N	16.2	50	0.5	50	-
7	Sulphide	3.8	5.0	1.4	2.0	-
8	Phosphate	3.1	15.0	0.7	5.0	-

All values are in mg/l except pH
Flow: 2.81 MLD


I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)


SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



ANALYSIS REPORT OF WAZIRPUR CETP (24 MLD) FOR THE MONTH OF JUNE 2025

Report Number: DPCC/W/CETP/25-26/35/1948

Dated: 30/06/2025

1. Name & Address of Ind. / Unit : WAZIRPUR CETP (24 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 06.06.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS*
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.5	5.5-9.0	7.2	6-9	8.45
2	TSS	224	600	40	100	43.9
3	COD	440	750	68	250	69.7
4	BOD (3 days at 27° C)	170	300	20	30	7.9
5	Oil & Grease	14	20.0	2.8	10.0	-
6	Ammonical Nitrogen as N	8.8	50	3.4	50	-
7	Sulphide	3.3	5.0	1.0	2.0	-
8	Phosphate	1.5	15.0	0.5	5.0	-

All values are in mg/l except pH
Flow: - 4.82MLD

I/C Water Laboratory

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



ANALYSIS REPORT OF LAWRENCE ROAD CETP (12 MLD) FOR THE MONTH OF JUNE 2025

Report Number: DPCC/W/CETP/25-26/36/1949

Dated: 30/06/2025

1. Name & Address of Ind. / Unit : **LAWRENCE ROAD (12 MLD)**
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 09.06.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS*
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.6	5.5-9.0	7.3	6-9	OLMS was Non-functional
2	TSS	416	600	26	100	
3	COD	504	750	60	250	
4	BOD (3 days at 27° C)	180	300	24	30	
5	Oil & Grease	10.8	20.0	3.6	10.0	
6	Ammonical Nitrogen as N	8.7	50	3.5	50	
7	Sulphide	3.5	5.0	1.5	2.0	
8	Phosphate	3.4	15.0	0.4	5.0	

All values are in mg/l except pH

Flow: 1.912 MLD

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



ANALYSIS REPORT OF BADLI CETP (12 MLD) FOR THE MONTH OF JUNE 2025

Report Number: DPCC/W/CETP/25-26/37/1950

Dated: 30/06/2025


1. Name & Address of Ind. / Unit
2. Sampling location
3. Date of Sampling
4. Sample analyzed and results
5. Parameters analyzed and result

BADLI CETP (12 MLD)
Inlet and Outlet of CETP
09.06.2025
DPCC LAB

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.5	5.5-9.0	7.1	6-9	8.08
2	TSS	173	600	86	100	76
3	COD	344	750	112	250	60.9
4	BOD (3 days at 27° C)	190	300	33	30	9.5
5	Oil & Grease	24	20.0	2.0	10.0	-
6	Ammonical Nitrogen as N	7.4	50	1.2	50	-
7	Sulphide	3.2	5.0	1.9	2.0	-
8	Phosphate	0.8	15.0	0.3	5.0	-

All values are in mg/l except pH

Flow: - 2.42 MLD


I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)


SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



ANALYSIS REPORT OF NARELA CETP (24 MLD) FOR THE MONTH OF JUNE 2025


Report Number: DPCC/W/CETP/25-26/38/1981

Dated: 30/06/2025

1. Name & Address of Ind. / Unit : NARELA CETP (22.5 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 12.06.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.6	5.5-9.0	7.1	6-9	7.70
2	TSS	288	600	29	100	5.0
3	COD	280	750	40	250	26.0
4	BOD (3 days at 27° C)	90	300	17	30	4.8
5	Oil & Grease	14.8	20.0	2.8	10.0	-
6	Ammonical Nitrogen as N	8.1	50	3.2	50	-
7	Sulphide	3	5.0	1.4	2.0	-
8	Phosphate	0.8	15.0	0.1	5.0	-

All values are in mg/l except pH
Flow: 9.41MLD


I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)


SSA/Analyst

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)**ANALYSIS REPORT OF BAWANA CETP (35 MLD) FOR THE MONTH OF JUNE 2025**

Report Number: DPCC/W/CETP/25-26/39/1982

Dated: 30/06/2025

1. Name & Address of Ind. / Unit : **BAWANA CETP (35 MLD)**
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 12.06.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.5	5.5-9.0	7.2	6-9	7.72
2	TSS	484	600	48	100	24.13
3	COD	408	750	76	250	45.6
4	BOD (3 days at 27° C)	120	300	22	30	11.26
5	Oil & Grease	14.8	20.0	3.2	10.0	-
6	Ammonical Nitrogen as N	17.4	50	7.7	50	-
7	Sulphide	4.0	5.0	1.5	2.0	-
8	Phosphate	1.9	15.0	0.6	5.0	-

All values are in mg/l except pH

Flow: 33.19 MLD

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

SSA/Analyst