



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpccdelhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/6/2871

Dated : 19/01/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2020

1. Name & Address of Ind./Unit : Molarband Mini STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.12.2020
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	0.66	Inlet	7.3	156	70	200	16.0	30.7	15.7	Not meeting the Standards w TSS, BOD, COD & D.P.
		Outlet	7.4	26	16	64	2.4	4.0	3.1	
		OLMS*	-	-	-	-	-	-	-	
		% Variation	-	-	-	-	-	-	-	
Total 0.66										
I-Increase & D-Decrease										

I-Increase & D-Decrease

Remarks: OLMS was not working

M. Misha
E/C LABORATORY
Scientist 'C'

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/465/2872

Dated: 19/01/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2020


1. Name & Address of Ind./Unit : Coronation Pillar STP
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 03.12.2020
4. Samples collected by : DPCC, Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
						10	10	50	10	
1	Ph-I,II(20)	Inlet	7.2	100	62	192	5.6	42.5	6.3	Not meeting the Standard w.r.t BOD, TSS, COD & A.N.
		Outlet	7.0	58	36	108	4.0	12.4	1.3	
		OLMS*	7.28	68.25	44.24	156.40	-	16.89	-	
		% variation	-4 (D)	-17.67 (D)	-22.88 (D)	-44.81 (D)	-	-36.20 (D)	-	
2	Ph-III(10)	Inlet	7.1	528	240	640	36.0	43.2	8.3	Not meeting the standards w TSS, BOD, COD & A.N.
		Outlet	7.1	66	32	108	2.4	9.7	1.9	
		OLMS*	7.2	60.07	35.02	130.06	-	4.44	-	
		% variation	-1.40 (D)	8.98 (I)	-9.43 (D)	-20.42 (D)	-	54.22 (I)	-	
Total 30										
I-Increase & D-Decrease										

I-Increase & D-Decrease

Nmitra
I/C LABORATORY
Scientist 'C'

SR. Scientific Assistant
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/466/2873

Dated: 19/01/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER -2020

1. Name & Address of Ind./Unit : Delhi Gate STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 02.12.2020
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results :										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
1	Phase-I,II(15)	Inlet	6.9	204	110	320	20.8	47.8	7.8	Meeting the Standards.
		Outlet	6.9	10	6	32	0.8	1.6	0.4	
		OLMS*	-	-	-	-	-	-	-	
		% Variation	-	-	-	-	-	-	-	
		Total 15								

I-Increase & D-Decrease

Remarks: The vendor of M/s Aaxis Nano was refused to calibrate the OLMS

I-Increase & D-Decrease

Remarks: The vendor of M/s Axis Nano was refused to calibrate OLMS.

I/C LABORATORY

Dr. NANDITA MOITRA

Scientist 'C'

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/467 / 2874

Dated: 19/01/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER -2020

1. Name & Address of Ind./Unit : DELHI GATE STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 02.12.2020
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	Phase-I,II(2.2)	Inlet	6.4	256	140	412	24.8	51.4	11.7	Meeting the Standards
		Outlet	6.8	8	5	20	0.4	1.4	0.7	
		OLMS*	6.94	7.58	2.26	13.95	-	1.95	-	
		% Variation	-2.05 (D)	5.25 (I)	54.8 (I)	30.25 (I)	-	-39.28 (D)	-	
Total 2.2										

I-Increase & D-Decrease

Mishra
I/C LABORATORY
Scientist 'C'

SR. Scientific Assistant
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE (Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/468

12875

Dated: 19/01/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2020

1. Name & Address of Ind./Unit : Keshopur STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.12.2020
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	12	Inlet	7.0	224	120	364	20.8	52.7	12.4	Meeting the Standards.
		Outlet	7.3	10	6	32	1.2	3.7	0.9	
		OLMS*	7.4	11.76	4.94	24.95	-	2.7	-	
		% Variation	-7.36 (D)	-17.6 (D)	17.6 (I)	22.03 (I)	-	27.02 (I)	-	
Total 12										

I-Increase & D-Decrease

N. Mishra
I/C LABORATORY
DR. NANDHA MOITRA
Scientist 'C'

R. P. Sharma
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/469/2876

Dated : 19/01/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER -2020

1. Sampling location : Inlet and Outlet of STP
2. Name & Address of Ind./Unit : SEN Nursing Home (SNH)
3. Date of Inspection : 02.12.2020
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters			Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
						COD (mg/l)	Oil & Grease (mg/l)				
				10	10	50	10	5	2		
1	Phase-I,II (2.2)	Inlet	6.3	136	72	280	8.4	39.6	5.7	Meeting the Standards.	
		Outlet	6.9	10	6	32	0.4	4.2	0.7		
		OLMS*	7.02	6.05	4.2	16.5	-	0.85	-		
		% Variation	-1.73 (D)	39.5 (I)	30 (I)	48.43 (I)	-	79.76 (I)	-		
Total 2.2											

I-Increase & D-Decrease

N. Mishra
I/C LABORATORY
Dr. NANDITA MISHRA
Scientist 'C'

Abhishek
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/470/2877

Dated: 19/01/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER -2020

1. Name & Address of Ind./Unit : Nilothi STP-II
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.12.2020
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	20	Inlet	6.4	212	110	320	17.6	53.4	12.0	Meeting the Standard
		Outlet	7.1	6	4	20	0.4	1.3	0.7	
		OLMS*	6.77	6.92	5.51	30.20	-	1.58	-	
		% Variation	4.64 (I)	-15.33 (D)	-37.75 (D)	-51 (D)	-	-21.53 (D)	-	
Total 20										

I-Increase & D-Decrease

N. Mitra
I/C LABORATORY
Dr. NANDNARAYAN
Scientist 'C'

SR. Scientific Assistant
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/471/2878

Dated: 19/01/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER -2020

1. Name & Address of Ind./Unit : Nilothi STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.12.2020
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	40	Inlet	7.4	168	95	260	12.8	34.9	10.3	Not Meeting the Standards w.r TSS, BOD, COD, A.N & D.P.
		Outlet	7.2	58	32	120	2.8	7.1	3.1	
		OLMS*	-	-	-	-	-	-	-	
		% Variation	-	-	-	-	-	-	-	
Total 40										

I-Increase & D-Decrease

Remarks: Calibration was not done due to plant was not working in previous month (November-2020)

M. Mittal
I/C LABORATORY
Scientist 'C'

M. Mittal
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/20-21/472/2879

Dated: 19/01/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER -2020

1. Name & Address of Ind./Unit : Najafgarh STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.12.2020
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters Analyzed and Result										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	5	Inlet	7.1	260	140	392	24.0	73.9	12.3	Not meeting the standards w.r.t to TS BOD, COD, A. N. & D.P.
		Outlet	7.2	72	36	132	5.2	9.7	2.4	
		OLMS*	7.42	64.30	25.94	71.59	-	4.03	-	
		% Variation	-3.05 (D)	10.69 (I)	27.94 (I)	45.76 (I)	-	58.42 (I)	-	
Total 5										

I-Increase & D-Decrease

I/C LABORATORY

Dr. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/473/2880

Dated: 19/01/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER -2020

1. Name & Address of Ind./Unit : Rithala STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 04.12.2020
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	Phase-I(40)	Inlet	6.9	260	120	340	28.0	42.7	9.3	Not meeting the standards w to TSS,BOD,COD.A.N & D.P.
		Outlet	6.9	42	26	88	3.2	6.9	2.7	
		OLMS*	7.42	59.36	27.11	105.88	-	7.19	-	
		% Variation	-7.53 (D)	-41.33 (D)	-4.26 (D)	-20.31 (D)	-	-4.20 (D)	-	
2	Ph-II(40)	Inlet	6.9	260	120	340	28.0	42.7	9.3	meeting the standards
		Outlet	7.2	8	5	32	0.4	3.8	1.3	
		OLMS*	7.44	8.40	4.59	22.75	-	0.73	-	
		% Variation	-3.33 (D)	-5 (D)	8.2 (I)	28.90 (I)	-	8.378 (I)	-	
Total 80										
I-Increase & D-Decrease										

N. Mitra
Dr. NANDITA MOITRA
I/C LABORATORY Scientist 'C'

ABedman
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/474/ 2881

Dated: 19/01/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2020

1. Name & Address of Ind./Unit : Pappankalan STP(Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.12.2020
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
				10	10	50	10	5	2	
1	20	Inlet	6.9	248	130	460	24.0	64.9	7.2	Not meeting the Standards w.r.t TSS, BOD & COD.
		Outlet	7.2	50	28	92	2.4	2.8	1.0	
		OLMS*	7.24	50.62	28.60	72.71	-	1.21	-	
		% Variation	-0.55 (D)	-1.22 (D)	-2.12 (D)	20.96 (I)	-	56.78 (I)	-	
Total 20										

I-Increase & D-Decrease

N. Mitra
I/C LABORATORY
Dr. NANDITA MOITRA
Scientist 'C'

SR. Scientific Assistant
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE (Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/475/2882

Dated: 19/01/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2020

1. Name & Address of Ind./Unit : Pappankalan STP-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.12.2020
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	20	Inlet	7.1	180	95	380	16.4	34.7	6.2	Meeting the Standards.
		Outlet	7.2	10	6	30	0.4	2.4	0.9	
		OLMS*	-	7.33	51.49	31.98	-	-	-	
		% Variation	-	26.7 (I)	-758.1 (D)	-6.6 (D)	-	-	-	
Total 20										

Remarks: pH & A.N. was under repair.

I-Increase & D-Decrease

N. Mitra
I/C LABORATORY
Scientist 'C'

A. Belwani
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/20-21/476 / 2883

Dated: 19/01/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2020

1. Name & Address of Ind./Unit : Rohini STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 04.12.2020
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	15	Inlet	7.2	284	125	360	28.0	45.2	7.5	Not meeting the Standards w TSS, BOD & COD.
		Outlet	7.3	24	16	56	3.2	4.3	1.2	
		OLMS*	7.4	14.02	8.42	36.36	-	3.52	-	
		% Variation	-1.36 (D)	41.58 (I)	47.37 (I)	35.07 (I)	-	18.13 (I)	-	
Total 15										
I-Increase & D-Decrease										

I-Increase & D-Decrease

N. Mitra
I/C LABORATORY
Dr. NANDITA MITRA
Scientist 'C'

A. K. Sharma
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/477/2884

Dated: 19/01/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER -2020

1. Name & Address of Ind./Unit : Narela STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 07.12.2020
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	10	Inlet	7.4	180	94	276	12.8	45.2	7.9	
		Outlet	7.5	22	16	64	1.2	5.1	1.3	Not Meeting the Standards w.r TSS, BOD, COD & A.N.
		OLMS*	7.4	32.26	15.97	64.79	-	3.22	-	
		% Variation	1.33 (I)	-46.63 (D)	0.187 (I)	-1.23 (D)	-	36.86 (I)	-	
Total 10										

I-Increase & D-Decrease

Nandita
I/C LABORATORY
Dr. NANDITA MOITRA
Scientist 'C'

SR. Scientific Assistant
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/478 / 2885

Dated: 19/01/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER -2020

1. Name & Address of Ind./Unit : Okhla STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.12.2020
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	30	Inlet	6.8	212	115	360	20.0	22.9	4.9	Meeting the Standard:
		Outlet	7.3	6	4	24	0.4	1.6	0.7	
		OLMS*	7.55	4.11	2.78	15.75	-	0.18	-	
		% Variation	-3.42 (D)	31.5 (I)	30.5 (I)	34.37 (I)	-	88.75 (I)	-	
Total 30										

I-Increase & D-Decrease

Mishra
I/C LABORATORY
Dr. NANDITA MITRA
Scientist 'C'

SR. Scientific Assistant
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/479/2886

Dated: 19/01/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER -2020

1. Name & Address of Ind./Unit : Kondli STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 16.12.2020
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :


Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	25	Inlet	6.8	280	120	392	24.0	62.6	9.7	Not meeting the Standards w.r.t TSS, BOD, COD & A.N.
		Outlet	7.2	24	14	64	3.6	7.4	1.2	
		OLMS*	7.6	28.53	12.67	49.64	-	2.80	-	
		% Variation	-5.55 (D)	-18.87 (D)	9.5 (I)	22.43 (I)	-	62.16 (I)	-	
Total 25										

I-Increase & D-Decrease

I-Increase & D-Decrease

N. Mishra
I/C LABORATORY
DR. N. MOITRA
Scientist 'C'

P. B. Meena
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/480/2887

Dated: 19/01/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER -2020

1. Name & Address of Ind./Unit : Kondli STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 16.12.2020
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	45	Inlet	6.9	324	170	460	28.0	43.6	13.8	Not Meeting the Standards w.r.t TSS, BOD & COD, A.N. & D.P.
		Outlet	7.0	134	72	220	6.4	9.7	2.9	
		OLMS*	-	-	-	-	-	-	-	
		% Variation	-	-	-	-	-	-	-	
Total 45										

Remarks: The vendor of M/s Axis Nano was refused to calibrate OLMS.

I-Increase & D-Decrease

I/C LABORATORY

Scientist 'C'

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE (Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/481 / 2888

Date: 19/01/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER -2020

1. Name & Address of Ind./Unit : Kapasahera STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 15.12.2020
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
1	5	Inlet		10	10	50	10	5	2	Meeting the Standard
			7.22	280	160	440	24.0	37.8	9.8	
		Outlet	7.1	8	5	20	0.4	1.7	0.4	
		OLMS*	7.18	10.08	6.05	35.16	-	3.77	-	
		% Variation	-1.12 (D)	-26 (D)	-21 (D)	-75.8 (D)	-	-121.76 (D)	-	
Total 5										
I-Increase & D-Decrease										

I-Increase & D-Decrease

Nmitra
I/C LABORATORY MOITRA
Scientist 'C'

SR. Scientific Assistant
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE (Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/482 | 2889

Dated: 19/01/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER -2020

1. Name & Address of Ind./Unit : Yamuna Vihar STP Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.12.2020
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	25	Inlet	6.9	304	140	386	17.6	48.9	10.4	Not meeting the Standards w.r.t TSS, BOD, COD & A.N.
		Outlet	7.0	26	16	72	4.0	7.5	1.7	
		OLMS*	7.38	27.87	15.99	83.42	-	4.22	-	
		% Variation	-5.42 (D)	-7.149 (D)	0.06 (I)	-15.86 (D)	-	43.73 (I)	-	
Total 25										

I-Increase & D-Decrease

N. Mishra
I/C LABORATORY
DR. NANDITA MISHRA
Scientist 'C'

SR. Scientific Assistant
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/483/2890

Dated: 19/01/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER -2020

1. Name & Address of Ind./Unit : Chilla STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 16.12.2020
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	9	Inlet	7.0	340	150	420	32.0	59.7	10.7	Meeting the Standards.
		Outlet	6.6	8	5	28	0.4	3.1	0.7	
		OLMS*	6.90	7.02	6.25	28.71	-	1.59	-	
		% Variation								
Total 9										

I-Increase & D-Decrease

N. Milia
I/C LABORATORY
Dr. NANDITA MOITRA
Scientist 'C'

SR. Scientific Assistant
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmir Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/484/2891

Dated: 19/01/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER -2020

1. Name & Address of Ind./Unit : Akshardham STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 16.12.2020
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	1	Inlet	6.4	340	180	520	36.0	72.90	18.9	Meeting the Standards.
		Outlet	6.8	4	2.5	20	0.4	2.7	0.5	
		OLMS*	-	1.43	2.39	17.79	-	-	-	
		% Variation	-	64.25 (I)	4.4 (I)	11.05 (I)	-	-	-	
Total 1										

I-Increase & D-Decrease

N. Mishra
V.C. MOITRA
LABORATORY
Scientist 'C'

R. Bedwan
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/485/12892

Dated : 19/01/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER -2020

1. Name & Address of Ind./Unit : Mehrauli STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 15.12.2020
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	15	Inlet	7.2	196	85	240	18.4	37.9	7.6	Not meeting the standards w.r.t TSS, BOD & COD.
		Outlet	7.1	24	16	60	2.0	4.7	1.0	
		OLMS*	7.30	24.50	12.35	50.04	-	3.80	-	
		% Variation	-2.81 (D)	-2.08 (D)	22.81 (I)	16.6 (I)	-	19.14 (I)	-	
Total 15										
I-Increase & D-Decrease										

I-Increase & D-Decrease

Mishra
I/C LABORATORY
Dr. NANDITA MOTTRA
Scientist 'C'

Redwan

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/486/2893

Dated: 19/01/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER -2020

1. Name & Address of Ind./Unit : Vasant Kunj STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 15.12.2020
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters			Dissolved Phosphate as P(mg/l)	Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)		
				10	10	50	10	5	2	
1	2.2	Inlet	7.1	260	140	392	24.0	38.0	11.2	Not meeting the Standards w.r.t TSS, BOD & COD.
		Outlet	7.3	20	12	56	2.6	3.2	1.2	
		OLMS*	7.4	26.38	17.83	59.95	-	4.62	-	
		% Variation	-1.36 (D)	-31.9 (D)	-48.58 (D)	-7.05 (D)	-	-44.87 (D)	-	
2	3	Inlet	7.2	244	130	360	16.0	35.0	12.2	Not Meeting the Standards w.r.t TSS, BOD, COD & A.N.
		Outlet	7.1	40	26	84	2.8	6.7	1.9	
		OLMS*	7.68	62.32	38.90	118.74	-	1.93	-	
		% Variation	-8.16 (D)	-55.8 (D)	-49.61 (D)	-41.35 (D)	-	71.19 (I)	-	
Total 5.2										
I-Increase & D-Decrease										

I-Increase & D-Decrease

N. Mitra
I/C LABORATORY
Scientist 'C'

Shelvam
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/487/2894

Date: 19/01/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER -2020

1. Name & Address of Ind./Unit : Yamuna Vihar STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.12.2020
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	2.2	Inlet	6.9	140	72	184	15.6	25.0	9.8	Not Meeting the Standards w.r.t TSS, BOD, COD, A.N. & D.P.
		Outlet	7.1	32	18	60	2.8	7.8	2.2	
		OLMS*	7.13	15.99	15.36	66.39	-	3.08	-	
		% Variation	-0.42 (D)	50.03 (I)	14.66 (I)	-10.65 (D)	-	60.51 (I)	-	
2	3	Inlet	7.9	114	60	172	17.2	31.8	7.2	Not Meeting the Standards w.r.t TSS.
		Outlet	7.0	18	10	32	0.8	2.7	1.0	
		OLMS*	-	-	-	-	-	-	-	
		% Variation	-	-	-	-	-	-	-	
Total 5.2										

I-Increase & D-Decrease

Remarks: OLMS (3 MGD) was not found.

I/C LABORATORY
Scientist 'C'

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/488

12895

Dated: 19/01/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER -2020

1. Name & Address of Ind./Unit : Okhla STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.12.2020
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	12	Inlet	7.4	120	72	280	7.6	36.9	7.6	Not meeting the Standards w.r. BOD & COD.
		Outlet	7.4	22	14	56	1.2	3.2	0.9	
		OLMS	7.0	36.66	17.86	70.82	-	2.81	-	
		% Variation	5.40 (I)	-66.63 (D)	-27.57 (D)	-26.46 (D)	-	12.18 (I)	-	
	16	Outlet	7.4	46	28	108	3.2	4.1	1.7	Not meeting the Standards w.r. BOD & COD.
		OLMS	7.4	118.41	16.58	174.63	-	3.21	-	
		% Variation	-	-15.74 (D)	40.78 (I)	-61.69 (D)	-	21.70 (I)	-	
	37	Outlet	-	-	-	-	-	-	-	
		OLMS	-	-	-	-	-	-	-	
		% Variation	-	-	-	-	-	-	-	
	45	Outlet	7.2	48	28	96	3.6	7.4	1.2	Not meeting the Standards w.r. BOD & COD & A.N.
		OLMS	7.5	32.52	20.05	78.40	-	2.02	-	
		% Variation	-4.16 (D)	32.25 (I)	28.3.9 (I)	18.33 (I)	-	72.70 (I)	-	
	Total 110									

Remarks: Plant (37 MGD) was not working due to electricity fault.

I-Increase & D-Decrease

N. K. MOITRA
Scientist 'C'

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/489

12896

Dated: 19/01/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER -2020

1. Name & Address of Ind./Unit : Keshopur STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.12.2020
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
						10	10	50	10	
1	40	Inlet	7.4	196	80	260	16.0	42.7	12.1	Not meeting the Standards w.r.t TSS,BOD,COD & A.N.
		Outlet	7.3	54	30	84	4.0	6.2	1.8	
		OLMS*	7.20	63.10	44.49	134.91	-	8.62	-	
		% Variation	1.36 (I)	-16.85 (D)	-48.3 (D)	-60.60 (D)	-	-39.06 (D)	-	
2	20	Inlet	7.4	196	80	260	16.0	42.7	12.1	Not meeting the Standards w.r.t TSS,BOD,COD, A.N & D.P.
		Outlet	7.1	68	38	108	5.6	6.9	2.6	
		OLMS*	6.82	57.04	32.54	109.35	-	6.60	-	
		% Variation	3.94 (I)	16.11 (I)	14.36 (I)	-1.25 (D)	-	4.34 (I)	-	
Total 60										

I-Increase & D-Decrease

N. Mitra
I/C LABORATORY
Scientist 'C'

A. Bedmani
SR. SCIENTIFIC ASSISTANT