

DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/26 /4805

Date: 03/06/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY -2022


1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 09.05.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	Ph-I,II(20)	Inlet	7.5	336	130	224	26.4	28.6	18.5	Not meeting the standards wrt TSS, BOD, COD, & Dissolved Phosphate
		Outlet	7.3	62	34	80	4.2	4.6	4.8	
		OLMS*	-	-	-	-	-	-	-	
2	Ph-III(10) (now upgrade with 70 MGD)	Inlet	7.5	244	118	304	12.4	36	30	Not meeting the standards wrt TSS, BOD & Dissolved Phosphate
		Outlet	7.2	30	16	40	2.4	4.5	4.2	
		OLMS	-	-	-	-	-	-	-	
Total 30										

*Remarks: OLMS (Ph-I & II) was stolen. FIR has been filed as informed by Plant Incharge & OLMS (Ph-III) not in functioning.

N. Mishra

I/C LABORATORY
DR. NANDITA MISHRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/27/4806

Dated: 03/06/2022


ANALYSIS REPORT OF STP FOR THE MONTH OF MAY -2022

1. Name of STP : Delhi Gate (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 24.05.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	Phase-I,II(15)	Inlet	7.1	184	98	272	19.2	42.32	7.8	Meeting the Standards.
		Outlet	7.2	8	6	48	1.2	5.6	2.45	
		OLMS	6.7	6.1	4.23	39.96	-	13.40	-	
Total 15										

Minita
I/C LABORATORY

Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/28/4807

Dated: 03/06/2022


ANALYSIS REPORT OF STP FOR THE MONTH OF MAY -2022

1. Name of STP : Delhi Gate (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 24.05.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
	Phase-I,II(2.2)	Inlet	6.9	200	92	264	20.4	40.4	7.3	Meeting the Standards
		Outlet	7.0	10	8	48	1.02	5.4	1.8	
		OLMS	6.7	3.94	3.31	23.06	-	0.54	-	
Total 2.2										

N. Mitter
I/C LABORATORY

Scientist



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/29/4808

Dated: 03/06/2022


ANALYSIS REPORT OF STP FOR THE MONTH OF MAY -2022

1. Name of STP : Keshopur STP (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.05.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	12	Inlet	7.7	280	137	352	29.6	32.4	16.8	Not meeting the standards wrt TSS, BOD & COD.
		Outlet	7.5	32	26	68	0.4	1.2	0.2	
		OLMS	7.5	7.78	6.24	28.95	-	4.57	-	
Total 12										

N. Mitra
I/C LABORATORY

Dr. SANDIPA MISHRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/30/4809

Dated: 03/06/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY -2022


1. Name of STP : SEN Nursing Home (SNH)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 24.05.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	Phase-I,II (2.2)	Inlet	6.8	276	94	248	30	43.4	17.8	Meeting the Standards
		Outlet	7.5	8	6	32	1.6	3.8	1.4	
		OLMS	-	-	-	-	-	-	-	
Total 2.2										

Remarks: OLMS was found non-operational at the time of Monitoring.

N. Mishra
I/C LABORATORY

DR. NANDITA DUTTA
Scientist



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/31/4810


Dated: 03/06/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY -2022

1. Name of STP : Nilothi Ph-II (NEW)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 23.05.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	20	Inlet	7.2	144	100	320	25.6	27.4	6	Meeting the standards.
		Outlet	7.4	8	4	16	0.4	1.7	1.2	
		OLMS	7.0	14.98	18.77	116.22	-	2.62	-	
Total 20										

N. Mishra
I/C LABORATORY
Dr. NANDITA MISHRA
Scientist I



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/32/4811

Dated: 03/06/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY -2022


1. Name of STP : Nilothi
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 23.05.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	40	Inlet	7.5	240	112	192	16.4	19.2	23.4	Not meeting the standards wrt TSS, BOD COD & Ammonical Nitrogen.
		Outlet	7.3	58	40	136	4.8	8.7	1.8	
		OLMS	-	-	-	-	-	-	-	
Total 40										

Remarks: OLMS was found non-operational at the time of Monitoring.

Mishra
I/C LABORATORY

Dr. VANDANA BOUTER
Scientist I



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/22-23/33/4812

Dated: 03/06/2022


ANALYSIS REPORT OF STP FOR THE MONTH OF MAY -2022

1. Name of STP : Najafgarh
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 23.05.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	5	Inlet	7.6	204	75	200	16.8	19.6	17.2	Not meeting the standards wrt TSS, BOD & COD.
		Outlet	7.7	52	35	112	4.4	4.5	2	
		OLMS*	-	-	-	-	-	-	-	
Total 5										

*Remarks: OLMS was Stolen informed by Plant Incharge.

N. Mitta
I/C LABORATORY
Scientist



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/34 | 4813

Dated: 03/06/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY -2022


1. Name of STP : Rithala
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 05.05.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	Phase-I(40)	Inlet	-	-	-	-	-	-	-	Plant was under Rehabilitation
		Outlet	-	-	-	-	-	-	-	
		OLMS	-	-	-	-	-	-	-	
2	Ph-II(40)	Inlet	7.4	252	84	204	27.2	17.3	18.6	Meeting the standards.
		Outlet	7.8	8	6	42	1.6	4.2	2	
		OLMS	7.5	11.31	9.05	32	-	3.84	-	
Total 80										

N. Mittal

I/C LABORATORY

Dr. Sandhya Mittal
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/35/48/4

Dated: 03/06/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY -2022


1. Name of STP : Pappankalan (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 23.05.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	20	Inlet	7.7	180	60	176	17.2	19.4	15.9	Not meeting the Standards wrt TSS, BOD COD, Ammonical Nitrogen & Dissolved Phosphate.
		Outlet	7.4	62	40	104	10	7.1	6.6	
		OLMS	-	-	-	-	-	-	-	
Total 20										

Remarks: OLMS sensor not found at the time of Monitoring.

N. Mishra
I/C LABORATORY

Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE (Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/36 / 4815

Dated : 03/06/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY -2022


1. Name of STP : Pappankalan Ph-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 23.05.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
	20	Inlet	7.5	176	120	336	19.6	21.4	17.8	Meeting the Standards
		Outlet	7.3	10	6	48	2.4	2.8	1.6	
		OLMS	6.9	36.54	23.20	159.86	-	23.5	-	
Total 20										

N. Mehta

I/C LABORATORY

Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/22-23/37/4816

Dated : 03/06/2022


ANALYSIS REPORT OF STP FOR THE MONTH OF MAY -2022

1. Name of STP : Rohini
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 05.05.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	15	Inlet	7.3	244	142	348	21.2	36.2	24.2	Not meeting the Standards wrt TSS, BOD, COD, Ammonical Nitrogen & Dissolved Phosphate
		Outlet	7.4	56	34	72	4.8	7.3	3.2	
		OLMS	7.7	28.40	14.62	122.36	-	13.49	-	
Total 15										

Mitra
I/C LABORATORY

DR. RANDHA MITRA
Scientist



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/38 14817

Dated : 03/06/2022


ANALYSIS REPORT OF STP FOR THE MONTH OF MAY -2022

1. Name of STP : Narela
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.05.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	10	Inlet	7.5	192	72	284	3.6	30.2	16.2	Not Meeting the Standards wrt TSS, BOD, COD & Dissolved Phosphate
		Outlet	7.2	82	58	132	1.2	4.5	3.2	
		OLMS	6.4	49.81	32.32	97.35	-	0.09	-	
Total 10										

M. Mittal
I/C LABORATORY

DR. JYANDHA MISHRA
Scientist



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/39/48)8

Dated : 03/06/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY -2022

1. Name of STP : Okhla New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.05.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	30	Inlet	7.5	232	120	324	18.4	28.5	20.8	Meeting the Standards.
		Outlet	7.2	8	6	44	2	4.3	1.8	
		OLMS	8.2	6.04	7.0	30.72	-	3.36	-	
Total 30										

N. Mitta
I/C LABORATORY

DR. NANDITA MITTA
Scientist



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/40 | 4819

Dated: 03/06/2022


ANALYSIS REPORT OF STP FOR THE MONTH OF MAY -2022

1. Name of STP : Kondli
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 24.05.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	25	Inlet	7	312	112	416	19.2	36.3	30.8	Not meeting the standards wrt TSS, BOD & COD
		Outlet	7.2	18	14	44	0.4	1.2	0.4	
		OLMS	-	-	-	-	-	-	-	
Total 25										

Remarks: OLMS found not installed at the time of Monitoring.

N. Mishra
I/G LABORATORY
Scientist C



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/41/1820

Dated : 03/06/2022


ANALYSIS REPORT OF STP FOR THE MONTH OF MAY -2022

1. Name of STP : Kondli New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 24.05.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	45	Inlet	7.2	208	150	304	20.4	34.8	26.2	Not Meeting the Standards wrt TSS, BOD, COD, Ammonical Nitrogen & Dissolved Phosphate.
		Outlet	7	80	42	132	5.2	6.8	4	
		OLMS*	-	-	-	-	-	-	-	
Total 45										

*Remarks: OLMS was not found in location at the time of Monitoring.

Mishra
I/C LABORATORY
DR. NANDITA MISHRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/42/4821

Dated: 02/06/2022


ANALYSIS REPORT OF STP FOR THE MONTH OF MAY -2022

1. Name of STP : Kapasaheera
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 06.05.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	5	Inlet	7.2	180	78	252	5.2	36.9	18.4	Meeting the standards
		Outlet	7.1	8	6	44	1.6	4.8	2.0	
		OLMS	-	-	-	-	-	-	-	
Total 5										

Remarks: OLMS was not functional properly as values of parameters are not shown on Screen.

Mishra
I/C LABORATORY
SCIENTIST 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/43/4822

Dated: 03/06/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY -2022


1. Name of STP : Yamuna Vihar Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 20.05.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	25	Inlet	7.7	164	100	288	18.2	23.4	19.6	Not meeting the Standards wrt TSS, BOD COD & Ammonical Nitrogen.
		Outlet	7.4	36	30	108	5.2	6.3	2	
		OLMS	7.8	36.85	23.29	134.69	-	14.47	-	
Total 25										

M. Mitta

I/C LABORATORY

Scientist 'I'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/44/4823

Dated: 03/06/2022


ANALYSIS REPORT OF STP FOR THE MONTH OF MAY -2022

1. Name of STP : Chilla
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 24.05.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	9	Inlet	7.8	188	92	244	20.4	30.4	20.2	Meeting the Standards.
		Outlet	7.3	10	6	48	1.6	4.3	1.6	
		OLMS*	7.1	7.84	4.18	41.21	-	3.59	-	
Total 9										

I/C LABORATORY

DR. NANDITA MISHRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/45 / 4824

Dated: 03/06/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY -2022


1. Name of STP : Akshardham
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 24.05.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	1	Inlet	7.2	164	98	300	18.4	38.6	20.2	Meeting the Standards.
		Outlet	7.4	6	4	28	0.4	0.5	1	
		OLMS	7.6	0.49	0.11	13.56	-	0.93	-	
Total 1										

N. Mitra

I/C LABORATORY

Dr. NANDITA MONTU
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/46 14825

Dated: 03/06/2022


ANALYSIS REPORT OF STP FOR THE MONTH OF MAY -2022

1. Name of STP : Mehrauli
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 06.05.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	15	Inlet	7.3	204	98	256	10.2	16.8	38.4	Not meeting the standards wrt TSS, BOD, COD Ammonical Nitrogen & Dissolved Phosphate.
		Outlet	7.1	16	12	68	2	5.6	2.6	
		OLMS	7.6	24.29	18.83	238.69	-	5.37	-	
Total 15										

N. Mitta
I/C LABORATORY

Dr. Sandhya Mitta
Scientist



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/47 /4826


Dated: 03/06/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY -2022

1. Name of STP : Vasant Kunj
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 06.05.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	2.2	Inlet	7.2	228	118	324	29.2	18.6	36.4	Not Meeting the Standards wrt TSS, BOD & Dissolved Phosphate
		Outlet	7.3	36	16	32	3.6	3	7.8	
		OLMS	7.0	5.14	3.88	25.04	-	7.38	-	
2	3	Inlet	7.4	284	110	292	10.6	20.4	30.2	Not Meeting the Standards wrt TSS, BOD & Dissolved Phosphate
		Outlet	7.1	20	14	44	2.6	4.8	2.45	
		OLMS	7.3	6.96	7.67	60.85	-	4.40	-	
Total 5.2										

N. Mishra
I/C LABORATORY
Dr. KANAKA MOH. SINGH
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/48 / 4827


Date: 03/06/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY -2022

1. Name of STP : Yamuna Vihar
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 20.05.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	10 Ph-1	Inlet	7.2	210	100	280	16.4	30.58	40.2	Not meeting the standards wrt TSS, & Dissolved Phosphate
		Outlet	7.4	14	10	40	2.4	5.0	4.5	
		OLMS	6.7	16.9	7.32	43.29	-	6.86	-	
2	10 Ph-2	Inlet	7.6	328	200	440	20.4	38.4	19.2	Not meeting the standard wrt TSS, BOD, COD, Ammonical Nitrogen & Dissolved Phosphate
		Outlet	7.3	54	36	104	5.2	10.2	5.8	
		OLMS	5.9	23.70	15.89	80.92	-	9.78	-	
Total 20										

N. Mitra
I/C LABORATORY
Scientist



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Dated: 23/06/2022

Report Number: DPCC/W/STP/22-23/49/4828


ANALYSIS REPORT OF STP FOR THE MONTH OF MAY -2022

1. Name of STP : Okhla
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.05.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P(mg/l) 2	
1	12	Inlet	7.4	184	88	186	15.2	30.6	19.8	Not meeting the Standards wrt TSS, BOD & Ammocial Nitrogen
		Outlet	7.2	32	18	44	3.6	5.8	2	
		OLMS	7.3	19.93	13.19	31.91	-	2.95	-	
	16	Outlet	7.2	26	14	28	2.8	5.2	3.2	Not meeting the Standards wrt TSS, BOD, Ammocial Nitrogen & Dissolved Phosphate
		OLMS*	-	-	-	-	-	-	-	
	37	Outlet	7.1	28	16	72	1.6	4.8	1.5	Not meeting the Standards wrt TSS, BOD & COD.
		OLMS*	-	-	-	-	-	-	-	
	45	Outlet	7.3	40	12	64	2.6	3.5	1.6	Not meeting the Standards wrt TSS, BOD & COD.
		OLMS	6.3	46.95	15.65	75.12	-	19.64	-	
	Total 110									

*Remarks: OLMS (16 & 37 MGD) was found non-operational at the time of DPCC Monitoring.

Nisha
I/C LABORATORY
DR. SANDRA MUTHU
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/50/4829

Date: 03/06/2022


ANALYSIS REPORT OF STP FOR THE MONTH OF MAY -2022

1. Name of STP : Keshopur
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.05.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	40	Inlet	7.5	208	65	216	16.4	21.6	16.7	Not meeting the Standards wrt TSS.
		Outlet	7.6	16	10	32	1.2	3.4	0.4	
		OLMS*	-	-	-	-	-	-	-	
2	20	Inlet	7.5	208	65	216	16.4	21.6	16.7	Not meeting the Standards wrt TSS, BOD, COD, Ammonical Nitrogen.
		Outlet	7.3	52	35	88	5.2	6.8	2	
		OLMS	7.6	134.7	95	530	-	20	-	
Total 60										

Remarks: OLMS (40 MGD) was found non-functional at the time of DPCC Monitoring

Mishra
I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/02/4830

Dated: 03/06/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY -2022

1. Name of STP : Molarband (Mini STP)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.05.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	0.66	Inlet	7.4	184	112	416	20.4	20.4	15.2	Not meeting the Standards wrt TSS, BOD & COD
		Outlet	7.2	18	12	64	1.6	2	2	
		OLMS	6.9	58.91	23.67	113.85	-	27.88	-	
Total 0.66										

I/C LABORATORY

DR. NANDITA MOHTRA
Scientist 'C'