



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/24-25/197/1443

Dated 03/12/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2024

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 13.11.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	70 MGD	Inlet	7.3	140	88	244	15.2	21.6	22.4	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.5	24	17	56	1.6	1.2	1.4	1300	
		OLMS	6.7	6.8	4.2	28.8	-	1.3	-	-	
Total 70											

I/C Water Laboratory

SSA/Analyst/SLA

Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/198/ 1444

Dated 03/12/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2024

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 13.11.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Fecal Coliform MPN/100ml	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
1	Ph-I,II (20)	Inlet	7.4	264	157	300	14.4	22.3	23.5	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.3	16	12	40	2.8	2.2	1.6	950	
		OLMS	7.4	14.85	9.90	49.50	-	5.59	-	-	
2	Ph-III (10)	Inlet	7.5	230	120	296	16.8	24.1	21.4	-	Not meeting the standards wrt TSS,BOD & COD.
		Outlet	7.7	21	13	48	1.2	1.8	1.6	180	
		OLMS	-	-	-	-	-	-	-	-	
Total 30											OLMS was non-functional

I/C Water Laboratory

SSA/Analyst/SLA

Dr. Nandana Mishra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/24-25/199/ 1445

Dated 03/12/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2024

1. Name of STP : Delhi Gate (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 22.11.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	Phase-I & II (15)	Inlet	7.5	210	100	264	14.4	14.8	16.4	-	Meeting the Standards.
		Outlet	7.1	6	4	40	1.2	2.4	1.2	95	
		OLMS	7.2	6.7	3.6	23.1	-	2.1	-	-	
Total 15											

[Signature]
I/C Water Laboratory
Dr. Nandini Mehta
Scientist 'D'

[Signature]
SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/24-25/200/ 1446

Dated 03/12/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2024

1. Name of STP : Delhi Gate (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 22.11.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	Ph-I & II (2.2)	Inlet	7.3	198	125	272	19.2	17.2	15.3	-	Not meeting the standards wrt Fecal Coliform.
		Outlet	7.4	9	8	36	0.8	1.2	1.1	1700	
		OLMS	7.3	5.0	2.0	13.0	-	1.1	-	-	
Total 2.2											

I/C Water Laboratory

Dr. Nandini Mishra
Scientist 'D'

SSA/Analyst/SLA

[Signature]



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/201/ 1447

Dated

03/12/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2024

1. Name of STP : Keshopur STP (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.11.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	12		6.5-9.0	10	10	50	10	5	2	230	Not meeting the standards wrt TSS, BOD, COD & fecal coliform.
		Inlet	7.4	208	133	196	14.4	22.9	23.6	-	
		Outlet	7.1	27	17	92	1.2	2.1	1.2	1400	
		OLMS	-	-	-	-	-	-	-	-	OLMS was non functional
Total 12											

I/C Water Laboratory

SSA/Analyst/SLA

Scientist D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/202/ 1448

Dated 03/12/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2024

1. Name of STP : SEN Nursing Home (SNH)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 22.11.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	Phase-I,II (2.2)	Inlet	7.5	182	120	268	15.6	16.9	19.3	-	Not meeting the standards wrt Fecal Coliform.
		Outlet	7.3	7	4	28	0.8	1.2	1.6	350	
		OLMS	7.2	5.6	4.7	21.6	-	1.5	-	-	
Total 2.2											

I/C Water Laboratory
Dr. Vandana Mittal

Scientist-D

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocnms.mc.in>)



Report Number: DPCC/W/STP/24-25/203/ 1449

Dated 03/12/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2024

1. Name of STP : Nilothi New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 20.11.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	20	Inlet	7.5	228	167	236	13.2	12.4	14.6	-	Meeting the standards.
		Outlet	7.3	8	7	40	2.0	1.6	1.4	90	
		OLMS	7.6	5.4	3.9	37.1	-	4.6	-	-	
Total 20											

I/C Water Laboratory

Dr. Namita Mohita
Scientist-D

SSA/Analyst/SLA

[Signature]



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccenmms.nic.in>)



Report Number: DPCC/W/STP/24-25/204/ **1450**

Dated **03/12/2024**

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2024

1. Name of STP : **Nilothi**
2. Sampling location : **Inlet and Outlet of STP**
3. Date of Inspection : **20.11.2024**
4. Samples collected by : **DPCC Lab**
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	40	Inlet	7.5	250	200	361	19.2	17.6	22.6	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.4	34	18	88	1.2	1.8	1.7	1400	
		OLMS	-	-	-	-	-	-	-	-	
Total 40											OLMS was non functional

I/C Water Laboratory

SSA/Analyst/SLA

Dr. Tanuja Mishra
Scientist D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number DPCC/W/STP/24-25/205/1451

Dated 03/12/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2024

1. Name of STP : Najafgarh
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 22.11.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Fecal Coliform MPN/100ml	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
1	5	Inlet	7.5	208	100	320	23.2	13.8	20.4	-	Meeting the standards.
		Outlet	7.4	8	7	36	1.2	2.8	1.3	95	
		OLMS	7.0	10.5	8.3	35.0	-	5.1	-	-	
Total 5											

I/C Water Laboratory

SSA/Analyst/SLA

Scientist D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/206/1452

Dated: 03/12/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2024

1. Name of STP : Rithala
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 05.11.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters									Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml		
1	Ph-I(40)		6.5-9.0	10	10	50	10	5	2	230	Meeting the standards	
		Inlet	7.3	198	167	260	15.6	18.4	22.7	-		
		Outlet	7.1	5	3	24	1.6	2.1	1.7	120		
		OLMS	-	-	-	-	-	-	-	-		
2	Ph-II(40)	Inlet	7.6	174	86	236	12.4	17.6	20.7	-	Meeting the standards	
		Outlet	7.4	3	2	32	2.4	2.7	1.5	150		
		OLMS	7.3	6.8	4.8	25.7	-	4.4	-	-		
Total 80												

I/C Water Laboratory

Dr. Renuka Mishra

Scientist 'D'

SSA/Analyst/SLA

Atash



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocoms.nic.in>)



Report Number: DPCC/W/STP/24-25/207/ 1453

Dated 03/12/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2024

1. Name of STP : Pappankalan (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 20.11.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	20	Inlet	7.5	202	120	208	12	20.5	21.4	-	Not meeting the Standards wrt TSS, BOD COD & Fecal Coliform.
		Outlet	7.3	31	17	76	2.4	2.6	1.8	2400	
		OLMS	8.1	15.7	11.6	58.6	-	6.0	-	-	
Total 20											

I/C Water Laboratory

SSA/Analyst/SLA

Scientist D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocemms.nic.in>)



Report Number: DPCC/W/STP/24-25/208/1454

Dated

03/12/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2024

1. Name of STP : Pappankalan Ph-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 20.11.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
20		Inlet	6.5-9.0	10	10	50	10	5	2	230	Not meeting the Standards wrt Fecal Coliform.
		7.5	202	120	208	12	20.5	21.4	-		
		Outlet	7.6	7	5	24	1.2	1.8	1.6	1700	
		OLMS	6.8	5.7	4.3	26.3	-	1.6	-		
Total 20											

I/C Water Laboratory

M. Kishor

Dr. Nandini Mishra

Scientist 'D'

SSA/Analyst/SLA

M. Kishor



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/210/ 1456

Dated 03/12/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2024

1. Name of STP : Narela
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 05.11.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	10	Inlet	6.5-9.0	10	10	50	10	5	2	230	Meeting the standards.
			7.1	256	217	276	17.2	21.3	22.4	-	
		Outlet	7.6	9	8	32	2.4	1.8	2.1	95	
		OLMS	-	-	-	-	-	-	-	-	OLMS was not functional.
Total 10											

I/C Water Laboratory

SSA/Analyst/SLA

D. Narela
Scientist 'D'

[Signature]



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocms.nic.in>)



Report Number: DPCC/W/STP/24-25/211/1457

Dated 03/12/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2024

1. Name of STP : Okhla New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 21.11.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Fecal Coliform MPN/100ml	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)		
1	30	Inlet	7.2	234	133	304	21.2	17.8	19.6	-	Meeting the Standards.
		Outlet	7.6	9	8	32	1.2	1.9	1.5	180	
		OLMS	7.3	6.9	4.8	24.0	-	1.5	-	-	
Total 30											

I/C Water Laboratory

Dr. Manisha Mohita

Scientist 'D'

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/24-25/212/ 1458

Dated 03/12/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2024

1. Name of STP : Kondli
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 22.11.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	Ph-I (10)	Inlet	7.6	266	160	272	16.8	18.7	19.6	-	Meeting the standards.
		Outlet	7.4	6	4	24	1.2	1.2	1.4	180	
		OLMS	7.5	8.6	4.4	28.3	-	0.2	-	-	
2	Ph-II & III (25+10)	Outlet	7.7	7	5	20	0.8	1.1	1.5	140	Meeting the standards
		OLMS	7.8	9.6	7.4	28.4	-	0	-	-	
Total 45											

M. K. Singh
M. K. Singh
Scientist 'D'

SSA/Analyst/SLA

Alka



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocms.nic.in>)



Report Number: DPCC/W/STP/24-25/213/ 1459

Dated 03/12/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2024

1. Name of STP : Kondli New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 22.11.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	Ph-IV (45)	Inlet	7.5	176	150	256	17.2	21.3	17.9	-	Meeting the Standards.
		Outlet	7.2	9	7	36	1.6	0.8	1.2	180	
		OLMS	7.5	5.5	3.1	18.5	-	3.3	-	-	
Total 45											

I/C Water Laboratory

SSA/Analyst/SLA

Dr. Nandini Mehta
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/214/ 1460

Dated 03/12/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2024

1. Name of STP : Kapasahera
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 25.11.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	5	Inlet	7.5	256	167	276	14.4	18.3	21.6	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.1	27	14	60	1.2	1.6	1.4	2100	
		OLMS	7.5	8.7	5.3	35.4	-	3.7	-	-	
Total 5											

I/C Water Laboratory

SSA/Analyst/SLA

Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/215/1461

Dated 03/12/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2024

1. Name of STP : Yamuna Vihar Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.11.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	25	Inlet	7.5	154	138	288	18.8	15.4	24.6	-	Not meeting the Standards wrt TSS, BOD & COD.
		Outlet	7.7	25	22	56	2.8	1.8	1.6	95	
		OLMS	7.34	20.04	11.62	54.81	-	16.05	-	-	
Total 25											

I/C Water Laboratory

SSA/Analyst/SLA

Dr. Nandana Mohita

Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/216/ 1462

Dated 03/12/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2024

1. Name of STP : Chilla
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 22.11.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	9	Inlet	7.3	190	125	264	10.8	23.7	18.5	-	Meeting the Standards.
		Outlet	7.5	5	3	16	0.8	1.6	1.2	110	
		OLMS	7.2	6.7	4.5	26.9	-	1.8	-	-	
Total 9											

I/C Water Laboratory

M. M. M. M.

Atash

SSA/Analyst/SLA

Dr. Anamika Mishra

Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocoms.nic.in>)



Report Number: DPCC/W/STP/24-25/217/ 1463

Dated 03/12/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2024

1. Name of STP : Akshardham
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 22.11.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	1	Inlet	6.5-9.0	10	10	50	10	5	2	230	Meeting the Standards.
		Outlet	7.4	188	160	272	18.4	20.4	16.9	-	
		OLMS	7.6	2	3	24	1.6	1.8	1.5	95	
Total 1			7.6	0.8	1.7	6.9	-	0.1	-	-	

I/C Water Laboratory

Dr. Anurag Mishra
Scientist 'D'

SSA/Analyst/SLA

[Signature]



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/218/ 1464

Dated

03/12/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2024

1. Name of STP : Mehrauli
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 25.11.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters									Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml		
1	15	Inlet	7.5	232	160	312	24.4	19.6	21.4	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.	
		Outlet	7.3	23	15	76	1.2	1.3	1.8	2200		
		OLMS	7.3	16.5	6.2	41.3	-	6.9	-	-		
Total 15												

I/C Water Laboratory

U. Mehrauli

Scientist D

SSA/Analyst/SLA

Atash



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/219/ 1465

Dated

03/12/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2024

1. Name of STP : Vasant Kunj
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 25.11.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	2.2	Inlet	6.5-9.0	10	10	50	10	5	2	230	Not meeting the standards wrt TSS,BOD, COD & Fecal Coliform.
		7.3	248	150	320	12.4	20.4	17.3	-		
		Outlet	7.6	57	34	84	2.4	1.3	1.1	1600	
2	3	OLMS	7.1	6.2	4.3	25.3	-	7.7	-	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
		Inlet	7.1	242	175	292	19.2	20.1	21.3	-	
		Outlet	7.4	59	38	80	1.6	0.9	1.6	1800	
		OLMS	7.4	6.9	6.4	34.4	-	8.3	-	-	
Total 5.2											

I/C Water Laboratory

Scientist 'D'

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/220/ 1466

Dated 03/12/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2024

1. Name of STP : Yamuna Vihar
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.11.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	10 Ph-1	Inlet	6.5-9.0	10	10	50	10	5	2	230	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform
		Outlet	7.3	180	129	268	12	14.6	22.4	-	
		OLMS	7.6	36	15	60	3.6	2.6	1.8	1300	
		OLMS	6.5	9.9	6.4	3.7	-	13.7	-	-	
2	10 Ph-2	Inlet	7.4	170	117	292	18.8	16.4	20.4	-	Meeting the standard.
		Outlet	7.7	7	5	24	2.8	2.4	1.6	90	
		OLMS	-	-	-	-	-	-	-	-	
		OLMS	-	-	-	-	-	-	-	-	
Total 20											OLMS was non functional

I/C Water Laboratory

M. Nandita

Dr. Nandita Mohita
Scientist 'D'

SSA/Analyst/SLA

M. Nandita



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, JSBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/24-25/221/ 1467

Dated

03/12/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2024

1. Name of STP : Molarband (Mini STP)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 21.11.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	0.66	Inlet	7.6	268	178	256	19.6	19.8	13.6	-	Not meeting the standard wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.1	32	18	64	2.4	1.5	1.3	1500	
		OLMS	6.9	28.4	18.6	86.6	-	8.8	-	-	
Total 0.66											

I/C Water Laboratory

SSA/Analyst/SLA

D. NARAYANA MOHITA
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/24-25/222/ 1468

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2024

Dated

03/12/2024

1. Name of STP : Okhla
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 21.11.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
	12	Inlet	6.5-9.0	10	10	50	10	5	2	230	No Flow and closed.
		Outlet	7.6	284	167	296	16	21.6	19.7	-	
		OLMS	-	-	-	-	-	-	-	-	
		OLMS	-	-	-	-	-	-	-	-	
1	16	Outlet	7.3	9	6	28	1.6	1.3	1.7	130	OLMS was non functional Meeting the Standards.
		OLMS	7.1	34.3	22.9	57.3	-	8.0	-	-	
		Outlet	-	-	-	-	-	-	-	-	
		OLMS	-	-	-	-	-	-	-	-	
	37	Outlet	7.1	29	16	76	2.4	2.2	1.9	1200	OLMS was non functional Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform.
		OLMS	7.0	16.3	9.3	46.8	-	7.0	-	-	
		Outlet	-	-	-	-	-	-	-	-	
		OLMS	-	-	-	-	-	-	-	-	
Total 110											

I/C Water Laboratory

Scientist 'D'

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocms.nic.in>)



Report Number: DPCC/W/STP/24-25/223/

1469

Dated

03/12/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2024

1. Name of STP : Keshopur
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.11.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	40	Inlet	6.5-9.0	10	10	50	10	5	2	230	Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform.
			7.5	224	138	292	26.4	21.6	22.7	-	
		Outlet	7.3	31	17	64	2.4	2.8	1.6	1100	
2	20	OLMS	-	-	-	-	-	-	-	-	Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.2	34	20	56	1.6	3.2	2	1400	
		OLMS	-	-	-	-	-	-	-	-	
Total 60											OLMS was non functional

I/C Water Laboratory

Scientist 'D'

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocems.nic.in>)



Report Number: DPCC/W/STP/24-25/224/ 1470

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2024

Dated 03/12/2024

1. Name of STP : Ghitorni
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 25.11.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	5	Inlet	7.8	208	200	272	15.2	19.8	21.4	-	Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.6	62	36	84	1.6	1.4	1.7	1200	
		OLMS	7.7	17.2	8.2	44.1	-	9.5	-	-	
Total 5											

I/C Water Laboratory

O. Naraina Mehta

Scientist D

SSA/Analyst/SLA

Arash