



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



LIFE
Lifestyle for Environment

Report Number: DPCC/W/STP/24-25/29/ 998

Dated 14/06/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2024

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 17.05.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters									Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml		
1	70 MGD	Inlet	7.5	284	100	352	12.8	21.7	2	230	Meeting the standards.	
		Outlet	7.6	9	6	28	0.4	3.5	1.7	95		
		OLMS	8.4	9.3	7.3	39.5	-	1.7	-	-		
Total 70												


Dr. Navin D.
 Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



LIFE
Lifestyle for Environment

Report Number: DPCC/W/STP/24-25/30/ 999 Dated 14/06/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2024

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 17.05.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Fecal Coliform MPN/100ml	Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)			
1	Ph-I,II (20)	Inlet	6.5-9.0	10	10	50	10	13.6	5	2	230	Not meeting the standards wrt TSS, BOD COD & Fecal Coliform.
		Outlet	7.4	220	150	352	10	21.7	17.8	-		
		OLMS	7.8	18	12	56	1.2	1.9	1.6	540		
2	Ph-III (10)	Inlet	7.5	14.2	9.4	47.4	-	6.1	-	-	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.2	158	100	248	16.4	24.6	21.7	-		
		OLMS	7.6	24	14	64	0.8	2.1	1.8	920		
Total 30			-	-	-	-	-	-	-	-	OLMS was non-functional	


 I/C LABORATORY
 Dr. Vasanti Moitra



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/24-25/31/ 1000

Dated

14/06/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2024

1. Name of STP : Delhi Gate (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.05.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :


S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	Phase-I & II (15)	Inlet	6.5-9.0	10	10	50	10	5	2	230	Meeting the Standards.
			7.4	172	120	248	8	21.7	10.6	-	
		Outlet	7.9	7	4	20	1.2	2.2	0.8	220	
			OLMS	7.3	5.2	2.1	16.1	-	1.7	-	
Total 15											

N. Nandita

I/C LABORATORY

Dr. Nandita Nandita

Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/32/ 100)

Dated

14/06/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2024

1. Name of STP : Delhi Gate (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.05.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	Ph-I & II (2.2)	Inlet	7.3	140	160	236	8.8	24.8	13.4	-	Meeting the Standards.
		Outlet	7.5	9	6	28	0.8	1.6	1.2	210	
		OLMS	7.5	7.0	3.9	23.3	-	0.5	-	-	
Total 2.2											

Nandita

I/C LABORATORY

Dr. Nandita Moitra

Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/24-25/33/ 1002

Dated

14/06/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2024

1. Name of STP : Keshopur STP (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.05.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	12	Inlet	6.5-9.0	10	10	50	10	5	2	230	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform. OLMS was non functional
			7.4	272	175	332	18.4	21.9	20.7	-	
		Outlet	7.1	36	13	72	1.6	1.5	1.3	920	
		OLMS	-	-	-	-	-	-	-	-	
Total 12											

N. Mohita

I/C LABORATORY

Dr. Nandita Moitra

Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/24-25/34/ 1003

Dated

14/06/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2024

1. Name of STP : SEN Nursing Home (SNH)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.05.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters									Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml		
1	Phase-I,II (2.2)	Inlet	7.1	224	133	296	8.4	21.7	9.3	-	Meeting the Standards	
		Outlet	7.6	7	4	24	0.4	1.8	1.5	81		
		OLMS	7.6	5.5	3.6	24.5	-	1.7	-	-		
		Total 2.2										

Maitra

I/C LABORATORY

Dr. Nandita Maitra

Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/24-25/35/ 1004

Dated

14/06/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2024

1. Name of STP : Nilothi New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 16.05.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	20	Inlet	7.5	218	75	288	12.8	17.3	13.8	-	Meeting the standards
		Outlet	7.1	8	5	24	0.4	1.7	1.2	79	
		OLMS	7.5	7.1	3.3	35.9	-	2.5	-	-	
Total 20											

N. N. Moitra

I/C LABORATORY

Dr. Nandita Moitra

Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/24-25/36/ 1005

Dated

14/06/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2024

1. Name of STP : Nilothi
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 16.05.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :


Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	40	Inlet	6.5-9.0	10	10	50	10	5	2	230	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
			7.7	248	150	312	18.4	20.3	27.5	-	
		Outlet	7.3	18	14	64	1.2	3.3	1.7	430	
		OLMS	8.3	32.1	20.2	178.6	-	12.5	-	-	
Total 40											

N. Naitra

I/C LABORATORY

Dr. Nandita Moitra

Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



LIFE
Lifestyle for
Environment

Report Number DPCC/W/STP/24-25/37/ 1006

Dated

14/06/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2024

1. Name of STP : Najafgarh
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 16.05.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Fecal Coliform MPN/100ml	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
1	5	Inlet	6.5-9.0	10	10	50	10	5	2	230	Not meeting the standards wrt TSS, BOD, COD & Fecal coliform.
			7.6	252	140	336	10.8	26.8	21.7	-	
		Outlet	7.8	28	17	88	0.8	1.7	1.8	1600	
		OLMS	8.1	24.2	17.7	129.7	-	18.4	-	-	
Total 5											

N. Mittal

I/C LABORATORY

Dr. Nandita Moitra

Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/24-25/38/ 1067

Dated: 14/06/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2024

1. Name of STP : Rithala
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 15.05.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	Ph-I(40)	Inlet	6.5-9.0	10	10	50	10	5	2	230	Plant was under Rehabilitation
			-	-	-	-	-	-	-	-	
			-	-	-	-	-	-	-	-	
2	Ph-II(40)	Inlet	7.5	224	150	312	15.6	23.6	14.2	-	Meeting the standards
			7.6	7	4	24	0.4	1.7	2.1	95	
			7.6	8.0	7.1	38.7	-	4.8	-	-	
Total 80											

N. Nandita

I/C LABORATORY

Dr. Nandita Nandita

Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/39/ 1008

Dated 14/06/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2024

1. Name of STP : Pappankalan (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 16.05.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	20	Inlet	7.9	288	80	320	13.6	19.6	25.5	-	Not meeting the Standards wrt TSS, BOD, COD, Dissolved Phosphate & Fecal Coliform.
		Outlet	7.3	36	16	56	1.2	3.2	2.4	350	
		OLMS	7.8	61.3	17.0	128.5	-	16.1	-	-	
Total 20											

N. N. Mitta

I/C LABORATORY
Dr. Nandita Moitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/40/ 1009

Dated

14/06/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2024

1. Name of STP : Pappankalan Ph-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 16.05.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
	20	Inlet	6.5-9.0	10	10	50	10	5	2	230	Meeting the Standards.
			7.9	288	80	320	13.6	19.6	25.5	-	
		Outlet	7.5	7	4	28	0.4	2.4	1.4	120	
		OLMS	7.6	6.7	5.2	41.5	-	1.9	-	-	
Total 20											

N. Nishita

I/C LABORATORY

Dr. Nandita Moitra

Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number DPCC/W/STP/24-25/41/ 10 | 0

Dated

14/06/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2024

1. Name of STP : Rohini
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 15.05.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :


Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	15	Inlet	7.9	292	180	324	12.4	22.8	15.6	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.8	28	17	52	0.4	2.4	1.9	540	
		OLMS	7.3	26.3	17.9	105.2	-	12.1	-	-	
Total 15											

Nandita

I/C LABORATORY

Dr. Nandita Mehta

Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/42/ 101

Dated 14/06/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2024

1. Name of STP : Narela
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 15.05.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters									Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml		
1	10	Inlet	6.5-9.0 7.1	10 214	10 100	50 192	10 8.8	5 24.4	2 13.7	230 -	Not meeting the standards wrt TSS, BOD, COD & Fecal coliform.	
		Outlet	7.5	26	18	72	1.2	1.4	1.5	430		
		OLMS	8.3	11.4	8.7	52.0	-	9.3	-	-		
Total 10												

Nandita

I/C LABORATORY

Dr. Nandita Mahtia

Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/24-25/43/ 10/2

Dated

14/06/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2024

1. Name of STP : Okhla New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 15.05.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	30	Inlet	6.5-9.0	10	10	50	10	5	2	230	Meeting the Standards.
			7.2	224	120	304	9.2	24.2	24.6	-	
			7.5	7	4	28	0.8	1.5	1.36	79	
		OLMS	8.1	6.1	3.8	23.6	-	0.9	-	-	
Total 30											

N. Mittal

Dr. Nalini Moitra

Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/24-25/44/10/3

Dated 14/06/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2024

1. Name of STP : Kondli
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.05.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	Ph-I (10)	Inlet	6.5-9.0	10	10	50	10	5	2	230	Meeting the standards.
			7.5	212	150	324	12.4	24.5	28.6	-	
			7.7	6	4	32	1.2	1.3	0.8	81	
		OLMS	9.3	12.0	4.0	24.1	-	0.03	-	-	
2	Ph-II & III (25+10)	Outlet	7.6	9	6	20	0.8	0.9	1.2	72	Meeting the standards
		OLMS	7.3	9.2	3.8	43.2	-	4.7	-	-	
		Total 45									

N. Mitra

I/C LABORATORY
Dr. Nandita Moitra

Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/45/ 1014

Dated

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2024


1. Name of STP : Kondli New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.05.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	Ph-IV (45)	Inlet	6.5-9.0	10	10	50	10	5	2	230	-
		Outlet	7.5	146	125	204	11.2	24.6	25.2	1.8	540
		OLMS	7.8	26	16	60	1.2	2.8	-	-	-
Total 45			-	-	-	-	-	-	-	-	OLMS was non-functional
Not Meeting the Standards wrt TSS, BOD, COD & Fecal coliform.											

N. Nanda

I/C LABORATORY
Dr. Nandita Moitra

Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



LIFE
Lifestyle for
Environment

Report Number: DPCC/W/STP/24-25/46/ 1015

Dated

14/06/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2024

1. Name of STP : Kapasahera
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 20.05.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :


Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	5	Standard	6.5-9.0	10	10	50	10	5	2	230	Not Meeting the Standards wrt TSS, BOD, COD & Fecal coliform.
		Inlet	7.3	182	122	244	7.6	26.5	16.4	-	
		Outlet	7.8	42	18	88	2.8	3.7	1.3	540	
		OLMS	7.3	8.9	4.8	43.2	-	3.7	-	-	
Total 5											

Nandita

I/C LABORATORY

Dr. Nandita Moitra

Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/24-25/47/ 1016

Dated

14/06/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2024

1. Name of STP : Yamuna Vihar Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.05.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters									Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml		
1	25	Inlet	7.5	176	133	196	5.2	17.5	25.7	-	Not meeting the Standards wrt TSS, BOD, COD & fecal coliform.	
		Outlet	7.2	18	12	56	1.6	1.6	1.2	920		
		OLMS	8.0	22.1	14.2	54.9	-	19.6	-	-		
Total 25												

N. Mitta

I/C LABORATORY

Dr. Nandita Moitra

Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



LIFE
Lifestyle for
Environment

Report Number: DPCC/W/STP/24-25/48/ 10/7

Dated

14/06/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2024

1. Name of STP : Chilla
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.05.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	9	Inlet	6.5-9.0	10	10	50	10	5	2	230	Meeting the Standards.
			7.1	172	80	228	3.8	25.8	12.4	-	
		Outlet	7.3	7	6	28	0.6	2.4	0.8	79	
		OLMS	7.3	9.9	6.9	35.6	-	2.6	-		
Total 9											

N. Mitta

Dr. Naitika Mitta

Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/49/ 1018

Dated

14/06/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2024

1. Name of STP : Akshardham
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.05.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	1	Inlet	6.5-9.0	10	10	50	10	5	2	230	Meeting the Standards.
			7.3	248	150	276	6.8	15.8	17.5	-	
		Outlet	7.5	6	5	16	0.4	1.2	0.6	62	
			OLMS	7.5	0.9	1.8	6.6	-	0.1	-	
Total 1											

N Naitra

I/C LABORATORY

Dr. Nandita Moitra

Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/24-25/50/ 1019

Dated

14/06/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2024

1. Name of STP : Mehrauli
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 16.05.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	15	Inlet	6.5-9.0	10	10	50	10	5	2	230	Not meeting the standards wrt TSS, BOD, COD & Fecal coliform.
			7.9	208	120	324	9.6	18.7	22.7	-	
		Outlet	7.3	32	16	68	1.2	3.8	1.7	920	
		OLMS	7.5	15.8	8.0	53.7	-	12.4	-		
Total 15											

N. Naita

I/C LABORATORY
Dr. Nandita Moitra
Scientist 'D'



(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

(Visit us at <https://www.dpccommms.nic.in>)

14/06/2024

1.	Name of STP	:	Vasant Kunj
2.	Sampling location	:	Inlet and Outlet of STP
3.	Date of Inspection	:	16.05.2024
4.	Samples collected by	:	DPCC Lab
5.	Parameters analyzed and results	:	

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	2.2	Inlet	6.5-9.0	10	10	50	10	5	2	230	Not meeting the standards wrt TSS, BOD, COD, Dissolved phosphate & Fecal coliform.
			7.8	242	140	268	13.6	17.8	28.9	-	
			7.5	76	38	132	1.6	3.2	2.6	920	
			7.6	7.9	5.6	39.7	-	7.2	-	-	
2	3	Inlet	7.3	210	133	292	10.8	21.3	21.8	-	Not meeting the standards wrt TSS, BOD, COD, Dissolved phosphate & Fecal coliform.
			7.6	85	34	168	1.2	2.7	3.5	540	
			7.7	6.8	4.9	30.8	-	8.5	-	-	
			Total 5.2								

Minister

Dr/C LABORATORY
Dr. Nandita Moitra

Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/24-25/52/ 1021

Dated 14/06/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2024


1. Name of STP : Yamuna Vihar
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.05.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	10 Ph-1	Inlet	6.5-9.0	10	10	50	10	5	2	230	Not meeting the standards wrt TSS, BOD & Fecal coliform.
			7.6	148	83	164	4.8	16.8	22.8	-	
		Outlet	7.8	28	16	44	1.2	3.1	1.5	920	
2	10 Ph-2	OLMS	8.1	-	8.8	36.5	-	20.6	-	-	TSS reading not shown in OLMS
		Inlet	7.2	140	120	228	5.6	18.2	19.6	-	
		Outlet	7.1	24	12	60	1.6	2.9	1.2	220	
Total 20		OLMS	-	-	-	-	-	6.6	-	-	OLMS was non functional

N. Nishan

KC LABORATORY
Dr. Vandita Moitra

Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/53/1022

Dated

14/06/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2024

1. Name of STP : Molarband (Mini STP)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 15.05.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	0.66	Inlet	6.5-9.0 7.1	10 292	10 160	50 324	10 16.8	5 25.6	2 20.6	230 -	Not meeting the standard wrt TSS, BOD, COD & Fecal coliform. OLMS was non functional
		Outlet	7.4	24	16	72	2.8	1.7	1.7	1600	
		OLMS	-	-	-	-	-	-	-	-	
Total 0.66											

N. Moitra

I/C LABORATORY

Dr. Nandita Moitra

Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/54/ 1023

Dated

14/06/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2024

1. Name of STP : Okhla
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 15.05.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)		Fecal Coliform MPN/100ml
1	12	Inlet	6.5-9.0	10	10	50	10	5	2	230	Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform.
			7.7	252	133	328	22.4	20.2	16.6	-	
		Outlet	7.8	38	22	76	0.8	1.3	1.4	540	
		OLMS	7.3	19.4	8.3	29.1	-	26.1	-	-	Meeting the Standards.
		Outlet	7.4	9	8	36	0.4	1.7	0.9	79	
		OLMS	7.7	9.5	7.4	32.6	-	3.5	-	-	
	37	Outlet	7.1	46	28	60	1.2	2.5	1.1	920	Not meeting the Standards wrt TSS, BOD, COD & Fecal coliform.
		OLMS	7.5	31.4	29.9	78.5	-	18.8	-	-	
	45	Outlet	7.5	58	30	84	1.6	2.1	1.9	1600	Not meeting the Standards wrt TSS, BOD, COD & Fecal coliform.
		OLMS	7.3	20.0	11.9	59.8	-	13.4	-	-	
Total 110											

Maitra

I/C LABORATORY Moitra

Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/55/ 1024

Dated

14/06/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2024


1. Name of STP : Keshopur
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.05.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	40	Inlet	6.5-9.0	10	10	50	10	5	2	230	Not meeting the Standards wrt TSS, BOD, COD & Fecal coliform. OLMS was Non functional
			7.5	256	160	348	15.6	21.6	29.8	-	
		Outlet	7.9	24	15	64	1.2	2.7	1.9	540	
2	20	OLMS	-	-	-	-	-	-	-	-	Not meeting the Standards wrt TSS, BOD, COD & Fecal coliform. OLMS was Non functional
		Outlet	7.3	28	18	56	0.4	3.5	1.7	350	
		OLMS	-	-	-	-	-	-	-	-	
Total 60											

Nmitra

I/C LABORATORY

Dr. Nandita Mitta
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



LIFE
Lifestyle for Environment

Report Number: DPCC/W/STP/24-25/56/ 1025 Dated 14/06/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2024

1. Name of STP : Ghitorni
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 16.05.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	5	Inlet	6.5-9.0 7.4	10 344	10 157	50 388	10 13.2	5 27.5	2 25.8	230 -	Not meeting the Standards wrt TSS, BOD, COD & Fecal coliform.
		Outlet	7.1	112	46	124	1.2	2.3	1.6	920	
		OLMS	7.7	16.2	11.1	62.7	-	12.8	-	-	
Total 5											


J/C LABORATORY
Dr. Nandita Moitra
 Scientist 'D'