

DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/38 / 3086

dt 5/3/21

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2021

1. Name & Address of Ind./Unit : Narela STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.02.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :


Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	10	Inlet	7.15	108	64	232	6.8	36.5	12.9	Not Meeting the Standards w.r.t TSS & DP.
		Outlet	7.38	18	8	40	1.4	3.7	2.3	
		OLMS*	7.53	28.96	14.47	70.90	-	-	-	
Total 10										

Nandita

I/C Water Lab

NANDITA MOITRA

Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/20-21/37

308

dt 5/3/21

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2021

1. Name & Address of Ind./Unit : Rohini STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 12.02.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :


5. Parameters analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	15	Inlet	7.56	344	250	488	26.0	56.2	17.5	Not meeting the Standards w.r.t TSS, AN, DP.
		Outlet	7.46	14	8	48	3.2	9.3	2.2	
		OLMS*	7.31	21.36	14.47	66.04	0.13	14.22	2.32	
Total 15										

Nandita

I/C Water Lab

Dr. NANDITA MOITRA

Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/35

3084

dt 5/3/21

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2021

1. Name & Address of Ind./Unit : Pappankalan STP(Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.02.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :


Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	20	Inlet	7.52	160	142	512	20.0	73.8	8.6	Not meeting the Standards w.r.t TSS, BOD, A.N, COD & DP.
		Outlet	7.66	50	28	148	3.6	8.2	2.5	
		OLMS*	7.50	49.44	25.39	98.06	-	14.8	-	
Total 20						Total 20				

N. Mohan

I/C Water Lab

Dr. NANDITA MOITRA

Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE (Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/20-21/33 / 3083


At 5/3/21

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2021

1. Name & Address of Ind./Unit : Najafgarh STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.02.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	5	Inlet	7.32	540	165	586	14.0	84.6	18	Not meeting the standards w.r.t to TSS, BOD, COD, A.N. & DP.
		Outlet	7.9	46	20	92	2.4	8.0	3.2	
		OLMS*	7.64	38.82	17.74	143.57	-	15.05	-	
Total 5										

Nandita
I/C Water Lab
Dr. NANDITA MOITRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/32 / 3082


dt 5/3/21

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2021

1. Name & Address of Ind./Unit : Nilothi STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.02.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	40	Inlet	7.47	248	85	384	16.4	39.3	16.0	Not meeting the standards w.r.t to TSS, BOD, A.N & DP, COD.
		Outlet	7.65	72	25	136	5.2	18.9	2.5	
		OLMS*	6.90	149.12	87.25	365.02	-	36.48	-	
Total 40										

N. Mishra
Dr. NANDITA Mishra
W/C Water Lab
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/29 / 3081

dt 5/3/21


ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2021

1. Name & Address of Ind./Unit : Keshopur STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.02.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
						COD (mg/l)				
				10	10	50	10	5	2	
1	12	Inlet	7.42	188	70	328	16.8	44.5	14.2	Not meeting the Standards w.r.t TSS, BOD, COD & D.P.
		Outlet	7.35	28	15	72	2.4	4.2	2.2	
		OLMS*	7.44	8.68	8.63	43.36	-	2.53	-	
Total 12										

Nandita
I/C Water Lab

DR. NANDITA MOITRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/26 / 3080

dt 5/3/21

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2021


1. Name & Address of Ind./Unit : Coronation Pillar STP
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 18.02.2021
4. Samples collected by : DPCC, Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	Parameters COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P(mg/l) 2	Remarks
1	Ph-I,II(20)	Inlet	7.02	112	68	280	14.2	42.14	14.3	Not meeting the Standards w.r.t TSS, BOD, COD & A.N.
		Outlet	7.13	40	25	76	3.2	11.8	2.0	
		OLMS*	-	-	-	-	-	-	-	
2	Ph-III(10)	Inlet	7.10	316	240	560	46.2	68.92	52.24	Not meeting the standards w.r.t , TSS, BOD, COD, A.N & DP.
		Outlet	7.2	102	40	132	8.6	19.2	4.9	
		OLMS*	7.42	91.75	50.85	190.89	-	5.75	-	
Total 30										

Remarks: Ph-I & II OLMS was not working

Mittra
I/C Water Lab

DR. NANDITA MOITRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/31 | 3079

St 5/3/21

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2021

1. Name & Address of Ind./Unit : Nilothi STP-II
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.02.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :


Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	20	Inlet	7.45	168	120	352	12	37.0	12.2	Meeting the standards.
		Outlet	7.51	8	4	28	0.6	2.7	1.4	
		OLMS*	7.04	19.34	0.27	28.93	-	7.04	-	
Total 20										

Nandita

I/C Water Lab

DR. NANDITA MOITRA

Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/36

3078

dt 5/3/21


ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2021

1. Name & Address of Ind./Unit : Pappankalan STP-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.02.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
	20	Inlet	7.46	216	155	544	12.4	44.8	9.2	Meeting the standards.
		Outlet	7.54	10	7	34	1.2	3.4	1.6	
		OLMS*	-	6.56	4.23	24.28	-	-	-	
Total 20										

N. Mitra
I/C Water Lab

NANDITA MOITRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/34

3077


05/3/21

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2021

1. Name & Address of Ind./Unit : Rithala STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 12.02.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	Phase-I(40)	Inlet	7.17	200	105	352	14.8	52	16	Not meeting the standards w.r.t to TSS, BOD, COD, A.N. & DP
		Outlet	7.13	126	88	264	8.6	27.8	6.5	
		OLMS*	7.41	124.11	44.64	170.77	-	44.46	-	
2	Ph-II(40)	Inlet	7.04	264	198	540	36.2	32.6	12.6	Not meeting the standards w.r.t to TSS, BOD, COD.
		Outlet	7.22	16	12	92	0.8	4.8	1.8	
		OLMS*	8.14	15.15	11.31	95.81	-	7.04	-	
Total 80										

N. Mishra
I/C Water Lab
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/42

3076

A 5/3/21

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2021

1. Name & Address of Ind./Unit : Kapasahera STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.02.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	5	Inlet	6.45	804	240	540	2.4	41.6	15.5	Meeting the standards.
		Outlet	6.88	10	8	60	2.4	4.4	1.9	
		OLMS*	-	-	-	-	-	-	-	
Total 5										

Remarks: OLMS was found non-operational.

Nandita

I/C Water Lab
Dr. NANDITA MOITRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/43

30/3

dt 5/3/21


ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2021

1. Name & Address of Ind./Unit : Yamuna Vihar STP Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.02.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	25	Inlet	7.10	316	240	560	46.2	52.24	68.92	Not meeting the Standards w.r.t TSS, BOD, COD.
		Outlet	7.23	28	20	68	8.6	4.2	2.0	
		OLMS*	-	-	-	-	-	-	-	
Total 25										

Remarks: OLMS was not in working condition.

N Mehta
I/C Water Lab
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE (Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/50


ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2021

1. Name & Address of Ind./Unit : Keshopur STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.02.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	40	Inlet	7.32	380	48	448	3.6	37.1	10	Not meeting the Standards w.r.t TSS,BOD,COD, A.N & D.P.
		Outlet	7.54	70	24	96	4.4	13.0	3.2	
		OLMS*	7.03	129.34	72.05	264.81	-	29.25	-	
2	20	Inlet	6.75	376	150	608	26.4	39.1	12.2	Not meeting the Standards w.r.t TSS, BOD, COD, A.N & D.P.
		Outlet	7.29	48	20	60	2.8	18.3	2.8	
		OLMS*	7.94	129.68	89.0	278.19	-	25.76	-	
Total 60										

N. Mittal

Dr. N. Mittal
Scientist (C)



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/49


ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2021

1. Name & Address of Ind./Unit : Okhla STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.02.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
1	12	Inlet	7.4	220	90	344	16.8	32.2	16.9	Not meeting the Standards w.r.t TSS & BOD, COD, A.N.
		Outlet	7.5	36	14	68	3.2	8.6	1.6	
		OLMS	7.55	32.44	21.23	72.86	-	14.08	-	
	16	Outlet	7.7	42	24	96	0.4	4.5	3.6	Not meeting the Standards w.r.t TSS, BOD, COD & DP.
		OLMS	7.7	22.12	12.12	41.29	-	11.04	-	
	37	Outlet	7.6	48	26	108	2.8	7.2	1.5	Not meeting the Standards w.r.t TSS, BOD, COD, A.N.
		OLMS	-	-	-	-	-	-	-	
	45	Outlet	7.6	24	13	72	1.2	4.5	0.7	Not meeting the Standards w.r.t TSS, BOD, COD.
		OLMS	7.6	25.30	21.12	77.09	-	9.46	-	
	Total 110									

Remarks: OLMS (37 MGD) was found non operational.

Nandita
Dr. NANDITA MOHANTY
D/C Water Lab
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE (Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/2

3072

At 5/3/21

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2021


1. Name & Address of Ind./Unit : Molarband Mini STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.02.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	0.66	Inlet	7.44	412	100	488	26.0	66.2	36.6	Not meeting the Standards w.r.t TSS, BOD, AN, DP & COD.
		Outlet	7.62	44	20	108	4.2	18.0	3.9	
		OLMS*	-	-	-	-	-	-	-	
Total 0.66										

Remarks: OLMS was found locked at the time of DPCC Monitoring.

Nandita
I/C Water Lab

DR. NANDITA MONDAL
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/48

30/1

5/3/21

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2021


1. Name & Address of Ind./Unit : Yamuna Vihar STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.02.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results :										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	10 Ph-1	Inlet	7.16	304	90	464	22.2	48.40	44.82	Not meeting the standards w.r.t TSS, COD, AN & DP.
		Outlet	7.44	18	9	64	5.2	20.7	3.7	
		OLMS*	7.41	19.63	11.94	48.62	-	26.66	-	
2	10 Ph-2	Inlet	7.10	316	120	448	22.8	40.86	15.5	Not meeting the standard wrt TSS, BOD, COD,A.N & DP.
		Outlet	8	58	28	82	4.8	5.4	2.8	
		OLMS*	-	-	-	-	-	-	-	
Total 20										
Remarks: Ph-II OLMS was not working										

Remarks: Ph-II OLMS was not working.

Mitra

I/C Water Lab
Dr. NANDITA MOITRA
Scientist IC



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/47

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2021


1. Name & Address of Ind./Unit : Vasant Kunj STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.02.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	AmmonicalN itrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	2.2	Inlet	6.9	456	210	576	24.0	37.8	21.9	Not Meeting the Standards w.r.t TSS, BOD & COD, A.N.
		Outlet	7	32	19	76	2.8	11.7	2	
		OLMS*	7.18	15.46	14.42	46.89	-	4.49	-	
2	3	Inlet	7.55	344	95	760	4.5	36.2	14.6	Not Meeting the Standards w.r.t COD, BOD, TSS.
		Outlet	6.74	28	15	80	2.0	4.2	2.0	
		OLMS*	7.68	8.24	8.32	27.79	-	1.93	-	
Total 5.2										

Nandita

I/C Water Lab

Dr. NANDITA MOITRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/46

13069

St 5/3/21

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2021


1. Name & Address of Ind./Unit : Mehrauli STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.02.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
m	15	Inlet	7.48	144	70	256	6.2	39.8	15.62	Not meeting the standards w.r.t TSS.
		Outlet	7.69	14	10	40	1.2	3.9	1.7	
		OLMS*	7.5	140	7.16	90.71	-	-	-	
Total 15										

N. Mehta

I/C Water Lab

Dr. NANDITA MOITRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE (Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/45 / 3068

dt 5/3/21


ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2021

1. Name & Address of Ind./Unit : Akshardham STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.02.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	1	Inlet	7.19	232	134	640	26.8	48.8	14.5	Meeting the Standards.
		Outlet	7.41	6	4.2	16	0.4	1.8	0.9	
		OLMS*	7.17	0.54	1.50	14.17	-	0.38	-	
Total 1										

N. Mitra
I/C Water Lab

Dr. NANDITA MOITRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/44/3067

at 5/3/21

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2021

1. Name & Address of Ind./Unit : Chilla STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.02.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results :										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	9	Inlet	7.13	292	116	448	2.6	55.8	14.52	Meeting the Standards.
		Outlet	7.08	8	5	24	0.4	3.1	1.0	
		OLMS*	7.23	7.88	3.56	12.05	-	1.48	-	
Total 9										

N. Mehta

I/C Water Lab

Dr. NANDITA MOITRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/41

3066

St 5/3/21

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2021

1. Name & Address of Ind./Unit : Kondli STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.02.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	45	Inlet	7.23	256	114	592	15.2	58.5	14.4	Not Meeting the Standards w.r.t TSS, BOD, COD, A.N. & DP.
		Outlet	7.34	76	46	196	6.4	18.6	4.2	
		OLMS*	7.40	61.78	59.09	199.69	-	23.91	-	
Total 45										


Remarks: OLMS was found locked.

Remarks: OLMS was found locked

N Mehta

I/C Water Lab

DR. NANDITA MOITRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/40


ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2021

1. Name & Address of Ind./Unit : Kondli STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.02.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	25	Inlet	7.31	216	146	512	12.2	52	57.2	Not meeting the Standards w.r.t TSS, BOD & COD.
		Outlet	7.56	26	19	82	3.2	4.8	1.5	
		OLMS*	7.29	18.05	11.56	49.17	-	7.78	-	
Total 25										

Nandita
I/C Water Lab

Dr. NANDITA MOITRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/39

/ 3069

St 5/3/21

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2021


1. Name & Address of Ind./Unit : Okhla STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.02.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	30	Inlet	7.55	312	136	568	16.0	38.4	16.6	Meeting the Standards.
		Outlet	7.58	8	6	28	0.4	3.6	1.2	
		OLMS*	7.13	7.56	5.34	28.71	-	1.95	-	
Total 30										

Nmitra

I/C Water Lab

Dr. NANDITA MOITRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/28/3063


At 5/3/21

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2021

1. Name & Address of Ind./Unit : DELHI GATE STP (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.02.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	Phase-I,II(2.2)	Inlet	6.88	96	56	184	20.0	35.4	6.2	Meeting the Standards.
		Outlet	6.82	9	7	16	1.6	2.5	0.6	
		OLMS*	8.07	7.35	3.98	19.73	-	1.85	-	
Total 2.2										

N Mehta
I/C Water Lab
Dr. NANDITA MOITRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/27

3062


Dr 5/3/21

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2021

1. Name & Address of Ind./Unit : Delhi Gate STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.02.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
						COD (mg/l)				
				10	10	50	10	5	2	
1	Phase-I,II(15)	Inlet	7.15	172	106	236	18.4	49.2	5.5	Meeting the Standards
		Outlet	7.09	8	5	26	0.8	2.6	1	
		OLMS*	7.25	6.23	6.79	32.28	-	0.66	-	
Total 15						Total 15				

N Mehta
Dr. NANDITA MOHITA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/30

3061

5/3/21

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2021

1. Name & Address of Ind./Unit : SEN Nursing Home (SNH)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.02.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	Phase-I,II (2.2)	Inlet	7.30	244	124	472	22.4	48.8	9.8	Meeting the Standards
		Outlet	6.98	8	5	28	0.8	5.0	1.6	
		OLMS*	-	-	-	-	-	-	-	
Total 2.2										

Remarks: OLMS was found non-operational at the time of DPCC Monitoring

N. Mittal
Dr. N.C. Water Lab
Dr. NANOITA MOHTRA
Scientist 'C'