



DELHI POLLUTION CONTROL COMMITTEE
WATER LABORATORY
4thFLOOR, ISBT BUILDING, KASHMERE GATE, DELHI-06
visit us at : <http://dpcc.delhigovt.nic.in>

WASTE WATER QUALITY STATUS OF DRAIN

REPORT NO: DPCC/W/D/2025/28-54/1855/16-05-2025

Date of Sampling: - 1/05/2025

S.No.	Sampling location	pH	TSS (mg/l)	COD (mg/l)	BOD (mg/l)
	Standards	5.5- 9.0	100	250	30
1.	Najafgarh Drain	7.2	152	241	72
2.	Metcalf House Drain	NO FLOW			
3.	Khyber Pass Drain				
4.	Sweeper Colony Drain				
5.	Magazine Road Drain				
6.	ISBT Drain	7.0	116	283	84
7.	Tonga Stand Drain	NO FLOW			
8.	Civil Mill Drain				
9.	SEN Nursing Home Drain	7.0	420	489	150
10.	Drain No. 14	NO FLOW			
11.	Power House Drain	6.9	148	404	130
12.	Indrapuri Drain	7.7	156	256	90
13.	Sonia Vihar Drain	7.2	436	178	65
14.	Kailash Nagar Drain	NO FLOW			
15.	Shastri Park Drain				
16.	Barapulla Drain	6.9	94	264	86
17.	Maharani Bagh Drain	7.3	312	445	150
18.	Old Agra Canal Drain	NO FLOW			
19.	Jaitpur Drain	7.2	144	264	102
20.	Sarita Vihar Pool	7.0	40	136	42
21.	Tuglakabad Drain	7.2	66	256	68
22.	Drain Near LPG Bottling Plant	NO FLOW			
23.	Drain Near Sarita Vihar Bridge (Mathura Road)	6.8	120	256	80
24.	Shahdara Drain	7.0	188	279	110
25.	Sahibabad Drain	7.8	336	543	185
26.	Molarband Drain	TAPPED			
27.	Abul Fazal Drain	7	196	339	104

Shweta
I/C WATER LAB
Dr. Shweta Gupta
Incharge (Water Laboratory)

[Signature]
SSA/Analyst