



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/31/1887

Dated 02-06-2025

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2025

1. Name of STP : Delhi Gate (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 06.05.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Ph-I & II (2.2)	Inlet	7.1	124	120	280	30	2.3	8.9		Meeting the standards.
		Outlet	7.2	9	8	32	1.6	0.3	0.6	130	
		OLMS	7.75	4.55	4.19	19.07	-	1.72	-	-	
Total 2.2											

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)




Report Number: DPCC/W/STP/25-26/32/1888

Dated 02-06-25

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY 2025

1. Name of STP : Delhi Gate (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 06.05.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Phase-I & II (15)	Inlet	6.9	72	50	180	9.2	2.5	9.7		Meeting the standards.
		Outlet	7	7	4	24	0.8	0.8	0.8	190	
		OLMS	7.13	6.55	2.247	22.2	-	4.07	—	—	
Total 15											


I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)


SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/33/1889

Dated 02-06-25

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2025

1. Name of STP : SEN Nursing Home (SNH)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 06.05.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results:

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Phase-I,II (2.2)	Inlet	7.3	228	180	416	9.2	10.3	4.1		Meeting the Standards.
		Outlet	7.2	7	8	36	0.8	0.6	0.8	95	
		OLMS	6.98	5.99	4.08	22.24	-	2.14	-	-	
Total 2.2											

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/34/ 1890

Dated 02-06-25

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2025

1. Name of STP : Akshardham
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 06.05.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonica INitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	1	Inlet	7.1	80	60	188	15.2	13.3	3.3		Meeting the Standards.
		Outlet	7.4	5	4	28	0.4	0.5	0.6	110	
		OLMS	7.53	0.9	1.93	7.55	-	0.42	-	-	
Total 1											

Shweta
I/C Water Laboratory
Incharge (Water Laboratory)

[Signature]
SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/35/1891

Dated 02-06-25

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2025

1. Name of STP : Chilla
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 06.05.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results:

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	9	Inlet	6.8	128	100	316	33.6	9.5	4.5		Meeting the Standards.
		Outlet	7.6	7	8	36	1.2	0.7	1.1	170	
		OLMS	7.39	8.40	33.60	5.60	-	5.42	-	-	
Total 9											

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/36/1892

Dated: 02-06-25

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2025

1. Name of STP : Rithala
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 06.05.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Ph-I(40)	Inlet	7.8	102	110	232	32	8.2	7.9	-	Meeting the standards
		Outlet	6.9	9	8	44	1.2	0.4	0.6	80	
		OLMS	7.41	8.62	6.90	31.61	-	2.01	-	-	
2	Ph-II(40)	Inlet	7.3	184	100	376	33.6	6.8	9.7	-	Meeting the standards
		Outlet	7.6	6	5	24	2	0.5	0.3	170	
		OLMS	7.49	7.96	7.04	34.27	-	3.06	-	-	
Total 80											

Shweta
I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

[Signature]
SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number DPCC/W/STP/25-26/37/1893

Dated 02-06-25

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2025

1. Name of STP : Rohini
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 06.05.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	15	Inlet	7.5	100	140	340	47.2	11.7	9.3	-	Meeting the standards.
		Outlet	7.1	7	5	32	1.2	0.8	0.8	180	
		OLMS	7.63	8.43	11.12	52.82		2.54			
Total 15											

Shweta
I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/38/1894

Dated 02-06-25

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2025

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of sampling : 06.05.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Ph-I,II (20)	Inlet	6.9	126	150	400	12	9.6	3.6	-	Meeting the standards.
		Outlet	7.1	6	7	40	2.4	0.7	0.6	120	
		OLMS	7.73	7.22	5.12	24.68	-	2.06	-	-	
2	Ph-III (10)	Inlet	7.6	136	160	444	23.2	10.8	4.8		Meeting the standards.
		Outlet	7.8	7	6	28	1.6	0.4	0.5	210	
		OLMS	7.21	7.39	5.03	22.23	-	1.21	-	-	
Total 30											

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)




Report Number: DPCC/W/STP/25-26/39/1895

Dated 02-06-25

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2025

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of sampling : 06.05.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results :											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	70 MGD	Inlet	7.5	108	90	224	12.8	8.5	4	-	Meeting the standards.
		Outlet	7.3	6	8	24	0.8	0.6	0.4	79	
		OLMS	7.19	5.13	5.39	25.28	-	1.84	-	-	
Total 70											


I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)


SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)




Report Number: DPCC/W/STP/25-26/40/ 1896

Dated 02-06-25

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2025

1. Name of STP : Yamuna Vihar Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 07.05.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/ 100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	25	Inlet	7.7	636	220	540	11.2	3.2	4.5		Not meeting the Standards wrt TSS, BOD, COD & fecal coliform.
		Outlet	7.6	28	16	56	1.6	0.3	1.8	1100	
		OLMS	7.84	26.30	16.64	60..79	-	11.5	-	-	
Total 25											


I/C Water Laboratory
Incharge (Water Laboratory)


SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



LIFE
Lifestyle for
Environment

Report Number: DPCC/W/STP/25-26/41/1897

Dated 02-06-25

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY -2025

1. Name of STP : Yamuna Vihar Ph-I,II
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 07.05.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results:

5. Parameters analyzed and results:											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	10 Ph-1	Inlet	7.2	370	240	500	21.2	10.9	5.7		Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform
		Outlet	7.7	14	18	56	1.2	0.5	0.8	950	
		OLMS	7.48	22.90	13.10	44.06	-	23.55	-	-	
2	10 Ph-2	Inlet	7.9	290	140	384	16	12.0	6.8		Meeting the Standards.
		Outlet	7.5	7	8	48	1.6	1	1.4	170	
		OLMS	7.12	11.14	10.48	43.53	-	12.76	-	-	
Total 20											

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/42/1898

Dated 02-06-25

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2025

1. Name of STP : Keshopur STP (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 08.05.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	12	Inlet	7.4	130	140	328	17.6	10.2	7.6	-	Meeting the standards.
		Outlet	7.9	8	8	28	1.6	0.4	0.6	150	
		OLMS	7.14	21.42	14.28	65.54	-	4.42			
Total 12											

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/43/ 1899

Dated 02-06-25

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY -2025

1. Name of STP : Keshopur
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 08.05.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	40	Inlet	7.2	402	320	752	9.6	12.1	11.5	-	Meeting the standards.
		Outlet	7.6	9	7	32	1.6	0.9	0.9	190	
		OLMS	7.2	10.6	6.4	18	-	-	2.7	-	
2	20	Outlet	7.9	8	9	36	1.2	0.5	0.8	130	Meeting the standards.
		OLMS	-	-	-	-	-	-	-	-	OLMS was non functional
Total 60											

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/44/1900

Dated 02-06-25

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2025

1. Name of STP : Nilothi
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 08.05.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	40	Inlet	7.7	150	160	424	11.2	12.9	7.9		Not meeting the standards w.r.t. fecal coliform.
		Outlet	7.6	8	8	36	2	0.8	0.8	350	
		OLMS	7.88	14.40	8.99	67.22	-	3.02	-	-	
Total 40											

Shweta
I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

[Signature]
SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/45/1901

Dated 02-06-25

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2025

1. Name of STP : Nilothi New
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 08.05.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	20	Inlet	7.8	220	140	336	12	12.2	4.4		Meeting the standards.
		Outlet	7.2	6	8	32	2	0.7	0.9	180	
		OLMS	7.62	6.92	7.62	42.18	-	4.71	-	-	
Total 20											

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number DPCC/W/STP/25-26/46/1902

Dated 02-06-25

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2025

1. Name of STP : Najafgarh
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 09.05.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Fecal Coliform MPN/100ml	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)		
			6.5-9.0	10	10	50	10	5	2	230	
1	5	Inlet	7.1	232	160	408	20.4	9.5	7		Meeting the standards.
		Outlet	7.3	5	6	36	1.2	0.7	0.6	210	
		OLMS	7.67	7.20	6.40	29	-	3.16	-	-	
Total 5											

I/C Water Laboratory
Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)




Report Number: DPCC/W/STP/25-26/47/ 1903

Dated 02-06-25

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2025

1. Name of STP : Pappankalan Ph-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 09.05.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
	20	Inlet	7.4	100	120	404	15.2	8.3	5.6		Not meeting the Standard wrt Fecal Coliform.
Outlet		7.4	10	6	20	2.8	1.6	1	1600		
OLMS		7.67	5.53	4.22	25.52	-	1.42	-	-		
Total 20											


I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)


SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccmms.nic.in>)



Report Number: DPCC/W/STP/25-26/48/1904

Dated 02-06-25

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2025

1. Name of STP : Pappankalan (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 09.05.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	20	Inlet	7.4	100	120	404	15.2	8.3	5.6	-	Meeting the standards.
		Outlet	7.7	7	8	40	1.6	1.2	0.5	150	
		OLMS	7.63	12.26	8.31	58.25		1.77			
Total 20											

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)




Report Number: DPCC/W/STP/25-26/49/ 1905

Dated 02-06-25

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2025

1. Name of STP : Kondli New
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 14.05.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Ph-IV (45)	Inlet	7.6	158	220	516	24.8	12.5	5.7	-	Meeting the standards.
		Outlet	7.1	8	9	24	0.8	1.1	0.8	170	
		OLMS	7.55	14.5	19.8	48.1	-	4.4	-	-	
Total 45											


I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)


SSA/Analyst

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)


Report Number: DPCC/W/STP/25-26/50/1906


Dated 02-06-25

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2025

1. Name of STP : Kondli
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 14.05.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Ph-I (10)	Inlet	7.8	150	100	248	12	8.2	4.5		Meeting the standards.
		Outlet	7.3	9	8	36	0.8	0.7	0.5	150	
		OLMS	7.89	5.50	7.60	24.60	-	4.72	-	-	
2	Ph-II & III (25+10)	Outlet	7.6	9	10	32	1.2	1	0.7	210	Meeting the standards.
		OLMS	7.63	5.42	7.81	25.02	-	4.5	-	-	
Total 45											


I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)


SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)




Report Number: DPCC/W/STP/25-26/51/1907


Dated 02-06-25

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2025

1. Name of STP : Narela
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 15.05.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	10	Inlet	7.7	176	140	356	19.2	8.2	10.2		Meeting the standards.
		Outlet	7.3	10	8	36	1.6	0.8	0.9	140	
		OLMS	7.96	7.38	5.20	23.08	-	1.67	-	-	
Total 10											


I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)


SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/52/1908

Dated 02-06-25

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2025

1. Name of STP : Molarband (Mini STP)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 19.05.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results :											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	0.66	Inlet	7.5	140	120	336	10	7.4	12.1		Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.7	24	18	56	2.8	1.3	1.8	2400	
		OLMS	7.71	25.99	13.28	89.51	-	7.51	-	-	
Total 0.66											

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)




Report Number: DPCC/W/STP/25-26/53/1909


Dated 02-06-25

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2025

1. Name of STP : Okhla New
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 19.05.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	30	Inlet	7.3	282	120	308	13.2	8	19.8	-	Meeting the standards.
		Outlet	7.4	10	8	32	1.2	0.8	0.5	220	
		OLMS	7.69	6.53	4.76	24.16	-	1.88	-	-	
Total 30											


I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)


SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)




Report Number: DPCC/W/STP/25-26/54/1910


Dated 02-06-25

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2025

1. Name of STP : Okhla
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 19.05.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	124 MGD	Inlet	7.4	184	160	380	20	10.8	11.1	-	Meeting the Standards.
		Outlet	7.4	5	6	20	1.2	0.9	1	140	
		OLMS	-	-	-	-	-	-	-	-	OLMS was under maintenance.
Total 124											


I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)


SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/55/ 1911

Dated 02-06-25

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2025

1. Name of STP : Okhla
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 19.05.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
	16	Inlet	7.4	184	160	380	20	10.8	11.1		Meeting the Standards.
		Outlet	7.2	7	8	24	2	0.9	1.8	130	
		OLMS	-	-	-	-	-	-	-	-	OLMS was under maintenance.
Total 16											

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)




Report Number: DPCC/W/STP/25-26/56/1912


Dated 02-06-25

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2025

1. Name of STP : Kapasahera
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 20.05.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results:

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	5	Inlet	7.3	282	120	308	13.2	8	19.8	-	Meeting the standards.
		Outlet	7.4	10	8	20	1.2	0.8	0.5	220	
		OLMS	7.97	9.73	6.42	46.90	-	3.56	-	-	
Total 5											


I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)


SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/57/ 1413

Dated 02-06-25

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2025

1. Name of STP : Vasant Kunj
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 20.05.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/ 100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	2.2	Inlet	7.5	162	200	592	11.6	8.8	11.7	-	Not meeting the Standards w.r.t. TSS, BOD, COD & Fecal Coliform.
		Outlet	7.8	26	34	76	2	0.7	1.1	9200	
		OLMS	8	6.05	4.11	24.77	-	9.46	-		
2	3	Inlet	7.2	238	220	664	12	10.2	11.8		Not meeting the Standards w.r.t. TSS, BOD, COD & Fecal Coliform.
		Outlet	7.4	19	28	72	2.4	0.7	0.9	22000	
		OLMS	8.15	13.99	9.12	45.61		0.15	-		
Total 5.2											

Shweta Gupta
I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

[Signature]
SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)




Report Number: DPCC/W/STP/25-26/58/1914


Dated 02-06-25

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2025

1. Name of STP : Ghitorini
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 20.05.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	5	Inlet	7.5	172	200	436	19.2	12.3	11.2	-	Not meeting the Standards w.r.t. TSS, BOD, COD & Fecal Coliform.
		Outlet	7.1	50	22	80	1.6	1	1	23000	
		OLMS	7.47	23.87	13.98	54.56	-	20.95	-	-	
Total 5											


I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)


SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/59/ 1915

Dated 02-06-25

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2025

1. Name of STP : Mehrauli
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 20.05.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	15	Inlet	7.2	88	60	280	14.4	11.8	11.3	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.5	18	24	76	2.4	0.9	1.2	2600	
		OLMS	8.14	14.67	8.38	47.91	-	5.42	-	-	
Total 15											

I/C Water Laboratory
Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/60/ 1916

Dated 02-06-25

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2025

1. Name of STP : Sonia Vihar
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 21.05.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	7	Inlet	-	-	-	-	-	-	-	-	No Sampling was conducted due to no flow at the time of DPCC insepection.
		Outlet	-	-	-	-	-	-	-	-	
		OLMS	-	-	-	-	-	-	-	-	
Total 7											

1
I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

SSA/Analyst