



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



ANALYSIS REPORT OF BAWANA CETP (35 MLD) FOR THE MONTH OF NOVEMBER 2025

Report Number: DPCC/W/CETP/25-26/92/2443

Dated: 17-12-2025

1. Name & Address of Ind. / Unit : BAWANA CETP (35 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 04.11.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.8	5.5-9.0	7.1	6-9	7.35
2	TSS	326	600	40	100	28.41
3	COD	344	750	64	250	47.69
4	BOD (3 days at 27° C)	130	300	22	30	11.45
5	Oil & Grease	13.6	20.0	2.4	10.0	-
6	Ammonical Nitrogen as N	7.1	50	2.1	50	-
7	Sulphide	3.3	5.0	1.3	2.0	-
8	Phosphate	3.0	15.0	1.1	5.0	-

All values are in mg/l except pH

Flow: 29.15 MLD

I/C Water Laboratory

Scientist 'B'/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



ANALYSIS REPORT OF NARELA CETP (24 MLD) FOR THE MONTH OF NOVEMBER 2025

Report Number: DPCC/W/CETP/25-26/93/2444

Dated: 17-12-2025

1. Name & Address of Ind. / Unit : NARELA CETP (22.5 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 04.11.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.7	5.5-9.0	7.1	6-9	7.72
2	TSS	307	600	20	100	5.6
3	COD	344	750	36	250	29.5
4	BOD (3 days at 27° C)	120	300	12	30	5.3
5	Oil & Grease	10.4	20.0	3.2	10.0	-
6	Ammonical Nitrogen as N	6.5	50	3.2	50	-
7	Sulphide	3.9	5.0	1.1	2.0	-
8	Phosphate	4.0	15.0	1.2	5.0	-

All values are in mg/l except pH

Flow: 7.0114MLD

I/C Water Laboratory

Scientist B/Analyst



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



ANALYSIS REPORT OF GTK CETP (6 MLD) FOR THE MONTH OF NOVEMBER 2025

Report Number: DPCC/W/CETP/25-26/94/2445

Dated: 17/12/2025

1. Name & Address of Ind. / Unit : GTK CETP (6 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 04.11.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.7	5.5-9.0	7.2	6-9	OLMS was Non-functional
2	TSS	460	600	88	100	
3	COD	544	750	132	250	
4	BOD (3 days at 27° C)	210	300	28	30	
5	Oil & Grease	22.4	20.0	1.6	10.0	
6	Ammonical Nitrogen as N	7.2	50	1.1	50	
7	Sulphide	4.1	5.0	1.7	2.0	
8	Phosphate	3.9	15.0	0.4	5.0	

All values are in mg/l except pH
Flow: 1.721 MLD

I/C Water Laboratory

Scientist B/ Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



ANALYSIS REPORT OF WAZIRPUR CETP (24 MLD) FOR THE MONTH OF NOVEMBER 2025

Report Number: DPCC/W/CETP/25-26/95 / 244-6

Dated: 17/12/2025

1. Name & Address of Ind. / Unit : WAZIRPUR CETP (24 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 04.11.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.4	5.5-9.0	7.1	6-9	7.34
2	TSS	390	600	26	100	62
3	COD	616	750	76	250	121.1
4	BOD (3 days at 27° C)	250	300	25	30	19.1
5	Oil & Grease	17.6	20.0	2.0	10.0	-
6	Ammonical Nitrogen as N	6.1	50	3.4	50	-
7	Sulphide	3.9	5.0	1.4	2.0	-
8	Phosphate	4.2	15.0	0.8	5.0	-

All values are in mg/l except pH
Flow: 5.062 MLD

I/C Water Laboratory

Scientist 'B'/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



ANALYSIS REPORT OF SMA CETP (12 MLD) FOR THE MONTH OF NOVEMBER 2025

Report Number: DPCC/W/CETP/25-26/96/2447

Dated: 17/12/2025

1. Name & Address of Ind. / Unit : SMA CETP (12 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 04.11.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.8	5.5-9.0	7.3	6-9	7.31
2	TSS	404	600	64	100	43.54
3	COD	352	750	104	250	95.79
4	BOD (3 days at 27° C)	150	300	27	30	14.09
5	Oil & Grease	20	20.0	1.2	10.0	-
6	Ammonical Nitrogen as N	7.3	50	4.6	50	-
7	Sulphide	4.1	5.0	2.2	2.0	-
8	Phosphate	4.3	15.0	0.5	5.0	-

All values are in mg/l except pH
Flow: 2.428 MLD

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



ANALYSIS REPORT OF LAWRENCE ROAD CETP (12 MLD) FOR THE MONTH OF NOVEMBER 2025

Report Number: DPCC/W/CETP/25-26/97/ **2478**


Dated: **17/12/2025**

1. Name & Address of Ind. / Unit : **LAWRENCE ROAD (12 MLD)**
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 04.11.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.6	5.5-9.0	7.4	6-9	7.69
2	TSS	393	600	88	100	55.58
3	COD	520	750	136	250	72.94
4	BOD (3 days at 27° C)	240	300	30	30	19.15
5	Oil & Grease	14.4	20.0	5.2	10.0	-
6	Ammonical Nitrogen as N	6.5	50	3.2	50	-
7	Sulphide	3.2	5.0	1.2	2.0	-
8	Phosphate	3.9	15.0	0.4	5.0	-

All values are in mg/l except pH

Flow: 0.941 MLD


I/C Water Laboratory


Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



ANALYSIS REPORT OF OKHLA CETP (24 MLD) FOR THE MONTH OF NOVEMBER 2025

Report Number: DPCC/W/CETP/25-26/98/ **2449**

Dated: **17/12/2025**

1. Name & Address of Ind. / Unit : **OKHLA CETP (24 MLD)**
2. Sampling location : **Inlet and Outlet of CETP**
3. Date of Sampling : **06.11.2025**
4. Sample analyzed and results : **DPCC LAB**
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS*
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.8	5.5-9.0	7.3	6-9	8.05
2	TSS	256	600	48	100	27.15
3	COD	480	750	80	250	143.57
4	BOD (3 days at 27° C)	190	300	22	30	23.04
5	Oil & Grease	16.4	20.0	4.0	10.0	-
6	Ammonical Nitrogen as N	3.6	50	1.3	50	-
7	Sulphide	3.4	5.0	1.3	2.0	-
8	Phosphate	4.1	15.0	2.0	5.0	-

All values are in mg/l except pH
Flow: 2.146 MLD

I/C Water Laboratory

Scientist 'B'/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



LIFE
Lifestyle for
Environment

ANALYSIS REPORT OF NARAINA CETP (21.6 MLD) FOR THE MONTH OF NOVEMBER 2025


Report Number: DPCC/W/CETP/25-26/99/ **2450**

Dated: **17/12/2025**

1. Name & Address of Ind. / Unit : **NARAINA CETP (21.6 MLD)**
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 07.11.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.9	5.5-9.0	7.3	6-9	7.81
2	TSS	440	600	62	100	51.6
3	COD	392	750	88	250	92.2
4	BOD (3 days at 27° C)	160	300	20	30	19.4
5	Oil & Grease	18	20.0	3.6	10.0	-
6	Ammonical Nitrogen as N	9.2	50	1.3	50	-
7	Sulphide	4.2	5.0	2.4	2.0	-
8	Phosphate	3.7	15.0	1.1	5.0	-

All values are in mg/l except pH
FLOW: 4.86 MLD


I/C Water Laboratory


Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



ANALYSIS REPORT OF MAYAPURI CETP (12 MLD) FOR THE MONTH OF NOVEMBER 2025


Report Number: DPCC/W/CETP/25-26/100/ **2451**


Dated: **17/12/2025**

1. Name & Address of Ind. / Unit : MAYAPURI CETP (12 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 07.11.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.5	5.5-9.0	7.3	6-9	7.69
2	TSS	360	600	78	100	13.8
3	COD	424	750	68	250	56.3
4	BOD (3 days at 27° C)	190	300	18	30	10.4
5	Oil & Grease	16.8	20.0	3.2	10.0	-
6	Ammonical Nitrogen as N	6.5	50	2.9	50	-
7	Sulphide	2.8	5.0	1.1	2.0	-
8	Phosphate	4.9	15.0	1.2	5.0	-

All values are in mg/l except pH
Flow: 3.987 MLD


I/C Water Laboratory


Scientist B / Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



ANALYSIS REPORT OF NANGLOI CETP (12 MLD) FOR THE MONTH OF NOVEMBER 2025


Report Number: DPCC/W/CETP/25-26/101/2452

Dated: 17/12/2025

1. Name & Address of Ind. / Unit : NANGLOI CETP (12 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 10.11.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.8	5.5-9.0	7.4	6-9	8.18
2	TSS	233	600	76	100	30.2
3	COD	472	750	72	250	124.7
4	BOD (3 days at 27° C)	220	300	28	30	17.8
5	Oil & Grease	12.4	20.0	2.4	10.0	-
6	Ammonical Nitrogen as N	6.2	50	1.9	50	-
7	Sulphide	3.5	5.0	2.4	2.0	-
8	Phosphate	3.7	15.0	0.4	5.0	-

All values are in mg/l except pH
Flow: 3.108 MLD


I/C Water Laboratory


Scientist B/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



ANALYSIS REPORT OF MANGOLPURI CETP (2.4 MLD) FOR THE MONTH OF NOVEMBER 2025

Report Number: DPCC/W/CETP/25-26/102/ **2753**


Dated: **17/12/2025**

1. Name & Address of Ind. / Unit : **MANGOLPURI CETP (2.4 MLD)**
2. Sampling location : **Inlet and Outlet of CETP**
3. Date of Sampling : **10.11.2025**
4. Sample analyzed and results : **DPCC LAB**
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.3	5.5-9.0	7.2	6-9	1.85
2	TSS	380	600	48	100	6.30
3	COD	552	750	76	250	61.70
4	BOD (3 days at 27° C)	220	300	25	30	7.0
5	Oil & Grease	20.4	20.0	2.4	10.0	-
6	Ammonical Nitrogen as N	6.7	50	1.0	50	-
7	Sulphide	3.2	5.0	1.6	2.0	-
8	Phosphate	5.4	15.0	1.0	5.0	-

All values are in mg/l except pH

Flow: 1.010 MLD


I/C Water Laboratory


Scientist 'B'/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



ANALYSIS REPORT OF BADLI CETP (12 MLD) FOR THE MONTH OF NOVEMBER 2025

Report Number: DPCC/W/CETP/25-26/103/ 2454

Dated: 17/12/2025

1. Name & Address of Ind. / Unit : **BADLI CETP (12 MLD)**
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 17.11.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.6	5.5-9.0	7.3	6-9	8.52
2	TSS	340	600	52	100	20.1
3	COD	256	750	64	250	53.8
4	BOD (3 days at 27° C)	100	300	23	30	19.5
5	Oil & Grease	7.2	20.0	2.8	10.0	-
6	Ammonical Nitrogen as N	7.4	50	4.8	50	-
7	Sulphide	2.7	5.0	1.0	2.0	-
8	Phosphate	3.2	15.0	0.5	5.0	-

All values are in mg/l except pH

Flow: - 2.13MLD

I/C Water Laboratory

Scientist 'B'/Analyst

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)**ANALYSIS REPORT OF JHILMIL CETP (16.8 MLD) FOR THE MONTH OF NOVEMBER 2025**

Report Number: DPCC/W/CETP/25-26/109/ 2955



Dated: 17/12/2025

1. Name of CETP : **JHILMIL CETP (16.8 MLD)**
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 10.11.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.8	5.5-9.0	7.4	6-9	7.11
2	TSS	407	600	86	100	49.69
3	COD	632	750	116	250	127.19
4	BOD (3 days at 27° C)	240	300	30	30	16.69
5	Oil & Grease	18.4	20.0	3.2	10.0	-
6	Ammonical Nitrogen as N	6.5	50	3.4	50	-
7	Sulphide	4.2	5.0	1.2	2.0	-
8	Phosphate	5.0	15.0	0.6	5.0	-

All values are in mg/l except pH

Flow: 3.178 MLD


I/C Water Laboratory
Scientist B/Analyst