



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi)
4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCCW/STP/19-20/08 | 1329

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER- 2019

10/12/19

1. Name & Address of Ind./Unit
Molarband mini STP
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
13.11.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Parameters										Remarks
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
2		Inlet	7.0	50	30	250	10	50	5	Meeting the Standards.
		Outlet	7.4	320	230	692	32.4	38.3	8.1	
		OLMS*	7.93	24	14	48	2.0	15.8	1.2	
1				44	26.02	67.30	-	-	-	
Total 2										

MM

I/C LABORATORY

Molara

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi)

4th Floor, I.S.B.-T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/182 | 1330

10/12/19
ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2019

- 1 Name & Address of Ind./Unit
Coronation Pillar STP
- 2 Sampling location
Inlet and Outlet of STP
- 3 Date of Inspection
6.11.2019
- 4 Samples collected by
DPCC Lab
- 5 Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	Parameters							Remarks
				TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
1	Ph-I,II(20)	Inlet	7.4	50	30	250	10	50	5		
				168	110	324	22.4	28.6	6.5		
		Outlet	7.8	28	20	64	0.8	9.8	0.6		
		OLMS*	7.98	20.14	14.46	50.30	-	-	-		
		Inlet	7.2	140	90	296	20.4	26.9	6.3		
Ph-III(10)	Outlet	7.6	52	44	124	4.8	21.6	3.2	Not meeting the standards w.r.t TSS and BOD.		
	OLMS*	8.31	43.36	35.17	105.91	-	-	-			
	Total 30										

MMisha

I/C LABORATORY

NMaha

S.R. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/183 | 1731

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER- 2019 10/12/19

1. Name & Address of Ind./Unit
DELHI GATE STP NEW
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
08.11.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	Parameters						Remarks
				TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	Phase-I,II(15)	Inlet	8.0	10	10	250	10	50	5	Meeting the Standards.
		Outlet	7.6	6	4	16	0.4	5.6	0.3	
		OLMS*	6.72	9.27	6.46	18.63	-	2.32	-	
		Total 15								

I/C LABORATORY

Neha

S.R. SCIENTIFIC ASSISTANT

[Signature]



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi)
4th Floor J.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/184

1332

10/12/19

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2019

1. Name & Address of Ind./Unit
Keshopur STP new
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
21.11.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	12	Inlet	7.5	30	20	250	10	50	5	Meeting the Standards.
		Outlet	7.4	8	4	360	28.0	34.9	6.9	
		OLMS*	7.05	3.60	2.68	16.01	-	-	3.4	
	Total 12									

Mishra
I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi)
4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhi.govt.nic.in>

Report Number : DPCC/W/STP/19-20/185 / 1323

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER- 2019

1. Name & Address of Ind./Unit Keshopur STP
2. Sampling location Inlet and Outlet of STP
3. Date of Inspection 21.11.19
4. Samples collected by DPCC Lab
5. Parameters analyzed and results

Parameters										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Remarks
1	40	Inlet	7.3	381	260	740	34.4	42.8	8.4	Not meeting the Standards w.r.t TSS and BOD .
		Outlet	6.9	76	48	136	4.0	19.2	2.2	
		OLMS*	-	-	-	-	-	-	-	
2	20	Inlet	7.3	381	260	740	34.4	42.8	8.4	Not meeting the Standards w.r.t BOD.
		Outlet	7.0	46	32	96	3.2	17.4	1.6	
		OLMS*	7.31	76.44	50.10	200.79	-	-	-	
	Total 60									

Remarks: OLMS (40 MGD) was found non operational.

Remarks: OLMS (40 MGD) was found non operational.

LC LABORATORY

Sr. Scientific Assistant



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/186 (1334)

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2019
4/12/19

1. Name & Address of Ind./Unit
Sen Nursing Home (SNH)
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
08.11.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	Phase-I, II(2.2)	Inlet	7.9	10 240	10 190	250 428	10 20.8	50 27.6	5 6.3	Meeting the Standards.
		Outlet	7.6	6	4	12	0.8	6.6	1.3	
		OLMS*	7.05	5.51	6.9	18.5	-	1.27	-	
		Total 2.2								

U/C LABORATORY

Mukherjee

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi)
4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/187 | 1235

16/12/19

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER- 2019

1. Name & Address of Ind./Unit
Nilothi STP-II
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
21.11.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	20	Inlet	7.2	10	10	250	10	50	5	Not meeting the Standards w.r.t TSS.
		Outlet	7.5	14	8	620	30.4	38.4	7.8	
		OLMS*	7.66	21.60	8.21	53.39	-	-	1.4	
		Total 20								

Mukherjee
I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)
4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/188 / 1336

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2019

19/12/19

1. Name & Address of Ind./Unit Nilothi STP
2. Sampling location Inlet and Outlet of STP
3. Date of Inspection 21.11.19
4. Samples collected by DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
	40	Inlet		10	10	250	10	50	5	STP was found non-operational at the time of DPCC monitoring.
1		Outlet								
		OLMS*								
	Total 40									

I/C LABORATORY

Mehar

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi)
4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/190 | 1238

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2019

10/12/19

1. Name & Address of Ind./Unit
Rithala STP
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
05.11.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	Parameters						Remarks
				TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	Phase-I(40)	Inlet	7.3	316	165	488	26.4	32.6	6.7	Not meeting the standards w.r.t to TSS and BOD.
		Outlet	7.6	86	54	164	4.8	20.4	2.6	
		OLMS*	7.34	78.3	27.52	129.20	-	-	-	
		Inlet	7.3	316	165	488	26.4	32.6	6.7	
2	Ph-II(40)	Outlet	7.7	26	18	56	1.2	14.6	1.0	Meeting the standards.
		OLMS*	6.9	17.55	12.93	63.84	-	-	-	
		Total 80								

I/C LABORATORY

Mishra

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.E.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhi.govt.nic.in>

Report Number : DPCC/W/STP/19-20/191

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER- 2019

10/12/19

1. Name & Address of Ind./Unit
Papankulam STP
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
14.11.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters					Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
1	20	Inlet	7.9	276	220	644	29.6	35.6	7.6	Meeting the Standards.	
		Outlet	7.5	22	12	40	2.4	12.3	1.4		
		OLMS#	7.70	33.80	29.27	97.67	-	-	-		
Total 20											

Mishra
I/C LABORATORY

SR. SCIENTIFIC ASSISTANT
[Signature]



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)
4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/192 | 24/

14/12/19

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2019

1. Name & Address of Ind./Unit
Pappankalan STP-II
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
14.11.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

		Parameters								Remarks
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	20	Inlet	7.8	156	95	284	26.4	31.9	7.6	Meeting the Standards.
		Outlet	7.6	6	4	12	0.4	6.8	0.3	
		OLMS*	7.44	46.68	37.65	108.28	-	-	-	
	Total 20									

I/C LABORATORY

Mudha

S.R. SCIENTIFIC ASSISTANT

[Signature]



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpec.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/193 | 1342

10/11/19

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2019

1. Name & Address of Ind./Unit
Rohini STP
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
05.11.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	Parameters							Remarks
				TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
1	15	Inlet	7.8	10	10	250	10	50	5	Not meeting the Standards w.r.t TSS and BOD.	
		Outlet	7.6	30	22	68	1.6	16.3	1.6		
		OLMS*	6.87	27.71	22.14	149.04	-	-	-		
		Total 15									

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/STP/19-20/194

13/12/19

12/12/19

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2019

1. Name & Address of Ind./Unit
Narela STP
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
07.11.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	10	Inlet	7.8	50	30	250	10	50	5	Meeting the Standards.
		Outlet	8.2	144	115	360	20.8	27.9	7.6	
		OLMS*	7.53	22	16	52	1.6	17.6	1.5	
	Total 10			114.10	37.55	144.44	-	3.89	-	

I/C LABORATORY

Mukherjee

SR. SCIENTIFIC ASSISTANT

[Signature]



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCCW/STP/19-20/195 / 1364

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER- 2019

10/12/19

1. Name & Address of Ind./Unit
Okhla STP New
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
13.11.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	PH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	30	Inlet	7.5	10	10	250	10	50	5	Meeting the Standards.
		Outlet	7.5	6	4	420	28.4	34.3	7.3	
		OLMS*	7.7	10.16	5.59	12	0.4	8.4	0.4	
	Total 30					46.40	-	-	-	

I/C LABORATORY

Mishra

S.R. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/196

1345

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER- 2019

20/12/19

1. Name & Address of Ind./Unit
Kondli STP
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
11.11.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	Parameters							Remarks
				TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
1	25	Inlet	7.2	10	10	250	10	50	5	Not meeting the Standards w.r.t TSS.	
		Outlet	8.0	14	10	624	30.4	36.4	7.4		
		OLMS*	7.90	20.32	12.04	40.80	-	-	0.8		
		Total 25									

I/C LABORATORY

Mehar

SR. SCIENTIFIC ASSISTANT

[Signature]



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi)
4th Floor, I.S.E.T. Building, Kashmere Gate, Delhi - 110005
Website : <http://www.dpcc.delhi.govt.nic.in>

Report Number : DPCC/W/STP/19-20/197

11/3/19

(21/12/19)

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2019

1. Name & Address of Ind./Unit
KONDLI STP New
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
11.11.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks								
			pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)									
1	45	Inlet	7.2	300	210	624	30.4	36.4	7.4	Meeting the Standards.								
											Outlet	8.0	10	6	20	0.4	7.1	0.6
		OLMS*	7.90	16.74	11.32	45.86	-	-	-									
Total 45																		

I/C LABORATORY

N. Mehta

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi)
4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/198 / 1347

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2019

18/12/19

1. Name & Address of Ind./Unit
Kapashera STP
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
22.11.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	PH 5.5-9.0	Parameters							Remarks
				TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
1	5	Inlet	7.1	172	120	320	16.4	28.8	5.9	Meeting the Standards.	
		Outlet	7.4	4	2	8	0.4	6.6	0.3		
		OLMS*	7.78	34.27	14.59	53.52	-	-	-		
		Total 5									

I/C LABORATORY *Murli*

SR. SCIENTIFIC ASSISTANT *[Signature]*



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.R.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhi.govt.nic.in>

Report Number : DPCC/W/STP/19-20/199

1348

10/12/19

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2019


1. Name & Address of Ind./Unit
Yamuna Vihar STP Ph-III
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
18.11.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	Parameters						Remarks
				TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	25	Inlet	7.3	356	260	680	32.8	42.0	8.7	Not meeting the Standards w.r.t TSS and BOD.
		Outlet	7.7	76	52	140	4.8	20.4	2.3	
		OLMS*	6.59	22.94	11.22	128.75	-	4.71	-	
		Total 25								

I/C LABORATORY

NMishra

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi)
4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhi.govt.nic.in>

Report Number : DPCC/W/STP/19-20/200 | 1349

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2019
10/12/19


1. Name & Address of Ind./Unit
Chilla STP
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
11.11.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters					Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)		
9		Inlet	8.0	148	90	280	24.4	28.6	7.3	Meeting the Standards.	
		Outlet	7.5	10	8	24	0.8	9.6	0.8		
		OLMS*	7.78	16.93	12.87	36.58	-	-	-		
Total 9											

I/C LABORATORY

Mukherjee

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhi.govt.nic.in>

Report Number : DPCC/W/STP/19-20/201

1352

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER- 2019

10/10/19

1. Name & Address of Ind./Unit
Akshardham STP
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
11.11.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results


Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	Parameters						Remarks
				TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	1	Inlet	7.2	10	10	250	10	50	5	Meeting the Standards.
		Outlet	7.0	4	2	640	32.4	38.8	7.8	
		OLMS*	7.98	0.92	1.3	8	0.4	7.9	0.3	
		Total 1					5.53			

I/C LABORATORY

Mukherjee

Sr. Scientific Assistant

2



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi)
4th Floor, I.S.E.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/202 | 1351

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2019

1. Name & Address of Ind./Unit
Mehrauli STP
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
22.11.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters					Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
15		Inlet	7.5	50	30	250	10	50	5	Meeting the Standards.	
		Outlet	7.9	224	185	540	28.4	36.0	6.6		
		OLMS*	7.59	14	8	24	1.2	12.2	1.0		
		OLMS*	7.59	45.49	27.03	90.12	-	-	-		
Total 15											

Almida

I/C LABORATORY

Sr. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi)
4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/203

1252

10/12/19

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER- 2019

1. Name & Address of Ind/Unit
Vasant Kunj STP
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
22.11.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	Parameters						Remarks
				TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	2.2	Inlet	7.5	50	30	250	10	50	5	Meeting the Standards
		Outlet	7.7	10	6	640	31.2	38.3	8.1	
		OLMS*	6.77	14.30	12.05	47.34	-	-	0.9	
	3	Inlet	7.4	148	110	332	24.4	32.6	6.9	Meeting the Standards
		Outlet	7.6	8	4	16	0.8	9.6	1.3	
		OLMS*	6.80	12.67	6.73	35.79	-	-	-	
	Total 5.2									

I/C LABORATORY

NMishra

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi)
4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/204

1353

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER- 2019

1 of 12/19

1. Name & Address of Ind./Unit
Yamuna Vihar STP
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
18.11.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	PH 5.5-9.0	Parameters							Remarks
				TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)		
1	10	Inlet	7.1	50	30	250	10	50	5	Meeting the Standards.	
		Outlet	7.1	280	230	692	33.6	38.4	8.0		
		OLMS*	7.12	10	6	20	1.6	7.9	0.8		
2	10	Inlet	7.2	316	245	728	36.4	40.6	8.6	Meeting the Standards.	
		Outlet	7.3	14	8	24	1.2	9.3	1.2		
		OLMS*	-	-	-	-	-	-	-		
Total 20											

Remarks: OLMS was found in non-operational condition

Mulha

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmir Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/205

135

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2019

10/12/19

1. Name & Address of Ind./Unit
Okha STP
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
13.11.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	Parameters						Remarks
				TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	12	Inlet	7.2	172	30	250	10	50	5	Meeting the Standards
		Outlet	7.5	24	16	44	1.6	9.6	0.8	
	16	OLMS	7.48	33.37	13.57	34.37	-	-	-	Meeting the Standards
		Outlet	7.7	20	12	40	2.0	11.2	0.9	
	37	OLMS	7.81	21.07	11.63	42.77	-	-	-	Meeting the Standards
		Outlet	7.8	20	14	48	2.0	10.3	0.8	
	45	OLMS	6.63	26.21	18.18	52.24	-	-	-	Meeting the Standards
		Outlet	7.7	26	18	56	2.4	14.3	1.1	
	Total 110	OLMS	7.47	38.71	19.96	80.70	-	-	-	Meeting the Standards

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



11356

10/12/19

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2019

- | | |
|------------------------------------|-------------------------|
| 1. Name & Address of Ind./Unit | DELHI GATE STP |
| 2. Sampling location | Inlet and Outlet of STP |
| 3. Date of Inspection | 08.11.19 |
| 4. Samples collected by | DPCC Lab |
| 5. Parameters analyzed and results | |

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
1	PhasC- I,II(2.2)	Inlet	7.9	10 132	10 95	250 284	10 18.4	50 25.3	5 5.7	
		Outlet	7.7	8	6	20	0.4	5.3	0.9	
		OLMS*	6.58	6.72	0.49	6.99	-	3.95	-	Meeting the Standards.
		Total 2.2								

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhi.govt.nic.in>

Report Number : DPCC/W/STP/19-20/206 / 12 SS

ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER- 2019

14/12/19

1. Name & Address of Ind./Unit
Oxidation pond STP
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
18.11.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

St. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	Parameters						Remarks
				TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
6		Inlet	-	50	30	250	10	50	5	Non- operational due to under rehabilitation.
		Outlet	-	-	-	-	-	-	-	
		OLMS*	-	-	-	-	-	-	-	
Total 6										

I/C LABORATORY
Mukherjee

S.R. SCIENTIFIC ASSISTANT