

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)

**ANALYSIS REPORT OF MANGOLPURI CETP (2.4 MLD) FOR THE MONTH OF OCTOBER 2025**

Report Number: DPCC/W/CETP/25-26/79/2278

Dated: 23/10/2025

1. Name & Address of Ind. / Unit : **MANGOLPURI CETP (2.4 MLD)**
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 01.10.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.6	5.5-9.0	7.1	6-9	7.27
2	TSS	247	600	52	100	2.6
3	COD	480	750	68	250	39.6
4	BOD (3 days at 27° C)	190	300	20	30	4.5
5	Oil & Grease	17.6	20.0	1.6	10.0	-
6	Ammonical Nitrogen as N	7.8	50	1.2	50	-
7	Sulphide	2.9	5.0	1.4	2.0	-
8	Phosphate	4.9	15.0	0.6	5.0	-

All values are in mg/l except pH

Flow: 0.8932 MLD

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

Scientist 'B'/Analyst

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)

**ANALYSIS REPORT OF JHILMIL CETP (16.8 MLD) FOR THE MONTH OF OCTOBER 2025**

Report Number: DPCC/W/CETP/25-26/80/2279

Dated: 23/10/2025

1. Name of CETP : **JHILMIL CETP (16.8 MLD)**
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 06.10.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.5	5.5-9.0	7.3	6-9	6.77
2	TSS	312	600	64	100	-
3	COD	656	750	112	250	126.78
4	BOD (3 days at 27° C)	270	300	32	30	16.64
5	Oil & Grease	20.8	20.0	5.2	10.0	-
6	Ammonical Nitrogen as N	6.9	50	3.2	50	-
7	Sulphide	4.7	5.0	1.6	2.0	-
8	Phosphate	5.5	15.0	1.0	5.0	-

All values are in mg/l except pH
Flow: 4.19 MLD

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

Scientist B/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



ANALYSIS REPORT OF WAZIRPUR CETP (24 MLD) FOR THE MONTH OF OCTOBER 2025

Report Number: DPCC/W/CETP/25-26/81/ 2280

Dated: 23/10/2025

1. Name & Address of Ind. / Unit : **WAZIRPUR CETP (24 MLD)**
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 08.10.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS*
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.5	5.5-9.0	7.2	6-9	7.55
2	TSS	460	600	46	100	70.6
3	COD	720	750	72	250	123.3
4	BOD (3 days at 27° C)	280	300	28	30	15.4
5	Oil & Grease	18.8	20.0	4.4	10.0	-
6	Ammonical Nitrogen as N	6.7	50	4.7	50	-
7	Sulphide	4.3	5.0	1.8	2.0	-
8	Phosphate	3.9	15.0	1.2	5.0	-

All values are in mg/l except pH
Flow: 5.66 MLD

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

Scientist 'B'/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



ANALYSIS REPORT OF LAWRENCE ROAD CETP (12 MLD) FOR THE MONTH OF OCTOBER 2025

Report Number: DPCC/W/CETP/25-26/82/ 2281

Dated: 23/10/2025

1. Name & Address of Ind. / Unit : LAWRENCE ROAD (12 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 09.10.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.8	5.5-9.0	7.3	6-9	7.24
2	TSS	430	600	92	100	195.63
3	COD	616	750	108	250	274.93
4	BOD (3 days at 27° C)	260	300	33	30	82.43
5	Oil & Grease	19.2	20.0	4.8	10.0	-
6	Ammonical Nitrogen as N	6.8	50	3.4	50	-
7	Sulphide	2.9	5.0	1.5	2.0	-
8	Phosphate	3.4	15.0	0.9	5.0	-

All values are in mg/l except pH

Flow: 1.425 MLD

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



ANALYSIS REPORT OF NANGLOI CETP (12 MLD) FOR THE MONTH OF OCTOBER 2025

Report Number: DPCC/W/CETP/25-26/83/ 2282

Dated: 23/10/2025

1. Name & Address of Ind. / Unit : **NANGLOI CETP (12 MLD)**
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 10.10.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.7	5.5-9.0	7.3	6-9	7.26
2	TSS	200	600	72	100	7.8
3	COD	584	750	64	250	47.8
4	BOD (3 days at 27° C)	250	300	20	30	7.3
5	Oil & Grease	9.6	20.0	2.0	10.0	-
6	Ammonical Nitrogen as N	6.8	50	2.4	50	-
7	Sulphide	3.0	5.0	1.5	2.0	-
8	Phosphate	3.3	15.0	1.3	5.0	-

All values are in mg/l except pH

Flow: 3.363 MLD

Shweta

I/C Water Laboratory

Dr. Shweta Gupta
(Incharge Water Laboratory)

[Signature]

Scientist B/Analyst

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)**ANALYSIS REPORT OF NARAINA CETP (21.6 MLD) FOR THE MONTH OF OCTOBER 2025**

Report Number: DPCC/W/CETP/25-26/84 / 2283

Dated: 23/10/2025

1. Name & Address of Ind. / Unit : **NARAINA CETP (21.6 MLD)**
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 10.10.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.5	5.5-9.0	7.2	6-9	7.21
2	TSS	320	600	54	100	25.6
3	COD	448	750	92	250	66.3
4	BOD (3 days at 27° C)	180	300	25	30	13.9
5	Oil & Grease	23.2	20.0	2.8	10.0	-
6	Ammonical Nitrogen as N	9.9	50	1.5	50	-
7	Sulphide	2.6	5.0	1.4	2.0	-
8	Phosphate	3.1	15.0	0.9	5.0	-

All values are in mg/l except pH

FLOW: 5.23 MLD

I/C Water Laboratory

Shweta
Dr. Shweta Gupta
 Incharge (Water Laboratory)

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



ANALYSIS REPORT OF MAYAPURI CETP (12 MLD) FOR THE MONTH OF OCTOBER 2025

Report Number: DPCC/W/CETP/25-26/85 / 2284

Dated: 23/10/2025

1. Name & Address of Ind. / Unit : MAYAPURI CETP (12 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 10.10.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.7	5.5-9.0	7.2	6-9	8.03
2	TSS	350	600	82	100	15
3	COD	496	750	72	250	51.7
4	BOD (3 days at 27° C)	220	300	26	30	9.5
5	Oil & Grease	12.8	20.0	3.2	10.0	-
6	Ammonical Nitrogen as N	6.8	50	3.3	50	-
7	Sulphide	2.5	5.0	1.4	2.0	-
8	Phosphate	4.4	15.0	0.6	5.0	-

All values are in mg/l except pH
Flow: 4.26 MLD

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



ANALYSIS REPORT OF NARELA CETP (24 MLD) FOR THE MONTH OF OCTOBER 2025

Report Number: DPCC/W/CETP/25-26/86/ 2285

Dated: 23/10/2025

1. Name & Address of Ind. / Unit : NARELA CETP (22.5 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 13.10.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.8	5.5-9.0	7.0	6-9	7.72
2	TSS	324	600	36	100	5
3	COD	360	750	32	250	27.7
4	BOD (3 days at 27° C)	150	300	13	30	5.1
5	Oil & Grease	15.2	20.0	1.2	10.0	-
6	Ammonical Nitrogen as N	6.9	50	3.4	50	-
7	Sulphide	4.2	5.0	1.3	2.0	-
8	Phosphate	3.3	15.0	0.8	5.0	-

All values are in mg/l except pH

Flow: 8.663 MLD

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

Scientist B/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



ANALYSIS REPORT OF BADLI CETP (12 MLD) FOR THE MONTH OF OCTOBER 2025

Report Number: DPCC/W/CETP/25-26/87/ 2286

Dated: 23/10/2025

1. Name & Address of Ind. / Unit
2. Sampling location
3. Date of Sampling
4. Sample analyzed and results
5. Parameters analyzed and result

BADLI CETP (12 MLD)
Inlet and Outlet of CETP
13.10.2025
DPCC LAB

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.5	5.5-9.0	7.2	6-9	8.54
2	TSS	240	600	48	100	10.5
3	COD	320	750	72	250	29.7
4	BOD (3 days at 27° C)	120	300	27	30	11
5	Oil & Grease	14.4	20.0	2.8	10.0	-
6	Ammonical Nitrogen as N	8.1	50	5.3	50	-
7	Sulphide	2.9	5.0	1.2	2.0	-
8	Phosphate	3.7	15.0	0.3	5.0	-

All values are in mg/l except pH

Flow: - 2.388 MLD

Shweta

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

[Signature]

Scientist 'B'/Analyst

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)**ANALYSIS REPORT OF SMA CETP (12 MLD) FOR THE MONTH OF OCTOBER 2025**

Report Number: DPCC/W/CETP/25-26/88/2287

Dated: 23/10/2025

1. Name & Address of Ind. / Unit : SMA CETP (12 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 13.10.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.9	5.5-9.0	7.4	6-9	7.37
2	TSS	372	600	38	100	43.50
3	COD	312	750	72	250	95.84
4	BOD (3 days at 27° C)	120	300	23	30	14.09
5	Oil & Grease	7.6	20.0	2.4	10.0	-
6	Ammonical Nitrogen as N	9.5	50	5.0	50	-
7	Sulphide	3.6	5.0	1.1	2.0	-
8	Phosphate	3.9	15.0	0.8	5.0	-

All values are in mg/l except pH

Flow: 2.299 MLD

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

Scientist B /Analyst

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)**ANALYSIS REPORT OF BAWANA CETP (35 MLD) FOR THE MONTH OF OCTOBER 2025**

Report Number: DPCC/W/CETP/25-26/89/2288

Dated: 23/10/2025

1. Name & Address of Ind. / Unit : **BAWANA CETP (35 MLD)**
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 13.10.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.5	5.5-9.0	7.2	6-9	7.70
2	TSS	212	600	42	100	25.10
3	COD	232	750	48	250	48.40
4	BOD (3 days at 27° C)	110	300	15	30	11.60
5	Oil & Grease	16.4	20.0	1.6	10.0	-
6	Ammonical Nitrogen as N	7.8	50	2.4	50	-
7	Sulphide	3.0	5.0	1.4	2.0	-
8	Phosphate	2.7	15.0	0.9	5.0	-

All values are in mg/l except pH

Flow: 35.381 MLD

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

Scientist 'B'/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



ANALYSIS REPORT OF OKHLA CETP (24 MLD) FOR THE MONTH OF OCTOBER 2025

Report Number: DPCC/W/CETP/25-26/90 / 2.289

Dated: 23/10/2025

1. Name & Address of Ind. / Unit : OKHLA CETP (24 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 14.10.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS*
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.6	5.5-9.0	7.1	6-9	8.39
2	TSS	196	600	42	100	29.46
3	COD	504	750	100	250	144.15
4	BOD (3 days at 27° C)	220	300	26	30	23.15
5	Oil & Grease	18.8	20.0	3.6	10.0	-
6	Ammonical Nitrogen as N	4.0	50	1.5	50	-
7	Sulphide	3.8	5.0	1.0	2.0	-
8	Phosphate	3.7	15.0	1.8	5.0	-

All values are in mg/l except pH
Flow: 16.8 MLD

Shweta

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

[Signature]

Scientist 'B'/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



ANALYSIS REPORT OF GTK CETP (6 MLD) FOR THE MONTH OF OCTOBER 2025

Report Number: DPCC/W/CETP/25-26/91/2290


Dated: 23/10/2025

1. Name & Address of Ind. / Unit : GTK CETP (6 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 16.10.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :


S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.6	5.5-9.0	7.1	6-9	OLMS was Non-functional
2	TSS	430	600	76	100	
3	COD	600	750	120	250	
4	BOD (3 days at 27° C)	240	300	38	30	
5	Oil & Grease	13.2	20.0	4.4	10.0	
6	Ammonical Nitrogen as N	8.0	50	1.4	50	
7	Sulphide	3.5	5.0	1.3	2.0	
8	Phosphate	4.4	15.0	1.1	5.0	

All values are in mg/l except pH

Flow: 1.94 MLD


I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)


Scientist B/ Analyst