



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



ANALYSIS REPORT OF BADLI CETP (12 MLD) FOR THE MONTH OF MAY-2025

Report Number: DPCC/W/CETP/25-26/14/1874

Dated: 30-05-2025

1. Name & Address of Ind. / Unit
2. Sampling location
3. Date of Sampling
4. Sample analyzed and results
5. Parameters analyzed and result

BADLI CETP (12 MLD)
Inlet and Outlet of CETP
06.05.2025
DPCC LAB

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.5	5.5-9.0	7.3	6-9	8.8
2	TSS	190	600	68	100	9.8
3	COD	424	750	132	250	42.1
4	BOD (3 days at 27° C)	180	300	34	30	8.8
5	Oil & Grease	24	20.0	5.3	10.0	-
6	Ammonical Nitrogen as N	13.1	50	6	50	-
7	Sulphide	2.8	5.0	1.5	2.0	-
8	Phosphate	1.2	15.0	0.5	5.0	-

All values are in mg/l except pH
Flow: - 2.41 MLD

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



ANALYSIS REPORT OF GTK CETP (6 MLD) FOR THE MONTH OF MAY-2025

Report Number: DPCC/W/CETP/25-26/15/1875

Dated: 30-05-2025

1. Name & Address of Ind. / Unit : GTK CETP (6 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 06.05.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.5	5.5-9.0	7.1	6-9	OLMS was Non-functional
2	TSS	444	600	86	100	
3	COD	528	750	152	250	
4	BOD (3 days at 27° C)	280	300	45	30	
5	Oil & Grease	18	20.0	3.6	10.0	
6	Ammonical Nitrogen as N	30.3	50	6.9	50	
7	Sulphide	4.2	5.0	1.5	2.0	
8	Phosphate	5.8	15.0	4	5.0	

All values are in mg/l except pH
Flow: 2.13 MLD

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



ANALYSIS REPORT OF WAZIRPUR CETP (24 MLD) FOR THE MONTH OF MAY-2025

Report Number: DPCC/W/CETP/25-26/16/1876

Dated: 30-05-2025

1. Name & Address of Ind. / Unit : WAZIRPUR CETP (24 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 06.05.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS*
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.6	5.5-9.0	7.3	6-9	8.3
2	TSS	380	600	30	100	18
3	COD	480	750	52	250	43.7
4	BOD (3 days at 27° C)	150	300	22.5	30	5
5	Oil & Grease	10.4	20.0	1.6	10.0	-
6	Ammonical Nitrogen as N	30.6	50	4.8	50	-
7	Sulphide	3.5	5.0	1.2	2.0	-
8	Phosphate	2.2	15.0	0.2	5.0	-

All values are in mg/l except pH

Flow: - 4.45 MLD

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



ANALYSIS REPORT OF LAWRENCE ROAD CETP (12 MLD) FOR THE MONTH OF MAY-2025


Report Number: DPCC/W/CETP/25-26/17/1877


Dated: 30-05-2025

1. Name & Address of Ind. / Unit : LAWRENCE ROAD (12 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 06.05.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS*
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.9	5.5-9.0	7.2	6-9	8.1
2	TSS	140	600	32	100	22.7
3	COD	296	750	76	250	79.1
4	BOD (3 days at 27° C)	110	300	26	30	28.4
5	Oil & Grease	26	20.0	5.2	10.0	-
6	Ammonical Nitrogen as N	13.6	50	1.5	50	-
7	Sulphide	2.9	5.0	1.1	2.0	-
8	Phosphate	3.4	15.0	0.3	5.0	-

All values are in mg/l except pH
Flow: 0.75 MLD


I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)


SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



ANALYSIS REPORT OF SMA CETP (12 MLD) FOR THE MONTH OF MAY-2025


Report Number: DPCC/W/CETP/25-26/18/1878

Dated: 30-05-2025


- | | | |
|-----------------------------------|---|--------------------------|
| 1. Name & Address of Ind. / Unit | : | SMA CETP (12 MLD) |
| 2. Sampling location | : | Inlet and Outlet of CETP |
| 3. Date of Sampling | : | 06.05.2025 |
| 4. Sample analyzed and results | : | DPCC LAB |
| 5. Parameters analyzed and result | : | |

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	Ph	6.5	5.5-9.0	7.3	6-9	7.4
2	TSS	164	600	28	100	14.8
3	COD	304	750	96	250	54.8
4	BOD (3 days at 27° C)	120	300	24	30	12.9
5	Oil & Grease	23.6	20.0	6.4	10.0	-
6	Ammonical Nitrogen as N	19.4	50	0.4	50	-
7	Sulphide	3.6	5.0	1.8	2.0	-
8	Phosphate	2.2	15.0	0.1	5.0	-

All values are in mg/l except pH
Flow: 0.76 MLD


I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)


SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



ANALYSIS REPORT OF JHILMIL CETP (16.8 MLD) FOR THE MONTH OF MAY-2025


Report Number: DPCC/W/CETP/25-26/19/1879

Dated: 30/05/2025


1. Name of CETP : JHILMIL CETP (16.8 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 07.05.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.7	5.5-9.0	7.5	6-9	7.21
2	TSS	260	600	56	100	49.60
3	COD	320	750	112	250	126.96
4	BOD (3 days at 27° C)	120	300	30	30	16.66
5	Oil & Grease	16.8	20.0	3.6	10.0	-
6	Ammonical Nitrogen as N	14.5	50	5.6	50	-
7	Sulphide	4.4	5.0	1.6	2.0	-
8	Phosphate	1.8	15.0	0.7	5.0	-

All values are in mg/l except pH
Flow: 2.29 MLD


I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)


SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



ANALYSIS REPORT OF NARAINA CETP (21.6 MLD) FOR THE MONTH OF MAY-2025


Report Number: DPCC/W/CETP/25-26/20/1880


Dated: 30/05/2025

1. Name & Address of Ind. / Unit : NARAINA CETP (21.6 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 09.05.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.7	5.5-9.0	7.1	6-9	7.03
2	TSS	124	600	54	100	20
3	COD	324	750	96	250	87.3
4	BOD (3 days at 27° C)	150	300	28	30	18.3
5	Oil & Grease	16	20.0	2.4	10.0	-
6	Ammonical Nitrogen as N	35.3	50	15.6	50	-
7	Sulphide	3.5	5.0	1.0	2.0	-
8	Phosphate	4	15.0	0.8	5.0	-

All values are in mg/l except pH
FLOW: 5.33 MLD


I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)


SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



ANALYSIS REPORT OF MAYAPURI CETP (12 MLD) FOR THE MONTH OF MAY-2025

Report Number: DPCC/W/CETP/25-26/21/ 188

Dated: 30/05/2025

1. Name & Address of Ind. / Unit : MAYAPURI CETP (12 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 09.05.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.6	5.5-9.0	7.1	6-9	7.5
2	TSS	104	600	23	100	51
3	COD	424	750	88	250	87
4	BOD (3 days at 27° C)	170	300	26	30	11.4
5	Oil & Grease	15.6	20.0	2.4	10.0	-
6	Ammonical Nitrogen as N	17	50	4.2	50	-
7	Sulphide	3.9	5.0	1.3	2.0	-
8	Phosphate	3.5	15.0	1.2	5.0	-

All values are in mg/l except pH
Flow: 3.73 MLD

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



ANALYSIS REPORT OF NARELA CETP (24 MLD) FOR THE MONTH OF MAY-2025

Report Number: DPCC/W/CETP/25-26/22/ 1882

Dated: 30/05/2025

1. Name & Address of Ind. / Unit : NARELA CETP (22.5 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 15.05.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.6	5.5-9.0	7.2	6-9	7.4
2	TSS	284	600	56	100	7.7
3	COD	384	750	116	250	30.4
4	BOD (3 days at 27° C)	125	300	33	30	5.6
5	Oil & Grease	17.2	20.0	4	10.0	-
6	Ammonical Nitrogen as N	10.3	50	1.8	50	-
7	Sulphide	2.6	5.0	1.5	2.0	-
8	Phosphate	2.7	15.0	0.7	5.0	-

All values are in mg/l except pH

Flow: 7.46 MLD

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

SSA/Analyst

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)

**ANALYSIS REPORT OF BAWANA CETP (35 MLD) FOR THE MONTH OF MAY-2025**Report Number: DPCC/W/CETP/25-26/23/ **1883**Dated: **30/05/2025**

1. Name & Address of Ind. / Unit : **BAWANA CETP (35 MLD)**
2. Sampling location : **Inlet and Outlet of CETP**
3. Date of Sampling : **15.05.2025**
4. Sample analyzed and results : **DPCC LAB**
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.7	5.5-9.0	7.4	6-9	7.2
2	TSS	270	600	34	100	18.9
3	COD	320	750	92	250	40
4	BOD (3 days at 27° C)	100	300	22	30	10
5	Oil & Grease	16.4	20.0	3.2	10.0	-
6	Ammonical Nitrogen as N	13.9	50	1.4	50	-
7	Sulphide	4.2	5.0	1.7	2.0	-
8	Phosphate	3.2	15.0	0.3	5.0	-

All values are in mg/l except pH
Flow: 30.69 MLD

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



ANALYSIS REPORT OF MANGOLPURI CETP (2.4 MLD) FOR THE MONTH OF MAY-2025

Report Number: DPCC/W/CETP/25-26/24/ 1884

Dated: 30/05/2025

1. Name & Address of Ind. / Unit
2. Sampling location
3. Date of Sampling
4. Sample analyzed and results
5. Parameters analyzed and result

MANGOLPURI CETP (2.4 MLD)

Inlet and Outlet of CETP

16.05.2025

DPCC LAB

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.8	5.5-9.0	7.2	6-9	6.9
2	TSS	260	600	35	100	10.5
3	COD	440	750	104	250	97
4	BOD (3 days at 27° C)	140	300	24	30	16.6
5	Oil & Grease	19.6	20.0	2.4	10.0	-
6	Ammonical Nitrogen as N	11.9	50	2.2	50	-
7	Sulphide	3.1	5.0	1.2	2.0	-
8	Phosphate	2.3	15.0	0.2	5.0	-

All values are in mg/l except pH

Flow: 1.47 MLD

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



ANALYSIS REPORT OF NANGLOI CETP (12 MLD) FOR THE MONTH OF MAY-2025

Report Number: DPCC/W/CETP/25-26/25/ 1885

Dated: 30/05/2025

1. Name & Address of Ind. / Unit : NANGLOI CETP (12 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 16.05.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.5	5.5-9.0	7.3	6-9	7.65
2	TSS	336	600	36	100	20.8
3	COD	560	750	88	250	51.3
4	BOD (3 days at 27° C)	200	300	24	30	10
5	Oil & Grease	22.4	20.0	3.2	10.0	-
6	Ammonical Nitrogen as N	8.6	50	2	50	-
7	Sulphide	4.6	5.0	1.2	2.0	-
8	Phosphate	2.8	15.0	0.6	5.0	-

All values are in mg/l except pH

Flow: 3.49 MLD

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

SSA/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



ANALYSIS REPORT OF OKHLA CETP (24 MLD) FOR THE MONTH OF MAY-2025

Report Number: DPCC/W/CETP/25-26/26/ 1886

Dated: 30/05/2025

1. Name & Address of Ind. / Unit : OKHLA CETP (24 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 19.05.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS*
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.5	5.5-9.0	7.1	6-9	7.36
2	TSS	185	600	32	100	42.7
3	COD	456	750	80	250	110.04
4	BOD (3 days at 27° C)	180	300	25	30	18.33
5	Oil & Grease	21.6	20.0	5.2	10.0	-
6	Ammonical Nitrogen as N	15.1	50	3.2	50	-
7	Sulphide	4.6	5.0	1.7	2.0	-
8	Phosphate	2.6	15.0	0.5	5.0	-

All values are in mg/l except pH

Flow: 2.026 MLD

I/C Water Laboratory

Dr. Shweta Gupta

Incharge (Water Laboratory)

SSA/Analyst