



DELHI POLLUTION CONTROL COMMITTEE
WATER LABORATORY
4thFLOOR, ISBT BUILDING, KASHMERE GATE, DELHI-06
visit us at : <http://dpcc.delhigovt.nic.in>


WASTE WATER QUALITY STATUS OF DRAIN


REPORT NO: DPCC/W/D/2025/1699

Date of Sampling: - 5/03/2025

Dated: 07/04/2025

S.No.	Sampling location	pH	TSS (mg/l)	COD (mg/l)	BOD (mg/l)
	Standards	5.5- 9.0	100	250	30
1.	Najafgarh Drain	7.3	118	267	96
2.	Metcalf House Drain	7.6	42	104	48
3.	Khyber Pass Drain	NO FLOW			
4.	Sweeper Colony Drain				
5.	Magazine Road Drain				
6.	ISBT Drain	7.3	88	173	54
7.	Tonga Stand Drain	NO FLOW			
8.	Civil Mill Drain				
9.	SEN Nursing Home Drain	7.4	134	327	124
10.	Drain No. 14	NO FLOW			
11.	Power House Drain	7.8	66	243	88
12.	Indrapuri Drain	7.4	84	223	72
13.	Sonia Vihar Drain	7.6	470	292	116
14.	Kailash Nagar Drain	7.5	54	173	52
15.	Shastri Park Drain	7.2	200	287	100
16.	Barapulla Drain	7.5	90	223	92
17.	Maharani Bagh Drain	7.5	210	262	108
18.	Old Agra Canal Drain	NO FLOW			
19.	Jaitpur Drain	7.3	150	332	120
20.	Sarita Vihar Pool	7.3	76	262	88
21.	Tuglakabad Drain	7.5	258	213	70
22.	Drain Near LPG Bottling Plant	NO FLOW			
23.	Drain Near Sarita Vihar Bridge (Mathura Road)				
24.	Shahdara Drain	7.9	172	342	112
25.	Sahibabad Drain	7.3	228	604	185
26.	Molarband Drain	NO FLOW			
27.	Abul Fazal Drain	7.7	31	267	92


I/C WATER LAB
Dr. Shweta Gupta
Incharge (Water Laboratory)


SSA/Analyst