



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccontrolsnctdelhi.in>)



Report Number: DPC/W/STP/23-24/239 | 589

Date: 31/01/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2024

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 08.01.2024
4. Samples collected by : DPC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results										
Sl. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
	70 MGD	Inlet	7.4	284	100	400	10.5	26.4	5.0	Meeting the standards.
		Outlet	7.1	8	6	36	2.8	1.2	1.4	
		Q.M.S	7.3	9.2	6.0	38.0	-	-	-	
Total 70										Ammonical Nitrogen readings not shown in Q.M.S

Signature
LABORATORY

Dr. Mandita Chandra
Secretary



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcclcms.nic.in>)



Report Number: DPCCL/MS/STP/23-24/240/590

Dated

31/01/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2024

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 08.01.2024
4. Samples collected by : DPCCLab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
1	Ph-II (20)	Inlet	7.6	316	135	416	10	0.2	17.1	16.6	Not meeting the standards wrt TSS, BOD & COD.
		Outlet	7.2	32	18	59	2	1.7	1.7		
		OLMS	7.4	12.7	7.2	43.2	-	5.9	-		
		Inlet	7.8	100	110	304	6	25.1	15.3		
		Outlet	7.6	24	13	52	2.4	1.8	1.5		
2	Ph-III (10)	OLMS	-	-	-	-	-	-	-	Not meeting the standards wrt TSS, BOD & COD.	
		Outlet	7.6	24	13	52	2.4	1.8	1.5		
Total 30											OLMS was non-functional

I/C LABORATORY

Dr. Nandita Mohita

Signature



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, JSBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocouncils.in>)



Report Number: DPCC/W/STP/23-24/241

Date: 31/01/24

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2024

1. Name of STP: Delhi Gate (New)
2. Sampling location: Inlet and Outlet of STP
3. Date of Inspection: 09.01.2024
4. Samples collected by: DPCC Lab
5. Parameters analyzed and results:

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	Phase- I, (11.15)	Inlet	7.4	144	155	144	4	15.6	9.2	Meeting the Standards.
		Outlet	7.5	10	5	36	2	2	1.1	
		OLWS	7.5	7.1	3.9	23.3	-	4.4	-	
Total: 15										

I/C LABORATORY

[Signature]

Dr. Mandita Mohtra

Senior Analyst



DELHI POLLUTION CONTROL COMMITTEE

Government of N.C.T. of Delhi 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccnctm.nic.in>)



Report Number: DPCC/WE/STP/23-24/242 / 502

Date: 31/01/24

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2024

1. Name of STP : Delhi Gate (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.01.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	Parameters								Remarks
		pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
P-1 & II (2.2)	STP Standard	6.5-9.0	10	10	50	10	5	2	Meeting the Standard.	
	Inlet	7.2	176	115	175	4.4	23.8	11.8		
	Outlet	7.2	10	8	45	2	2.5	1.7		
	DI MS	7.3	5.0	2.0	15.0	-	1.1	-		
	Total 2.2									

Meeting the Standard.

W/C LABORATORY

M. Mittal

Dr. Nandita Moitra

Secretary



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in/>)



Report Number: DPCC/W/STP/23-24/243 | 593

Dated: 31/01/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2024

1. Name of STP : Keshopur STP (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.01.2024
4. Samples collected by : DPCC Lab
5. Parameters analysed and results :

St. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved phosphate as P (mg/l)	
1	12	Inlet	7.1	254	165	415	17.6	2.3	20.8	Not Meeting the standards wrt TSS, BOD & COD.
		Outlet	7.3	22	15	64	1.2	1.2	1.5	
		QLPS	7.5	7.9	5.2	29.8	-	3.9	-	
Total 12										

I/C LABORATORY

Dr. Nandita Mohita
Scientist 'P'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccnctms.nic.in>)



Report Number: DPCC/GW/STP/23-24/244 | 594

Date: 31/01/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2024

1. Name of STP : SEN Nursing Home (SNH)
2. Sampling location : Inlet and Outlet of STP
3. Date of inspection : 09.01.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	Phase I, II (2.2)		6.5-9.0	10	10	50	10	5	2	Meeting the Standard
		Inlet	7.2	240	155	192	5.6	15.1	19.2	
		Outlet	7.7	6	6	28	2.4	1.5	2	
		Outlet	7.7	6.3	5.2	24.8	-	0.9	-	
Total 2.2										

I/C LABORATORY

Signature

Dr. Manjula Mishra
Senior STP



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/245 | 595

Dated 31/01/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2024

1. Name of STP : Nilothi New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.01.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	20	Inlet	7.2	216	130	300	13.6	11.8	10.5	Meeting the standards
		Outlet	7.6	8	6	28	3.2	1	1.2	
		Q.M.S	7.6	6.7	4.5	35.0	-	1.6	-	
Total 20										

W/C LABORATORY

M. Mohit

Dr. Namita Mohita
Secretary



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/246 / 596

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2024

Dated 31/01/2024

1. Name of STP: Nilothi
2. Sampling location: Inlet and Outlet of STP
3. Date of Inspection: 08.01.2024
4. Samples collected by: DPCC Lab
5. Parameters analyzed and results:

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	60	Inlet	7.2	244	105	304	17.2	29.2	26.8	Not meeting the standards wrt TSS, BOD & COD.
		Outlet	7.5	36	21	64	4.8	1.6	1.5	
		OLWS	7.5	24.5	17.2	104.1	-	15.3	-	
Total 40										

W/C LABORATORY

Signature

Dr. Namita Moura
Secretary



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110016

(Visit us at <http://www.dpcenmssdc.in>)



Report Number DPCG/W/STP/23-24/267 / 597

Dated 31/01/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2024

1. Name of STP : Najafgarh
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.01.2024
4. Samples collected by : DPC Lab
5. Parameters analysed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	3	6.5-9.0	10	10	50	10	5	2	Not meeting the standards wrt TSS, BOD and COD	
		Inlet	7.2	237	115	272	13.4	19.6		11.8
		Outlet	7.5	76	21	72	1.1	1.9		1.7
		OLMS	7.6	20.9	14.8	79.4	-	10.4		-
Total 5										

W/C LABORATORY

Signature

Dr. Nandita Mohita

Secretary



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, JSRT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccnctmctc.in>)



Report Number: DPCC/W/STP/23-24/248

598

Date: 31/01/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2024

1. Name of STP : Rithala
2. Sampling location : Inlet and Outlet of STP
3. Date of inspection : 04.01.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	Pre-1(60)	Inlet	6.5-9.0	10	10	50	10	5	2	Plant was under Rehabilitation
		Outlet	-	-	-	-	-	-	-	
		OLMS	-	-	-	-	-	-	-	
2	Pre-1(40)	Inlet	7.2	188	120	304	10	10.1	17.1	Meeting the standards
		Outlet	7.5	8	6	36	2.9	2.4	1.32	
		OLMS	7.4	8.2	5.9	19.2	-	5.0	-	
Total 80										

I/C LABORATORY

Dr. Namita Mohita



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th floor, ESRT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccnctm.nic.in>)



Report Number: DPCC/W/STP/23-24/249 | 599

Dated 31/01/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2024

1. Name of STP : Pappankalan (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.01.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sl. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	20	Inlet	7.2	180	85	272	16	25.1	25.8	Not meeting the Standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.2	22	18	60	3.2	2.6	2.3	
		OLMS	7.3	100.9	13.6	18.6	-	7.3	-	
		Total 20								

W/LABORATORY

Dr. Vandita Moura
Scientist D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccnctnms.nic.in>)



Report Number: DPCC/WS/123-24/150 / 600

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2024

Dated 31/01/2024

1. Name of STP Pappankalan Ph-II (New)
2. Sampling location Inlet and Outlet of STP
3. Date of Inspection 08.01.2024
4. Samples collected by DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
20		Inlet	7.2	180	35	272	15	25.1	25.8	Meeting the Standards.
		Outlet	7.1	5	5	32	1.4	1.2	1.3	
		Others	5.0	6.6	5.2	35.4	-	1.0	-	
Total 20										

I/C LABORATORY

Dr. Manjita Mohtra
Secretary



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccnmc.nct.ni>)



Report Number DPCC/W/STP/23-24/251 / 601

Date 31/01/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2024

1. Name of STP : Rohini
2. Sampling location : Inlet and Outlet of STP
3. Date of inspection : 04.01.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	15	Inlet	7.4	320	160	360	11.2	19.6	19.9	Not meeting the Standards wrt TSS, BOD & COD.
		Outlet	7.2	30	17	70	5.6	1.6	1.3	
		OMIS	7.2	19.7	14.2	88.5	-	12.5	-	
Total 15										

I/C LABORATORY

M. K. Sharma

Dr. Manisha Mohita

Secretary



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcclnms.nct.ni>)



Report Number: DPCCL/W/STP/23-24/252/602

Dated 31/01/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2024

1. Name of STP : Narela
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 04.01.2024
4. Samples collected by : DPCC Lab
5. Parameters analysed and results :

Sr. No	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	10	Inlet	6.5-9.0	10	10	50	10	5	2	Not meeting the standards w.r.t TSS, BOD & COD.
			7.3	172	60	128	6.4	15.1	10.5	
		Outlet	7.6	24	11	52	1.6	1.1	1.3	
		CLMS	6.9	8.5	4.1	36.8	-	7.7	-	
Total 10										

LABORATORY

Dr. Mandita Mohita

Scientist D



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, JSBT Building
Kashmere Gate, Delhi 110016
(Visit us at <https://www.dpccnctms.nic.in>)



Report Number: DPCC/M/STP/23-24/244 / 603

Date: 31/01/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2024

1. Name of STP : Okhla New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 05.01.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	30	Inlet	6.5-9.0	10	10	50	10	5	2	Meeting the Standards.
		Outlet	7.5	21.2	125	336	10	16.7	24.1	
		OLMS	7.2	8	5	36	1.6	1.5	1.4	
Total 30			6.7	5.7	3.6	23.4	-	0.7	-	

I/C LABORATORY

Dr. Vandita Mohita

Signature



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccl.com>)



Report Number: DPCCL/W/STP/23-24/254 / 604

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2024

Dated 31/01/24

1. Name of STP: Kondli
2. Sampling location: Inlet and Outlet of STP
3. Date of Inspection: 09.01.2024
4. Samples collected by: DPCCL Lab
5. Parameters analyzed and results:

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	PH-I (10)	Inlet	7.3	10	10	50	10	5	2	Meeting the standards.
		Outlet	7.5	6	5	32	1.2	2.4	1.2	
		OLMS	6.3	5.5	3.6	20.6	-	3.8	-	
2	PH-II (25)	Outlet	7.6	6	3	20.6	0.8	1.1	1	Meeting the standards.
		OLMS	-	-	-	-	-	-	-	
3	PH-III (10)	Outlet	7.2	10	6	24	3.6	1.6	1.5	OLMS was non-functional. Meeting the standards.
		OLMS	7.5	8.4	6.0	40.9	-	NH	-	
Total 45										

Dr. Nandita Mohita



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, JSBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccnctnms.nct.ni>)



Report Number: DPCC/W/STP/23-24/255

1605

Date:

31/01/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2024

1. Name of STP : Kondli New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.01.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	10.14 (45)		6.5-9.0	10	10	50	10	5	2	Not Meeting the Standards wrt TSS, BOD & COD.
		Inlet	7.5	202	165	192	5.5	17.5	22.8	
		Outlet	7.6	25	14	76	1.2	1.2	1.5	
		OLPS	-	-	-	-	-	-	-	
Total 45										OLMS was non-functional

I/C LABORATORY
Dr. Nandita Mohita
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi 4th & 5th Floor, JSBI Building)

Kashmere Gate, Delhi 110016

(Visit us at <https://www.dpccnctms.nic.in>)



Report Number: DPCC/W/STP/23-24/256

606

Dated

31/01/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2024

1. Name of STP : Kapasahera
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 04.01.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	Parameters								Remarks
		STP Standard	pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	5	Inlet	7.2	248	84	289	4.4	22.5	10.6	Meeting the standards -
		Outlet	7.5	10	8	48	2	2.9	1.6	
		OLEs	7.5	9.7	6.2	25.6	-	2.7	-	
Total 5										

Signature

J/C LABORATORY

Dr. Mandita Mohita

Signature ID



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 40 & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomcans.nct.ni>)



Report Number DPCC/W/STP/23-24/257/607

Date: 31/01/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2024

1. Name of STP : Yamuna Vihar Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 05.01.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sl. No.	Installed Capacity (MGD)	Parameters								Remarks
		pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
1	25	STP Standard	6.5-9.0	10	10	50	10	5	2	Not meeting the Standards wrt TSS & BOD.
		Inlet	7.2	208	110	72	4	16.5	27.6	
		Outlet	7.8	28	15	40	1.6	1.3	1.5	
		OU-15	7.4	22.2	13.8	54.2	-	15.16	-	
Total: 25										

Not meeting the Standards w.r.t TSS & BOD.

Signature
10/1/2024

Dr. Mandita Mohita
Secretary, DP



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcnctmss.nic.in>)



Report Number: DPCQ/W/STP/23-24/258 /668

Dated: 31/01/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2024

1. Name of STP: Chilla
2. Sampling location: Inlet and Outlet of STP
3. Date of inspection: 09.01.2024
4. Samples collected by: DPCCLab
5. Parameters analyzed and results:

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	9	Inlet	7.3	200	66	144	5.2	20.8	11.4	Meeting the Standards.
		Outlet	7.5	8	6	40	2	1.2	1.4	
		0.25	7.3	6.2	4.6	24.4	-	1.5	-	
Total 9										

W/CLABORATORY

Dr. Nandita Mishra

Senior IGT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, JSBI Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/259 | 609

Date: 31/01/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2024

1. Name of STP : Akshardham
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.01.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	1	Inlet	7.3	200	105	240	5.2	20.9	13.5	Meeting the Standards.
		Outlet	7.7	8	6	32	0.8	1.2	1.4	
		GLMS	7.6	0.7	1.3	5.7	-	0.1	-	
Total 1										

I/C LABORATORY

N. Mishra

Dr. Nandita Mishra
Scientist-III



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, JSRT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccenmns.nic.in>)



Report Number: DPCC/W/STP/23-24/260 / 610

Date: 31/01/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2024

1. Name of STP : Mehrauli
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 04.01.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	15	Inlet	8.3	112	90	240	7.6	10.1	20.1	Not meeting the standards wrt TSS, BOD & COD.
		Outlet	7.5	28	20	64	1.2	1.2	1.1	
		OLMS	7.5	22.9	4.5	30.1	-	6.9	-	
Total : 5										

VC LABORATORY

Dr. Mansita Mishra

Secretary



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpecomms.nic.in>)



Report Number: DPEC/W/ST/23-24/251

611

Date: 31/01/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2024

1. Name of STP: Vasant Kunj
2. Sampling location: Inlet and Outlet of STP
3. Date of inspection: 04.01.2024
4. Samples collected by: DPEC Lab
5. Parameters analyzed and results:

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	2.2	Inlet	7.5	204	170	400	17.2	17.5	23.5	Not meeting the standards wrt TSS, BOD, COD & dissolved phosphate.
		Outlet	7.3	24	19	64	2.4	1.7	2.7	
		OLMS	6.5	6.5	4.8	26.1		2.0		
2	3	Inlet	7.2	280	155	320	3.6	16.9	27.8	Not meeting the standards wrt TSS, BOD .
		Outlet	7.6	30	22	48	1.2	1.8	1.7	
		OLMS	-	-	-	-	-	-	-	
Total S.O.										OLMS was non functional

Signature

Dr. Mandita Mohita
Secretary



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, JSRT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccommittee.nct.ni>)



Report Number: DPCC/MS/STP/23-24/262 / 612

Dated: 31/01/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2024

1. Name of STP : Yamuna Vihar
2. Sampling location : Inlet and Outlet of STP
3. Date of inspection : 05.01.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters										Remarks
Sr. No.	Installed Capacity (MCD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	10 P-1		6.5-9.0	10	10	50	10	5	2	Not meeting the standards w.r.t TSS.
		Inlet	7.3	136	85	72	1.2	13.6	23.5	
		Outlet	7.5	38	7	40	1.6	2.2	1.9	
		OLMS	7.4	-	5.7	31.6	-	15.5	-	
		Inlet	7.4	120	90	208	6.4	12.6	17.3	
2	10 P-2	Outlet	7.6	16	11	52	1.6	1.4	2.2	Not meeting the standard w.r.t TSS, BOD, COD & Dissolved Phosphate..
		OLMS	-	-	-	-	-	-	-	
Total 20										OLMS was Non functional



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccnctmss.in/dccn>)



Report Number: DPCC/7M/23/19/23-24/10 16/3

Dated: 8/10/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2024

1. Name of STP : Molarband (Mini STP)
2. Sampling location : Inlet and Outlet of STP
3. Date of inspection : 05.01.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters						Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	
1	0.66	Inlet	-	-	-	-	-	-	Sampling was not carried out due to no flow.
		Outlet	-	-	-	-	-	-	
		CLPS	-	-	-	-	-	-	
Total 0.66									

I/C LABORATORY

Nandita Mishra

Dr. Nandita Mishra
Scientist, Jr



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccnctnctn.in>)



Report Number: DPCC/W/STP/23-24/253/614

Date:

31/01/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2024

1. Name of STP: Okhla
2. Sampling location: Inlet and Outlet of STP
3. Date of Inspection: 05.01.2024
4. Samples collected by: DPCC Lab
5. Parameters analysed and results: -

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
12		Inlet	6.5-9.0	10	10	50	10	5	2	Not meeting the Standards wrt TSS, BOD & COD.
			7.5	266	160	412	16.8	16.2	18.6	
		Outlet	7.3	24	21	64	3.6	1.6	1.4	
		OLMS	6.9	34.8	15.2	71.9	-	15.6	-	
16		Outlet	7.1	10	8	32	2.9	1.2	1.8	Meeting the Standards.
		OLMS	6.9	5.7	3.9	16.2	-	2.2	-	
		Outlet	7.3	36	24	48	1.2	1.1	2.6	
		OLMS	6.8	16.6	10.3	49.9	-	6.1	-	
4.5		Outlet	7.1	34	26	44	2	1.6	1.6	Not meeting the Standards wrt TSS, BOD.
		OLMS	5.5	5.7	3.9	16.2	-	2.2	-	
Total 110										

I/C LABORATORY

Dr. Manojita Mondra

Scientist D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, JSRT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccnctus.nic.in>)



Report Number: DPCC/W/STP/23-24/264

1615

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2024

Dated: 31/01/2024

1. Name of STP: Keshopur
2. Sampling location: Inlet and Outlet of STP
3. Date of Inspection: 08.01.2024
4. Samples collected by: DPCC Lab
5. Parameters analyzed and results:

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	40		6.5-9.0	10	10	50	10	5	2	Not meeting the standards wrt TSS, BOD & COD.
		Inlet	6.5	236	140	412	16	22.4	20.3	
		Outlet	7.3	22	13	52	1.6	3.8	1.3	
		DLRS	5.2	76.0	50.0	232.0	-	5.1	-	
2	20	Outlet	7.5	34	20	75	2	1.6	1.1	Not meeting the Standards wrt TSS, BOD & COD.
		DLRS	-	-	-	-	-	-	-	
			-	-	-	-	-	-	-	
Total 60										DLRS was not functional

LABORATORY

Dr. Mandita Mishra

Signed by



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi: 4th & 5th Floor, ISBT Building)

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/WT/STP/23-24/205 16/6

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2024

Dated 31/01/2024

1. Name of STP : Ghitorini
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 04.01.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	5	Inlet	6.5-9.0	10	10	50	10	5	2	Not meeting the Standards wrt TSS & BOD.
		7.2	110	58	240	3.5	10.7	19.1		
		Outlet	7.5	24	13	48	1	1.3	1.3	
		GLMS	7.4	9.7	2.7	22.6	-	5.8	-	
Total 5										

I/C LABORATORY

M. K. Jha

Dr. Nandita Mishra

Scientist-IV