

DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/22-23/01/4755

Dated: 23/05/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2022


1. Name & Address of Ind./Unit : Molar band Mini STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.04.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	0.66	Inlet	7.4	220	112	418	22.4	20.20	16.6	Not meeting the Standards wrt TSS, COD & Dissolved Phosphate.
		Outlet	7.8	20	10	72	1.6	2.95	2.4	
		OLMS	7.5	16.03	12.32	67.44	-	2.16	-	
		% Variation	-3.84(D)	-19.85(D)	23.2(I)	-6.33(D)		-26.77		
Total 0.66										

I-Increase & D-Decrease

I-Increase & D-Decrease

Mishra
I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/02/4756

Date: 23/05/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2022

1. Name & Address of Ind./Unit : Delhi Gate STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.04.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	Phase-I,II(15)	Inlet	7.0	204	70	464	30.4	31.2	16.2	Meeting the Standards.
		Outlet	7.4	8	8	32	2.8	2.3	1.4	
		OLMS	7.1	9.08	6.07	42.81	-	4.06	-	
		% Variation	-4.22(D)	13.5(I)	-28.58(D)	33.78(I)		76.52(I)		
Total 15										
I-Increase & D-Decrease										

I-Increase & D-Decrease

M. Mita
I/C LABORATORY

Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/03/4757

Dated: 23/05/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2022


1. Name & Address of Ind./Unit : DELHI GATE STP (OLD)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.04.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	Phase-I,II(2.2)	Inlet	7.2	296	90	440	23.0	32.2	20.4	Meeting the Standards.
		Outlet	7.4	10	8	48	1.6	3.2	1.8	
		OLMS	6.2	10.10	5.83	37.73	-	3.0	-	
		% Variation	-16.21(D)	1(I)	-27.125(D)	-21.39(D)		-6.25(D)		
Total 2.2										

I-Increase & D-Decrease

I/C LABORATORY

Dr. Sandhya Mehta
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/05/4758

Dated : 23/05/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2022

1. Name & Address of Ind./Unit : SEN Nursing Home (SNH)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.04.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :


Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P(mg/l) 2	
1	Phase-I,II (2.2)	Inlet	7.4	252	90	24.4	21.2	31.28	16.2	Meeting the Standards
		Outlet	7.0	10	7	40	1.6	2.8	2.0	
		OLMS	7.8	8.01	6.01	26.02	-	3.35	-	
		% Variation	11.42(I)	-19.9(D)	-14.14(D)	-34.95(D)	-	19.64(I)	-	
Total 2.2										
I-Increase & D-Decrease										

I-Increase & D-Decrease

M. Mitra

U/C LABORATORY

Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/09/4759

Dated: 23/05/2022


ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2022

1. Name & Address of Ind./Unit : Rithala STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 12.04.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	Phase-I(40)	Inlet	-	-	-	-	-	-	-	Plant was under Rehabilitation
		Outlet	-	-	-	-	-	-	-	
		OLMS	-	-	-	-	-	-	-	
		% Variation	-	-	-	-	-	-	-	
2	Ph-II(40)	Inlet	7.5	120	92	240	32.4	32.2	12.40	Not meeting the standards wrt TSS, COD & Ammonical Nitorgen.
		Outlet	7.3	18	10	53.3	1.6	6.2	1.8	
		OLMS	7.5	8.35	9.71	45.45	-	3.61	-	
		% Variation	2.73(I)	-53.61(D)	-2.9(D)	-14.72(D)		-41.77(D)		
Total 80										

I-Increase & D-Decrease

Misha
I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/22-23/12/4760

Dated: 23/05/2022


ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2022

1. Name & Address of Ind./Unit : Rohini STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 12.04.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	15	Inlet	7.8	248	120	480	26.8	48.3	18.26	Not meeting the Standards wrt TSS, BOD, COD, & Dissolved Phosphate.
		Outlet	7.4	36	24	78	2.4	4.6	3.40	
		OLMS	7.8	27.80	17.94	73.43	-	6.35	-	
		% Variation	5.40(I)	-22.7(D)	-25.25(D)	-5.85(D)	-	38.04(I)	-	
Total 15										

I-Increase & D-Decrease

Mitra
I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/13/4761

Dated: 23/05/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2022

1. Name & Address of Ind./Unit : Narela STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 12.04.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	10	Inlet	7.8	112	90	440	4.4	40.20	18.20	Not Meeting the Standards w.r.t TSS, BOD, COD & Dissolved Phosphate
		Outlet	7.3	36	20	84	1.2	4.6	2.80	
		OLMS*	-	-	-	-	-	-	-	
		% Variation	-	-	-	-	-	-	-	
Total 10										

I-Increase & D-Decrease

Remarks: After calibration reading not shown in OLMS, hence calibration not done.

N. Mishra
I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/14/4762

Dated : 23/05/2022


ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2022

1. Name & Address of Ind./Unit : Okhla STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.04.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	30	Inlet	7.2	248	150	432	18.4	38.12	17.2	Meeting the Standards
		Outlet	7.3	10	8	48	1.2	3.52	1.48	
		OLMS	7.7	7.18	5.98	48.47	-	3.35	-	
		% Variation	5.47(I)	-28.2(D)	-25.25(D)	0.97(I)		-4.82(D)		
Total 30										

I-Increase & D-Decrease

N. Mitha
I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/15/4763

Dated : 23/05/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2022

1. Name & Address of Ind./Unit : Kondli STP
2. Sampling location : Inlet of STP
3. Date of Inspection : 11.04.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :


Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
				10	10	50	10	5	2	
1	25	Inlet*	7.4	280	180	480	16.4	48.2	52.3	Not meeting the Standards wrt TSS, BOD, COD, Ammonical Nitrogen & Dissolved Phosphate
Total 25										

*Remarks: Bypass effluent was being discharged into drain without treatment.

N. Mithra

I/C LABORATORY

Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/16/4764

Dated: 23/05/2022


ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2022

1. Name & Address of Ind./Unit : Kondli STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.04.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	45	Inlet	7.2	260	112	560	14.4	48.30	18.2	Not Meeting the Standards wrt TSS, BOD, COD, Ammonical Nitrogen. & Dissolved Phosphate.
		Outlet	7.0	84	48	208	5.2	15.12	4.30	
		OLMS*	-	-	-	-	-	-	-	
		% Variation	-	-	-	-	-	-	-	
Total 45										
*Remarks: OLMS was found non-functional at the time of DSSGAT.										

*Remarks: OLMS was found non-functional at the time of DPCC Monitoring.

Mitra
I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/17/4765

Dated : 23/05/2022


ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2022

1. Name & Address of Ind./Unit : Kapasahera STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.04.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	5	Inlet	7.4	332	280	496	3.6	43.60	18.2	Not Meeting the Standards wrt TSS, BOD & Ammonical Nitrogen
		Outlet	7.5	28	18	42.6	2.0	5.2	1.8	
		OLMS	7.1	23.62	17.01	56.70	-	4.23	-	
		% Variation	-5.33(D)	-15.64(D)	-5.5(D)	33.09(I)		-18.65(D)		
Total 5										

I-Increase & D-Decrease

Misha
I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/22-23/19/4766

Dated: 23/05/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2022


1. Name & Address of Ind./Unit : Chilla STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.04.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	9	Inlet	7.5	196	110	336	4.4	28.3	21.5	Not Meeting the Standards wrt TSS & BOD.
		Outlet	7.3	16	12	48	1.6	3.1	1.8	
		OLMS	7.2	5.17	5.73	46.56	-	3.20	-	
		% Variation	-1.36(D)	-67.68(D)	-52.25 (D)	-3(D)		3.22(I)		
Total 9										

I-Increase & D-Decrease

N. Mishra
I/C LABORATORY

Scientist



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/22-23/21/4767


Dated: 23/05/2022


ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2022

1. Name & Address of Ind./Unit : Mehrauli STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.04.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	15	Inlet	7.8	192	110	416	8.4	41.30	18.20	Not meeting the standards wrt TSS, BOD, COD, Ammonical Nitrogen & Dissolved Phosphate.
		Outlet	7.4	32	24	80	2.4	5.2	2.80	
		OLMS	7.5	8.66	11.08	59.09	-	4.32	-	
		% Variation	1.35(I)	-72.93(D)	-53.83(D)	-26.13(D)		-16.92(D)		
Total 15										
I-Increase & D-Decrease										

I-Increase & D-Decrease


I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/22/4768

Dated: 23/05/2022


ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2022

1. Name & Address of Ind./Unit : Vasant Kunj STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.04.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	2.2	Inlet	7.32	356	270	624	14.4	34.16	11.30	Not meeting the Standards wrt TSS & Ammonical Nitrogen
		Outlet	7.72	18	7	40	2.4	8.61	1.91	
		OLMS	6.8	61.14	14.90	21.52	-	2.38	-	
		% Variation	-11.91(D)	239.6(I)	112.85(I)	-46.2(D)	-	-72.35(D)	-	
2	3	Inlet	7.12	284	240	448	06	31.11	1.44	Not Meeting the Standards wrt TSS, BOD & COD
		Outlet	7.25	20	12	56	3.6	4.74	1.62	
		OLMS	7.9	6.03	3.16	25.82	-	5.22	-	
		% Variation	8.96(I)	-69.85(D)	-73.6(D)	-53.89(D)	-	10.12(I)	-	
Total 5.2										
I-Increase & D-Decrease										

I-Increase & D-Decrease

Nmita
I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/24/4769

Dated: 23/05/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2022

1. Name & Address of Ind./Unit : Okhla STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.04.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	12	Inlet	7.8	196	110	432	15.2	31.20	18.10	Not meeting the Standards wrt TSS, BOD & COD, Ammonical Nitrogen
		Outlet	7.6	18	12	64	5.2	6.20	1.40	
		OLMS*	-	-	-	-	-	-	-	
		% Variation	-	-	-	-	-	-	-	
	16	Outlet	7.3	30	22	104	1.2	3.90	2.8	Not meeting the Standards wrt TSS, BOD, COD & Dissolved Phosphate.
		OLMS	7.4	16.03	15.93	22.46	-	4.39	-	
		% Variation	1.3(I)	-46.56(D)	-27.59(D)	-78.40(D)		12.56(I)		
	37	Outlet	7.4	20	18	96	2.8	6.30	1.90	Not meeting the Standards wrt TSS, BOD, COD & Ammonical Nitrogen.
		OLMS*	-	-	-	-	-	-	-	
		% Variation	-	-	-	-	-	-	-	
	45	Outlet	7.2	28.0	20	96	1.6	4.2	1.20	Not meeting the Standards wrt TSS, BOD & COD.
		OLMS	7.3	43.65	14.55	69.84	-	3.74	-	
		% Variation	1.38(I)	55.89(I)	-27.25(D)	-27.25(D)		-10.95(D)		
Total 110										

*Remarks: OLMSs (12 & 37 MGD) was found non-operational at the time of BSCS Monitoring.

*Remarks: OLMSs (12 & 37 MGD) was found non-operational at the time of DPCC Monitoring.
I-Increase & D-Decrease

N. Mitta

I/C LABORATORY