

DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/226/4503

Dated: 23/12/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2021

1. Name & Address of Ind./Unit : Coronation Pillar STP
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 08.12.2021
4. Samples collected by : DPCC, Lab
5. Parameters analyzed and results :


Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	COD (mg/l)	10	5	2	
1	Ph-I,II(20)	Inlet	6.9	332	165	512	22	24.6	10.4	Not meeting the Standards w.r.t TSS, BOD, COD, A.N& DP.
		Outlet	7.4	36	21	80	2.4	6.8	3.1	
		OLMS*	-	-	-	-	-	-	-	
2	Ph-III(10)	Inlet	7.3	240	115	464	12.4	35.8	31.1	Not meeting the standards w.r.t. TSS, BOD, COD, A.N & DP.
		Outlet	7.5	40	27	96	3.2	8.2	3.6	
		OLMS*	7.5	88.27	46.29	181.85	-	8.14	-	
Total 30										

Remarks: Ph-I & II OLMS was stolen FIR has been filed as informed.

N. Mishra
I/C LABORATORY

SR. SCIENTIFIC ASSISTANT

Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/230/4507

Date: 23/12/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2021

1. Name & Address of Ind./Unit : SEN Nursing Home (SNH)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.12.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	Phase-I,II (2.2)	Inlet	7.6	244	95	320	18.2	30.2	15.4	Meeting the Standards.
		Outlet	7.1	8	5	32	0.6	1.6	1.4	
		OLMS*	7.4	6.87	3.26	20.28	-	0.98	-	
	Total 2.2									

N. Mithra
I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/231) 4588

Dated : 23/12/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2021

1. Name & Address of Ind./Unit : Nilothi STP-II
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.12.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				
				10	10	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
						50	10	5	2	
1	20	Inlet	6.9	176	100	304	15.2	17.2	13.3	Meeting the standards.
		Outlet	7.3	10	6	36	1.2	3.4	1.2	
		OLMS*	7.1	8.67	4.94	30.74	-	2.98	-	
Total 20										

N. Mishra
I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/232 / 4509

Dated: 23/12/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2021

1. Name & Address of Ind./Unit : Nilothi STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.12.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	40	Inlet	7.0	308	145	352	18.4	25.1	10.9	Not meeting the standards w.r.t to TSS, BOD & COD.
		Outlet	7.2	40	28	96	2	4.2	1.8	
		OLMS*	6.6	95.50	NA	NA	-	17.61	-	
Total 40										

N. Mittal
I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/21-22/233 / 4510

Dated : 23/12/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2021

1. Name & Address of Ind./Unit : Najafgarh STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.12.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

3. Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	5	Inlet	7.4	212	85	368	18	42.4	18.2	Not meeting the standards w.r.t to TSS, BOD, COD, & DP.
		Outlet	7.6	34	26	96	1.2	4.6	3.9	
		OLMS*	7.3	31.63	19.70	97.97	-	12.08	-	
Total 5										

M. Mitta
I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/234 | 4511

Dated : 23/12/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2021


1. Name & Address of Ind./Unit : Rithala STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.12.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	Phase-I(40)	Inlet	-	-	-	-	-	-	-	Plant was under Rehabilitation
		Outlet	-	-	-	-	-	-	-	
		OLMS*	-	-	-	-	-	-	-	
2	Ph-II(40)	Inlet	7.2	220	100	400	14.4	15.4	18.7	Meeting the standards
		Outlet	7.4	10	8	36	0.8	3.2	1.4	
		OLMS*	N/A	7.22	6.93	24.7	-	N/A	-	
Total 80										

Remarks: Ph-1 Plant was under Rehabilitation.

M. Mitta
I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/227/4504

Date: 23/12/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2021

1. Name & Address of Ind. /Unit : Delhi Gate STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.12.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	Phase-I,II(15)	Inlet	7.0	208	85	336	18.8	28.4	14.6	Meeting the Standards.
		Outlet	7.3	6	5	32	0.4	1.8	1	
		OLMS*	7.3	7.08	5.79	29.78	-	1	-	
Total 15										

N. Mitra
I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/228/4505

Date: 23/12/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2021

1. Name & Address of Ind./Unit: : Delhi Gate STP Old
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.12.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
						COD (mg/l)				
				10	10	50	10	5	2	
1	Phase-I,II(2.2)	Inlet	7.1	232	90	384	16	30.2	18.3	Meeting the Standards
		Outlet	7.2	8	6	37.3	0.8	1.4	1.8	
		OLMS*	6.9	6.91	4.23	21.96	-	0.6	--	
Total 2.2										

N. Mitra
I/C LABORATORY
Scientist 'C'

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/229/4506

Dated: 23/12/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2021


1. Name & Address of Ind./Unit : Keshopur STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 15.12.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	12	Inlet	6.9	188	85	272	14	30.3	12.6	Meeting the Standards.
		Outlet	7.2	10	10	37.3	1.6	3.8	1.6	
		OLMS*	7.2	8.27	4.57	24.64	-	3.56	-	
Total 12										

N. Mukherjee
I/C LABORATORY

SR. SCIENTIFIC ASSISTANT

Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/235/4512

Dated: 23/12/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2021

1. Name & Address of Ind./Unit : Pappankalan STP (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.12.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	20	Inlet	7.2	104	55	192	16	30.2	10.4	Not meeting theStandards w.r.t TSS, BOD & COD.
		Outlet	7.4	32	26	85.3	4	4	1.8	
		OLMS*	7.3	33.31	22.45	161.12	-	20.7	-	
Total 20										

N. Mitta
I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/236 / 4513

Date: 23/12/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2021

1. Name & Address of Ind./Unit : Pappankalan STP-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.12.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
	20	Inlet	6.8	124	85	240	15.2	28.3	8.2	Meeting the Standards.
		Outlet	7.0	8	6	32	1.2	3.8	1.4	
		OLMS*	6.7	5.70	3.75	23.83	-	0.86	-	
Total 20										

Mitika
I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/21-22/237/4514

Dated : 23/12/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2021

1. Name & Address of Ind./Unit : Rohini STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.12.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
						COD (mg/l)				
				10	10	50	10	5	2	
1	15	Inlet	7.4	312	145	448	18	34.5	31.1	Not meeting the Standards w.r.t TSS, BOD, COD A.N.&DP.
		Outlet	7.6	12	14	58.6	1.2	5.4	3.2	
		OLMS*	7.5	26.17	N/A	N/A	-	11.66	-	
Total 15										

N. Mitta
I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/238/4515

Date: 23/12/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2021


1. Name & Address of Ind./Unit : Narela STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.12.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonica Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
1	10	Inlet	7.1	232	90	304	16	26.4	12.3	Not Meeting the Standards w.r.t TSS, BOD&COD.
		Outlet	7.3	20	12	58.6	1.2	4.6	2	
		OLMS*	-	-	-	-	-	-	-	
		Total 10								

Remarks: OLMS was found non-operational at the time of DPCC Monitoring.

N. Mishra
I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/239 / 4516

Dated : 23/12/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2021

1. Name & Address of Ind./Unit : Okhla STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 07.12.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results :										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	AmmonicalNi trogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
1	30			10	10	50	10	5	2	Meeting the Standards.
		Inlet	7.0	220	110	336	15.2	16.9	22.7	
		Outlet	7.3	6	5	37.3	0.4	2.6	1.4	
		OLMS*	7.1	6.26	8.21	41.84	-	2.94	-	
Total 30										

Mita
I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/240/4517

Dated : 23/12/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2021

1. Name & Address of Ind./Unit : Kondli STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.12.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	25	Inlet	7.4	232	105	416	16.8	34.6	32.9	Not Meeting the Standards w.r.t TSS, BOD & COD.
		Outlet	7.3	20	14	64	1.2	3.2	1.6	
		OLMS*	7.1	23.16	12.89	67.44	-	4.37	-	
Total 25										

N. Mishra
I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/241/4518

Dated: 23/12/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2021


1. Name & Address of Ind./Unit : Kondli STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.12.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	45	Inlet	7.4	216	85	368	16	30.1	32.1	Not Meeting the Standards w.r.t TSS, BOD, COD, AN& DP.
		Outlet	7.2	44	38	117.3	3.2	5.84	3.4	
		OLMS*	-	-	-	-	-	-	-	
Total 45										

Remarks: OLMS was found locked.

N. Mitta
I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/242/4579

Dated: 23/12/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2021

1. Name & Address of Ind./Unit : Kapasahera STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.12.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Remarks
				10	10	50	10	5	2	
1	5	Inlet	7.0	100	85	304	4.4	25.1	10.8	Meeting the standards
		Outlet	7.3	10	8	32	0.8	4.2	1.2	
		OLMS*	7.1	5.85	3.54	30.31	-	2.68	-	
Total 5										

N. Mitta
I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/243/4520

Dated: 23/12/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2021


1. Name & Address of Ind./Unit : Yamuna Vihar STP Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.12.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	25	Inlet	7.4	320	155	400	22.4	25.4	28.6	Not meeting the Standards w.r.t TSS, BOD, COD & DP.
		Outlet	7.2	30	24	88	1.2	3.2	3	
		OLMS*	-	-	-	-	-	-	-	
Total 25										

Remarks: OLMS was found non-operational at the time of DPCC Monitoring.

N. Mitta
I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/244/4521

Dated : 23/12/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2021

1. Name & Address of Ind./Unit : Chilla STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.12.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	9	Inlet	7.4	172	96	304	22	17.7	20.5	Meeting the Standards.
		Outlet	7.1	10	6	32	0.8	2.8	1.2	
		OLMS*	7.1	7.7	5.01	25.09	-	1.61	-	
Total 9										

M. M. M. M.
I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/245 / 4522

Dated: 23/12/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2021

1. Name & Address of Ind./Unit : Akshardham STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.12.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	1	Inlet	7.5	168	75	256	18.8	34.5	19.3	Meeting the Standards.
		Outlet	7.2	4	2	26.6	0.6	0.6	1	
		OLMS*	7.5	0.38	0.67	7.01	-	0.27	-	
Total 1										

Mukta
I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/246/4523

Dated: 23/12/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2021

1. Name & Address of Ind./Unit : Mehrauli STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.12.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	15	Inlet	7.0	172	95	336	20	12.24	31.9	Not meeting the standards w.r.t TSS.
		Outlet	6.8	16	10	48	0.8	3.5	1.6	
		OLMS*	6.6	47.83	25.94	164.16	-	3.36	-	
Total 15										

Munira
I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/247/4524

Dated : 23/12/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2021

1. Name & Address of Ind./Unit : VasantKunj STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.12.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	2.2	Inlet	7.4	216	115	384	19.2	16	25.2	Not Meeting the Standards w.r.t TSS, BOD, COD & DP.
		Outlet	7.6	16	12	69.33	2.4	2.1	4.1	
		OLMS*	7.8	4.85	3.7	19.41	-	0.36	-	
2	3	Inlet	7.0	220	110	464	6.8	17.5	26.54	Not Meeting the Standards w.r.t TSS & COD.
		Outlet	6.8	12	8	64	1.2	3	2	
		OLMS*	6.5	6.38	3.07	26.45	-	3.57	-	
Total 5.2										

Mintia
I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/248 / 4525

Dated: 23/12/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2021


1. Name & Address of Ind./Unit : Yamuna Vihar STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.12.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	10 Ph-1	Inlet	7.5	180	85	336	13.3	28.9	32.3	Not meeting the standards w.r.t TSS, BOD & COD.
		Outlet	7.3	12	14	58.6	0.6	2.8	2	
		OLMS*	7.4	17.90	10.53	75.35	-	13.99	-	
2	10 Ph-2	Inlet	7.0	264	125	384	16	22.2	15.3	Not meeting the standard w.r.t TSS, BOD, COD & DP.
		Outlet	7.2	18	15	74.6	0.8	2.1	2.3	
		OLMS*	-	-	-	-	-	-	-	
Total 20										

Remarks: Ph-II OLMS was found non-operational at the time of DPCC Monitoring.

M. K. Mishra
I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/249/4526

Date: 23/12/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2021


1. Name & Address of Ind./Unit : Okhla STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 07.12.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	12	Inlet	7.0	184	95	304	19.2	27.8	31.4	Not meeting the Standards w.r.t TSS, BOD & COD.
		Outlet	7.3	26	17	80	2	4.1	1.2	
		OLMS	7.7	26.65	20.50	101.50	-	5.78	-	
	16	Outlet	7.2	16	13	69.3	2.4	4.2	1.4	Not meeting the Standards w.r.t TSS, BOD & COD.
		OLMS	7.1	19.60	11.59	46.85	-	5.80	-	
	37	Outlet	7.3	24	16	85.3	1.2	4	1.9	Not meeting the Standards w.r.t TSS, BOD & COD.
		OLMS	7.0	39.92	25.73	127.97	-	21.39	-	
	45	Outlet	7.4	28	20	96	1.6	4.3	1.5	Not meeting the Standards w.r.t TSS, BOD& COD.
		OLMS	-	-	-	-	-	-	-	
Total 110										

Remarks: 45 MGD OLMS was found non-operational at the time of DPCC Monitoring.

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/250/4527

Dated: 23/12/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2021

1. Name & Address of Ind./Unit : Keshopur STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 15.12.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	40	Inlet	6.8	204	95	432	15.2	11.6	17.9	Not meeting the Standards w.r.t TSS,BOD,COD, A.N & D.P.
		Outlet	7.8	58	40	152	2	6.6	4.8	
		OLMS*	8.1	74.28	58.73	197.28	-	6.87	-	
2	20	Inlet	6.8	204	95	432	15.2	11.6	17.9	Not meeting the Standards w.r.t TSS, BOD, COD, A.N & D.P.
		Outlet	7.0	62	46	136	3.6	7.1	8.2	
		OLMS*	6.4	76.36	61.76	181.03	-	16.96	-	
Total 60										

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/10/4528

Dated: 23/12/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2021

1. Name & Address of Ind./Unit : Molarband Mini STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 07.12.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	0.66	Inlet	7.3	268	90	368	22.4	22.2	16.6	Not meeting the Standards w.r.t TSS, BOD, COD & DP.
		Outlet	7.4	32	18	80	1.2	2.9	2.2	
		OLMS*	7.1	23	12.89	67.44	-	1.58	-	
Total 0.66										

Mitla
I/C LABORATORY

SR. SCIENTIFIC ASSISTANT