



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/132/973

Date - 9/10/19

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER- 2019

- 1 Name & Address of Ind./Unit
Coronation Pillar STP
- 2 Sampling location
Inlet and Outlet of STP
- 3 Date of Inspection
05-09-2019
- 4 Samples collected by
DPCC Lab
- 5 Parameters analyzed and results

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				50	30	250	10	50	5	
1	Ph-I,II(20)	Inlet	8.1	84	74	232	14.4	20.4	6.9	Meeting the Standards.
		Outlet	8.0	18	14	48	0.8	1.3	0.8	
		OLMS*	-	-	-	-	-	-	-	
	Ph-III(10)	Inlet	7.9	278	220	640	28.8	32.6	7.6	Not meeting the w.r.t BOD.
Outlet		8.0	46	36	108	2.8	3.8	2.3		
OLMS*		-	-	-	-	-	-	-		
	Total 30									

*Remarks:

*Remarks:

OLMS was found locked

N. Mishra
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/133 /974

9/10/19


ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER - 2019

1. Name & Address of Ind./Unit **DELHI GATE STP NEW**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **17.09.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	250	10	50	5	
1	Phase-I,II(15)	Inlet	7.9	196	135	400	20.4	26.4	7.1	Meeting the Standards.
		Outlet	7.7	6	4	16	0.4	1.6	0.8	
		OLMS*	6.6	11.82	6.09	35.65	-	9.66	-	
	Total 15									

N. Mitha
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/134 1975

9/10/19

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER - 2019

1. Name & Address of Ind./Unit **DELHI GATE STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **17.09.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	250	10	50	5	
		Inlet	7.9	112	90	276	18.4	24.6	6.8	
1	Phase-I,II(2.2)	Outlet	7.8	10	6	16	0.8	1.9	1.2	Meeting the Standards.
		OLMS*	7.08	12.55	5.40	22.54	-	4.0	-	
	Total 2.2									

Nmitra
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/135 /976

9/10/19

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER - 2019

1. Name & Address of Ind./Unit
Keshopur STP new
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
02.09.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	12	Inlet	7.5	228	165	250	10	50	5	Not meeting the Standards w.r.t TSS and BOD.
		Outlet	7.7	34	26	496	28.4	31.6	7.3	
		OLMS*	7.7	7.39	3.22	84	3.6	4.6	2.1	
	Total 12					19.15	-	0.59	-	

N. Maitra
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/136/977

9/10/19

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER - 2019

1. Name & Address of Ind./Unit

Sen Nursing Home (SNH)

2. Sampling location

Inlet and Outlet of STP

3. Date of Inspection

17.09.19

4. Samples collected by

DPCC Lab

5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	250	10	50	5	
1	Phase-I,II(2.2)	Inlet	8.0	276	120	332	28.4	31.3	6.8	Meeting the Standards.
		Outlet	7.7	4	2	8	ND	ND	ND	
		OLMS*	7.32	7.07	4.77	15.48	-	1.73	-	
	Total 2.2									

Nmisha
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/137/978

9/10/19

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER- 2019

1. Name & Address of Ind./Unit

Nilothi STP-II

2. Sampling location

Inlet and Outlet of STP

3. Date of Inspection

02.09.19

4. Samples collected by


DPCC Lab

5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	250	10	50	5	
1	20	Inlet	7.3	296	220	648	31.2	34.6	7.6	Meeting the Standards.
		Outlet	7.6	8	6	20	0.8	1.6	0.9	
		OLMS*	-	-	-	-	-	-	-	
	Total 20									

N. Mahesh
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/138/979

9/10/19

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER - 2019

1. Name & Address of Ind./Unit
Nilothi STP
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
02.09.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
1	40	Inlet	7.2	312	260	760	32.4	34.8	7.9	Not meeting the Standards w.r.t TSS and BOD.
		Outlet	7.4	56	44	132	2.8	3.9	2.0	
		OLMS*	7.36	34.21	42.48	121.67	-	21.75	-	
	Total 40									

Muiba
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/139/980

9/10/19

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER - 2019

1. Name & Address of Ind./Unit
Najafgarh STP
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
02.09.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

5. Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
1	5	Inlet	7.36	50 236	30 190	250 560	10 28.8	50 32.8	5 7.3	Not meeting the Standards w.r.t TSS and BOD.
		Outlet	7.6	58	46	128	4.0	5.3	2.6	
		OLMS*	-	-	-	-	-	-	-	
	Total 5									
Remarks:- OLMS was found locked										

Remarks:- OLMS was found locked

N. Mitha
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/140/981

9/10/19

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER - 2019

1. Name & Address of Ind./Unit
Rithala STP
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
05.09.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

5. Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l) 250	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 50	Dissolved Phosphate as P(mg/l) 5	Remarks
1	Phase-I(40)	Inlet	8.2	152	120	348	24.4	26.4	29.6	Not meeting the standards w.r.t BOD.
		Outlet	8.1	48	36	76	2.4	3.2	1.6	
		OLMS*	-	-	-	-	-	-	-	
2	Ph-II(40)	Inlet	8.2	152	120	348	24.4	26.4	29.6	Meeting the standards.
		Outlet	8.0	26	12	44	1.2	2.1	1.4	
		OLMS*	7.16	17.77	15	64.91	-	-	-	
	Total 80									
*Remarks: OLMS was										

*Remarks: OLMS was under maintenance

N. Mishra
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/141 982

9/10/19

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER - 2019

1. Name & Address of Ind./Unit **Pappankalan STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **02.09.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
				50	30	250	10	50	5	
1	20	Inlet	7.4	208	185	544	26.4	28.7	7.1	Not meeting the Standards w.r.t BOD.
		Outlet	7.7	42	36	104	3.2	4.6	2.2	
		OLMS*	-	-	-	-	-	-	-	
	Total 20									

Remarks:- OLMS was found locked

N. Mishra
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/142/983

9/10/19

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER - 2019

1. Name & Address of Ind./Unit
Pappankalan STP-II
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
02.09.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
1	20	Inlet	7.5	10	10	250	10	50	5	Not meeting the Standards w.r.t TSS and BOD.
		Outlet	7.6	160	125	364	24.4	26.9	6.9	
		OLMS*	7.07	46	38	108	3.6	4.2	2.1	
			8.11	2.46	24.98	-	1.39	-		
	Total 20									

NMisha
I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/143 984

9/10/19

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER - 2019

1. Name & Address of Ind./Unit **Rohini STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **05.09.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
1	15			10	10	250	10	50	5	Not meeting the Standards w.r.t TSS and BOD.
		Inlet	8.1	192	145	444	26.4	30.8	7.1	
		Outlet	8.0	74	58	176	3.2	4.0	2.1	
		OLMS*	7.15	24.01	14.29	109.58	-	10.86	-	
	Total 15									

N. Misha
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/144 / 985

9/10/19

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER- 2019

1. Name & Address of Ind./Unit
Narela STP
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
18.09.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
1	10	Inlet	7.7	220	175	532	28.8	33.2	7.4	Not meeting the Standards w.r.t BOD.
		Outlet	8.1	42	36	84	2.8	3.8	2.3	
		OLMS*	-	-	-	-	-	-	-	
		Total 10								

Remarks: OLMS was found locked

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/145/986

9/10/19

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER - 2019

1. Name & Address of Ind./Unit
Okhla STP New
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
20.09.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
1	30	Inlet	8.0	10 156	10 120	250 368	10 16.4	50 22.4	5 26.4	Meeting the Standards.
		Outlet	8.1	8	6	24	0.4	1.2	0.9	
		OLMS*	-	-	-	-	-	-	-	
		Total 30								
Remarks: OLMS was										

Remarks: OLMS was found locked

Mishra
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/146 / 987

9/10/19

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER - 2019

1. Name & Address of Ind./Unit
Kapashera STP
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
12.09.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

5. Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
1	5			10	10	250	10	50	5	
		Inlet	7.6	184	130	380	26.4	29.8	7.6	Not meeting the Standards w.r.t TSS and BOD.
		Outlet	7.9	26	18	56	3.6	4.3	2.0	
		OLMS*	7.08	11.11	6.19	33.64	-	3.64	-	
	Total 5									

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/147/988

9/10/19

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER - 2019


1. Name & Address of Ind./Unit
Yamuna Vihar STP Ph-III
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
04.09.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	25	Inlet	7.6	204	180	532	26..8	29.2	7.9	Not meeting the Standards w.r.t TSS and BOD.
		Outlet	7.7	34	26	76	4.4	5.3	2.8	
		OLMS*	-	-	-	-	-	-	-	
		Total 25								

Remarks: OLMS was found locked.

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/148 / 989

9/10/19


ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER - 2019

1. Name & Address of Ind./Unit **Chilla STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **04.09.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	250	10	50	5	
1	9	Inlet	7.7	184	135	400	24.4	28.6	6.9	Not meeting the Standards w.r.t TSS and BOD.
		Outlet	7.8	16	12	36	1.6	4.0	1.6	
		OLMS*	7.17	12.47	4.47	21.20	-	5.14	-	
	Total 9									

N. Misha
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/149/996

9/10/19

ANALYSIS REPORT OF STP FOR THE MONTH OF **SEPTEMBER- 2019**

1. Name & Address of Ind./Unit
Akshardham STP
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
20.09.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

5. Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
1	1	Inlet	7.8	116	90	276	24.0	26.8	28.9	Meeting the Standards.
		Outlet	8.1	6	4	16	0.4	1.3	0.4	
		OLMS*	7.38	0.16	0.14	1.58	-	0.25	-	
		Total 1								

N. M. M. M.
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/150/991

9/10/19

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER - 2019

1. Name & Address of Ind./Unit
Mehrauli STP
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
20.09.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
15		Inlet	7.8	132	95	296	20.4	22.6	6.0	Meeting the Standards .
		Outlet	7.9	38	28	82	2.8	3.5	1.6	
		OLMS*	7.35	34.14	18.33	88.67	-	15.09	-	
		Total 15								

N. Misha
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/151/992

9/10/19

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER - 2019


1. Name & Address of Ind./Unit
Vasant Kunj STP
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
02.09.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
1	2.2	Inlet	7.7	188	160	484	26.4	29.4	7.8	Meeting the Standards .
		Outlet	8.2	22	16	56	1.6	2.6	1.6	
		OLMS*	7.32	7.43	6.92	31.528	-	11.44	-	
	3	Inlet	7.8	144	110	320	14.4	18.8	6.3	Meeting the Standards
Outlet		7.9	16	12	36	0.4	1.2	0.6		
OLMS*		7.01	12.62	6.21	35.41	-	5.32	-		
	Total 5.2									

I/C
LABORATORY

N. Mishra

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/152/993

9/10/19

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER- 2019

1. Name & Address of Ind./Unit
Yamuna Vihar STP
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
04.09.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

5. Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
1	10	Inlet	8.1	50 148	30 120	250 356	10 22.4	50 26.4	5 7.1	Not meeting the Standards w.r.t TSS and BOD.
		Outlet	8.0	64	48	144	3.2	5.1	1.9	
		OLMS*	7.48	57.03	25.60	97.05	-	27.3	-	
	10	Inlet	8.0	176	135	532	26.4	29.6	7.6	Not meeting the Standards w.r.t BOD
		Outlet	8.1	46	38	112	4.0	5.6	2.8	
		OLMS*	7.2	40.61	10.49	64.57	-	10.87	-	
Total 20										

I/C LABORATORY

Misha

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/06/994

9/10/19

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER - 2019

1. Name & Address of Ind./Unit
Molarband mini STP
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
20.09.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	2	Inlet	7.9	50	30	250	10	50	5	Meeting the Standards.
		Outlet	8.0	268	230	680	33.6	36.4	6.9	
		OLMS*	-	38	26	64	1.6	2.4	1.3	
	Total 2									

Remarks: OLMS was found locked.

N. Mishra
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/153/995

9/10/19

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER - 2019

1. Name & Address of Ind./Unit
Okhla STP
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
20.09.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
1	12	Inlet	7.9	50 268	30 195	250 596	10 32.4	50 34.6	5 8.3	Meeting the Standards
		Outlet	8.0	26	12	32	1.2	2.8	1.9	
	16	Outlet	8.1	18	14	40	1.6	2.6	1.6	Meeting the Standards
	37	Outlet	8.1	26	18	56	1.2	2.0	1.4	Meeting the Standards
	45	Outlet	7.9	42	30	96	2.0	3.2	1.2	Meeting the Standards
	Total 110									Meeting the Standards

Remarks: OLMS was found locked.

N. Mishra
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/154/996

9/10/19

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER- 2019

1. Name & Address of Ind./Unit **Keshopur STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **02.09.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

5. Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
1	40	Inlet	7.3	200	160	480	27.2	29.6	7.0	Not meeting the Standards w.r.t TSS and BOD.
		Outlet	7.0	58	42	124	3.6	4.8	2.4	
		OLMS*	-	-	-	-	-	-	-	
	20	Inlet	7.3	200	160	480	27.2	29.6	7.0	Not meeting the Standards w.r.t TSS and BOD
Outlet		6.9	62	48	140	4.8	5.3	2.8		
OLMS*		-	-	-	-	-	-	-		
	Total 60									
Remarks: OLMS was										

Remarks: OLMS was found locked.

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/155/997

9/10/19

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER - 2019

6. Name & Address of Ind./Unit

Oxidation pond STP

7. Sampling location

Inlet and Outlet of STP

8. Date of Inspection

05.09.19

9. Samples collected by

DPCC Lab

10. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				50	30	250	10	50	5	
	6	Inlet	-	-	-	-	-	-	-	Non- operational due to under rehabilitation.
		Outlet	-	-	-	-	-	-	-	
		OLMS*	-	-	-	-	-	-	-	
	Total 6									

N. Mittal
I/C LABORATORY

SR. SCIENTIFIC ASSISTANT