

DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/74/3141

Dated: 9/4/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2021


1. Name & Address of Ind./Unit : Okhla STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 15.03.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	Parameters						Remarks
				TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	12	Inlet	6.79	248	138	384	8.8	30.64	15.06	Not meeting the Standards w.r.t TSS, BOD & COD, A.N & D.P.
		Outlet	7.10	24	14	72	5.2	6.10	2.34	
		OLMS	7.50	26.11	13.95	66.14	-	8.52	-	
		% Variation	-5.63 (D)	-8.79 (D)	0.35 (I)	8.13 (I)	-	-39.67 (D)	-	
	16	Outlet	6.84	28	20	76	2.8	3.19	2.68	Not meeting the Standards w.r.t TSS, BOD & D.P.
		OLMS	7.55	35.18	18.91	81.73	-	4.92	-	
		% Variation	-10.38 (D)	-25.64 (D)	5.45 (I)	-7.53 (D)	-	-54.23 (D)	-	
	37	Outlet	7.06	38	20	84	2.8	3.32	1.66	Not meeting the Standards w.r.t TSS, BOD & COD.
		OLMS	7.53	49.74	25.80	108.27	-	7.30	-	
		% Variation	-6.65 (D)	-30.89 (D)	-29 (D)	-28.89 (D)	-	-119.87 (D)	-	
	45	Outlet	7.00	42	24	106	4.4	3.56	2.57	Not meeting the Standards w.r.t TSS, BOD & COD & D.P.
		OLMS	7.60	24.70	12.92	72.26	-	4.46	-	
		% Variation	-8.57 (D)	41.19 (I)	46.16 (I)	31.83 (I)	-	-25.28 (D)	-	
Total 110										

I-Increase & D-Decrease

I/C LABORATORY
Scientist 'C'

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/73/3142

Dated: 9/4/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2021

1. Name & Address of Ind./Unit : Yamuna Vihar STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 12.03.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :


5. Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Remarks
				10	10	50	10	5	2	
1	2.2	Inlet	6.60	292	154	592	4.8	30.37	12.53	Not Meeting the Standards w.r.t TSS,COD & A.N.
		Outlet	7.16	16	10	52	3.2	9.2	1.56	
		OLMS*	7.43	15.56	8.79	61.99	-	20.85	-	
		% Variation	-3.77 (D)	2.75 (I)	12.1 (I)	-19.2 (I)	-	-126.63 (D)	-	Not Meeting the Standards w.r.t TSS, BOD, COD & A.N.
2	3	Inlet	6.85	352	140	704	06	17.67	16.50	
		Outlet	7.00	28	20	76	2.4	7.47	1.39	
		OLMS*	-	-	-	-	-	-	-	
		% Variation	-	-	-	-	-	-	-	
Total 5.2										

I-Increase & D-Decrease

Remarks: OLMS (3 MGD) was not found.

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/72/3143

Dated: 9/4/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2021

1. Name & Address of Ind./Unit : Vasant Kunj STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.03.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	2.2	Inlet	7.32	356	270	624	14.4	34.16	11.30	Not meeting the Standards w.r.t TSS, COD & A.N.
		Outlet	7.72	18	10	60	2.4	8.61	1.91	
		OLMS*	7.0	33.86	19.56	77.70	-	11.53	-	
		% Variation	9.32(I)	-88.11 (D)	-95.3 (D)	-29.5 (D)	-	-33.91 (D)	-	
2	3	Inlet	7.12	284	240	448	06	31.11	1.44	Not Meeting the Standards w.r.t TSS, BOD & COD.
		Outlet	7.25	20	12	56	3.6	4.74	1.62	
		OLMS*	7.68	48.32	15.69	91.78	-	1.93	-	
		% Variation	-5.93 (D)	-141.6 (D)	-30.75 (D)	-63.89 (D)	-	59.28 (I)	-	
Total 5.2										


I-Increase & D-Decrease

N. Mishra

I/C LABORATORY
Scientist

SR. Scientific Assistant

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Dated : 9/4/2021

Report Number : DPCC/W/STP/20-21/71/3144

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2021

1. Name & Address of Ind./Unit : Mehrauli STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.03.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results :										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	15	Inlet	7.43	124	92	389.33	18.4	36.16	13.62	Not meeting the standards w.r.t TSS, BOD & COD.
		Outlet	7.58	16	12	56	1.4	4.25	2.16	
		OLMS*	7.69	14.45	9.96	40.52	-	3.98	-	
		% Variation	-1.45 (D)	9.68 (I)	17 (I)	27.64 (I)	-	6.35 (I)	-	
Total 15										


I-Increase & D-Decrease

M. Mittal
I/C LABORATORY

[Signature]

SR. SCIENTIFIC ASSISTANT

Scientist



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/70/3145

Dated: 9/4/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2021

1. Name & Address of Ind./Unit : Akshardham STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 22.03.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :


Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
						10	10	50	10	
1	1	Inlet	7.00	288	118	336	24.0	46.90	15.17	Meeting the Standards.
		Outlet	7.56	2	1	12	0.4	1.61	0.21	
		OLMS*	7.69	7.39	5.18	17.09	-	0.40	-	
		% Variation	-1.71 (D)	-269.5 (D)	-418 (D)	-42.41 (D)	-	75.15 (I)	-	
Total 1										

I-Increase & D-Decrease

Mulla
I/C LABORATORY

ANITA MOTTA
Scientist 'C'

Abhinav
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE (Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/69/3146

Dated: 9/4/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2021

1. Name & Address of Ind./Unit : Chilla STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 22.03.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :


Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	9	Inlet	7.26	284	150	296	2.9	56.76	18.41	Meeting the Standards.
		Outlet	7.34	6	4	28	0.8	4.25	1.69	
		OLMS*	7.08	8.66	5.01	24.56	-	3.08	-	
		% Variation	3.54 (I)	-44.33 (D)	-25.25 (D)	12.28 (I)	-	27.52 (I)	-	
Total 9										

I-Increase & D-Decrease

N. Mahesh
I/C LABORATORY

Scientist

Sh. S. Sharma
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/68/3147

Dated: 9/4/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2021


1. Name & Address of Ind./Unit : Yamuna Vihar STP Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 12.03.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	25	Inlet	7.00	728	325	960	1.6	28.87	16.92	Not meeting the Standards w.r.t TSS, BOD & COD.
		Outlet	6.60	30	20	68	3.6	2.75	1.12	
		OLMS*	-	28.37	20.71	69.80	-	-	-	
		% Variation	-	5.43 (I)	-3.55 (D)	-2.64 (D)	-	-	-	
Total 25										

I-Increase & D-Decrease

Milra
I/C LABORATORY
Scientist

R. K. Sharma
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/67/3148

Dated: 9/4/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2021

1. Name & Address of Ind./Unit : Kapasahera STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.03.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results :


Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	5	Inlet	7.34	604	260	1120	3.6	43.62	16.55	Meeting the Standards.
		Outlet	7.54	10	8	48	2.2	4.43	1.90	
		OLMS*	6.88	12.45	8.73	66.43	-	4.38	-	
		% Variation	8.75 (I)	-24.5 (D)	-9.12 (D)	-38.39 (D)	-	1.12 (I)	-	
Total 5										

I-Increase & D-Decrease

N. Mittal
I/C LABORATORY

A. B. Sharma

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE (Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/66/3149

Dated: 9/4/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2021


1. Name & Address of Ind./Unit : Kondli STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 22.03.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
						COD (mg/l)				
				10	10	50	10	5	2	
1	45	Inlet	7.07	284	205	704	15.8	51.60	11.32	Not Meeting the Standards w.r.t TSS, BOD & COD & A.N.
		Outlet	7.08	132	74	284	6.8	14.98	1.60	
		OLMS*	7.35	63.42	53.13	193.52	-	22.53	-	
		% Variation	-3.81 (D)	51.95 (I)	28.20 (I)	31.85 (I)	-	-50.40 (D)	-	
Total 45										

I-Increase & D-Decrease

Mukherjee
I/C LABORATORY
Scientist

SR. Scientific Assistant
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/65/3/56

Dated: 9/4/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2021

1. Name & Address of Ind./Unit : Kondli STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 22.03.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	25	Inlet	7.04	372	285	664	13.7	45.69	18.14	Not meeting the Standards w.r.t TSS, BOD & COD
		Outlet	7.54	16	12	52	3.6	4.11	1.90	
		OLMS*	7.50	15.13	19.20	86.24	-	4.79	-	
		% Variation	0.53 (I)	5.43 (I)	-60 (D)	-65.84 (D)	-	-16.54 (D)	-	
Total 25										


I-Increase & D-Decrease

Maita
I/C LABORATORY

Scientist 'C'

SR. Scientific Assistant

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/64 |3|51

Dated: 9/4/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2021


1. Name & Address of Ind./Unit : Okhla STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 15.03.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters Analysis and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	30	Inlet	6.66	280	240	368	20.4	33.38	11.57	Meeting the Standards
		Outlet	6.88	8	6	30	0.8	1.07	0.63	
		OLMS*	7.68	6.48	5.85	22.59	-	3.79	-	
		% Variation	-11.62 (D)	19 (I)	2.5 (I)	24.7 (I)	-	-254.20 (D)	-	
Total 30										

I-Increase & D-Decrease

N. Mishra
I/C LABORATORY
ANDITA MOITRA
Scientist

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/63/3152

Dated: 9/4/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2021

1. Name & Address of Ind./Unit : Narela STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.03.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	10	Inlet	7.48	216	100	624	0.8	39.73	16.21	Not Meeting the Standards w.r.t TSS.
		Outlet	7.64	12	5	40	0.8	2.39	1.12	
		OLMS*	7.38	17.62	7.18	38.05	-	3.69	-	
		% Variation	3.40 (I)	-46.83 (D)	-43.6 (D)	4.87(I)	-	-54.39 (D)	-	
Total 10										


I-Increase & D-Decrease

N. Mishra
I/C LABORATORY

Scientist

SR. Scientific Assistant

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/20-21/62/3153

Dated: 9/4/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2021

1. Name & Address of Ind./Unit : Rohini STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.03.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :


5. Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	15	Inlet	7.54	64	195	800	9.2	39.27	17.46	Not meeting the Standards w.r.t TSS & A.N.
		Outlet	7.50	16	8	40	2.4	8.64	1.81	
		OLMS*	7.46	12.27	8.0	47.75	-	9.35	-	
		% Variation	0.53 (I)	23.31 (I)	-	-19.37 (D)	-	-8.21 (D)	-	
Total 15										

I-Increase & D-Decrease

N. Mitra
I/C LABORATORY

Scientist C

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/61/354

Dated: 9/4/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2021

1. Name & Address of Ind./Unit : Pappankalan STP-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.03.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results :										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
						COD (mg/l)				
				10	10	50	10	5	2	
1	20	Inlet	6.60	500	275	576	12	38.56	15.20	Meeting the Standards.
		Outlet	7.01	8	6	36	1.6	3.86	1.26	
		OLMS*	-	-	-	-	-	-	-	
		% Variation	-	-	-	-	-	-	-	
Total 20										


Remarks: OLMS was found non-operational at the time of DPCC Monitoring

I-Increase & D-Decrease

I/C LABORATORY

Scientist

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/60/3155

Dated: 9/4/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2021

1. Name & Address of Ind./Unit : Pappankalan STP (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.03.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results :										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	20	Inlet	6.46	452	225	480	20	39.48	15.87	Not meeting the Standards w.r.t TSS, BOD, COD, A.N & D.P.
		Outlet	7.10	64	48	132	4	10.92	8.89	
		OLMS*	7.63	50.76	27.88	148.31	-	8.2	-	
		% Variation	-7.46 (D)	20.68 (I)	41.91 (I)	-12.35 (D)	-	24.90 (I)	-	
Total 20										

I-Increase & D-Decrease

Mishra
I/C LABORATORY

P. K. Sharma
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE (Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/59/3156

Dated: 9/4/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2021


1. Name & Address of Ind./Unit : Rithala STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.03.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

5. Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters	Oil & Grease (mg/l)	Ammonica INitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	Phase-I(40)	Inlet	7.07	284	180	512	26	45.66	12.16	Not meeting the standards w.r.t to TSS,BOD,COD.A.N & D.P.
		Outlet	7.24	114	56	240	4.8	25.40	8.60	
		OLMS*	7.15	126.34	87.34	265.13	-	62.13	-	
		% Variation	1.24 (I)	-10.82 (D)	-55.96 (D)	-10.47 (D)	-	-144.60 (D)	-	
2	Ph-II(40)	Inlet	7.03	312	120	384	15.6	42.36	16.13	Not meeting the standards w.r.t to TSS,BOD,COD & D.P.
		Outlet	7.02	18	12	48	2.4	4.11	2.0	
		OLMS*	7.11	16.02	11.97	92.06	-	4.06	-	
		% Variation	-1.28 (D)	11 (I)	0.25 (I)	-91.79 (D)	-	1.21 (I)	-	
Total 80										

I-Increase & D-Decrease

Mukherjee
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/20-21/58/3157

Dated: 9/4/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2021


1. Name & Address of Ind./Unit : Najafgarh STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.03.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	5	Inlet	6.42	152	122	440	13.2	26.91	13.63	Not meeting the standards w.r.t to TSS, BOD, COD & A. N.
		Outlet	7.17	46	24	104	6.4	11.09	1.60	
		OLMS*	7.90	45.73	20.83	91.64	-	8.24	-	
		% Variation	-10.18 (D)	0.58 (I)	13.20 (I)	11.88 (I)	-	25.69 (I)	-	
Total 5										

I-Increase & D-Decrease

Mukta
I/C LABORATORY

Abhinav
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/57/3/58

Dated: 9/4/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2021


1. Name & Address of Ind./Unit : Nilothi STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.03.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
				COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)			
				10	10	50	10	5	2	
1	40	Inlet	7.02	284	125	436	18.3	30.45	19.87	Not Meeting the Standards w.r.t TSS, BOD, COD & A.N.
		Outlet	7.04	82	56	240	6.4	11.72	1.41	
		OLMS*	5.79	71.25	24.97	135.74	-	19.05	-	
		% Variation	17.79 (I)	13.10 (I)	55.41 (I)	43.44 (I)	-	-62.54 (D)	-	
Total 40										

I-Increase & D-Decrease

N. Mittal
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE (Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/56/3/59

Dated : 9/4/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2021


1. Name & Address of Ind./Unit : Nilothi STP-II
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.03.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

3. Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	20	Inlet	6.56	244	155	352	14	26.82	15.04	Meeting the Standards.
		Outlet	7.03	10	6	48	1.2	4.06	1.99	
		OLMS*	7.50	7.63	4.20	34.45	-	2.72	-	
		% Variation	-6.68 (D)	23.7 (I)	30 (I)	28.22 (I)	-	33.00 (I)	-	
Total 20										

I-Increase & D-Decrease

N. Mishra
I/C LABORATORY
Scientist

[Signature]
SR, SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/55/3/60

Dated: 9/4/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2021


1. Sampling location : Inlet and Outlet of STP
2. Name & Address of Ind./Unit : SEN Nursing Home (SNH)
3. Date of Inspection : 05.03.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	Phase-I,II (2.2)	Inlet	6.93	184	104	528	20	39.79	15.36	Meeting the Standards
		Outlet	6.60	8	6	36	3.6	2.89	1.44	
		OLMS*	7.04	7.95	4.88	27.66	-	4.93	-	
		% Variation	-6.66 (D)	0.62 (I)	18.66 (I)	23.15 (I)	-	-70.58 (D)	-	
Total 2.2										

I-Increase & D-Decrease

Mishra
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/54/3161

Dated: 9/4/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2021

1. Name & Address of Ind./Unit : Keshopur STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.03.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	12	Inlet	7.00	316	285	176	17.2	40.61	12.37	Meeting the Standards.
		Outlet	7.70	8	4	32	2.6	3.16	1.23	
		OLMS*	-	-	-	-	-	-	-	
		% Variation	-	-	-	-	-	-	-	
Total 12										


I-Increase & D-Decrease

Remarks: OLMS was found non-operational during the visit of DPCC.

Mitha
I/C LABORATORY

Scientist

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/53/3/62

Dated: 9/4/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2021

1. Name & Address of Ind./Unit : DELHI GATE STP (OLD)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 05.03.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :


5. Parameters analyzed and results :										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	Phase-I,II(2.2)	Inlet	7.11	128	106	512	16.8	43.17	16	Meeting the Standards.
		Outlet	6.90	10	8	40	6.4	2.21	1.60	
		OLMS*	6.92	10.35	8.76	18.15	-	2.23	-	
		% Variation	-0.289 (D)	-3.5 (D)	-9.5 (D)	54.625 (I)	-	0.904 (D)	-	
Total 2.2										

I-Increase & D-Decrease

I/C LABORATORY

Scientist

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Dated: 9/4/2021

Report Number: DPCC/W/STP/20-21/52/ 3/63

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2021

1. Name & Address of Ind./Unit : Delhi Gate STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 05.03.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	Phase-I,II(15)	Inlet	7.21	184	114	256	24.4	14.30	12.54	Meeting the Standards.
		Outlet	7.07	6	4	32	1.2	2.46	0.8	
		OLMS*	7.15	5.87	4.83	25.56	-	0.90	-	
		% Variation	-1.13 (D)	2.16 (I)	-20.75 (D)	20.12 (I)	-	63.41 (I)	-	
Total 15										

I-Increase & D-Decrease

N. Mitra
I/C LABORATORY

BANDITA MOTTRA
Scientist 'C'

S. B. Momo
SR. SCIENTIFIC ASSISTANT