



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, JSBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/151/2229

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2025

Dated 06/10/2025

1. Name of STP : Delhi Gate (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 02.09.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	Phase-I & II (15)	Inlet	6.5-9.0	10	10	50	10	5	2	Meeting the standards
		Outlet	7.5	138	100	228	12.8	9.5	9.5	
		OLMS	7.3	7	4	20	1.6	1.6	0.6	
Total 15			7.28	7.33	7.09	23.76	-	2.70		

Fecal coliform analysis is not done due to bacteriological lab under rehabilitation.

Note - Fecal coliform analysis is not done due to bacteriological lab under rehabilitation.

I/C Water Laboratory

Dr. Shweta Gupta
(Water Laboratory)

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/152/2230

Dated 06/10/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2025

1. Name of STP : Delhi Gate (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 02.09.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	Ph-I & II (10)	Inlet	7.1	156	120	248	13.6	8.2	6.7	Meeting the standards.
		Outlet	7.4	8	6	28	1.2	1.6	0.8	
		OLMS	7.31	4.39	4.81	16.77	-	1.22		
Total 2.2										

2 - Fecal coliform analysis is not done due to bacteriological lab under rehabilitation

Note - Fecal coliform analysis is not done due to bacteriological lab under rehabilitation.

I/C Water Laboratory

Dr. Shweta Gupta

Incharge (Water Laboratory)

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocms.nic.in>)



Report Number: DPCC/W/STP/25-26/15 3/2231

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2025

Dated 06/10/2025

1. Name of STP : SEN Nursing Home (SNH)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 02.09.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	Phase-I,II (2.2)	Inlet	6.5-9.0	10	10	50	10	5	2	Meeting the Standards.
			7.6	182	167	396	14.8	9.0	10.2	
		Outlet	7.2	7	8	36	0.8	1.8	1.8	
			OLMS	7.12	4.84	2.80	20.79	-	2.19	
Total 2.2										

Fecal coliform analysis is not done due to bacteriological lab under rehabilitation

Note - Fecal coliform analysis is not done due to bacteriological lab under rehabilitation.

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/25-26/154/2232

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2025 Dated 06/10/2025

1. Name of STP : Akshardham
2. Sampling location : Inlet and Outlet of STP=
3. Date of sampling : 02.09.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	1	Inlet	6.5-9.0	10	10	50	10	5	2	Meeting the Standards.
		Outlet	7.3	214	100	316	13.2	9.6	9.1	
		OLMS	7.1	5	6	28	1.2	1.4	1.0	
Total 1			7.55	0.80	1.60	7.36	-	0.52		

Note - Fecal coliform analysis is not done due to bacteriological lab under rehabilitation.

Dr. Shweta Gupta
In-charge Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/155/2233

Dated 66/10/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2025

1. Name of STP : Kondli
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 02.09.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	Ph-I (10)	Inlet	7.2	228	140	412	12.8	8.8	6.9	
		Outlet	7.5	9	8	24	0.8	1.2	1.0	
		OLMS	7.44	6.6	08	20	-	3.75	-	
2	Ph-II & III (25+10)	Outlet	7.6	8	6	32	0.4	1.4	1.0	Meeting the Standards.
		OLMS	7.4	6.9	7.9	20.50	-	3.85		
Total 45										

Note - Fecal coliform analysis is not done due to bacteriological lab under rehabilitation.

I/C Water Laboratory
Incharge (Water Laboratory)

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/156/2234

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2025

Dated 06/10/25

1. Name of STP : Chilla
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 02.09.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results:

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	9	Inlet	6.5-9.0	10	10	50	10	5	2	Meeting the Standards.
		Outlet	7.3	156	130	316	16	10.8	8.6	
		OLMS	7.5	7	7	40	0.8	1.2	1.0	
Total 9			7.41	6.58	4.87	27.77	-	2.07	-	

Note - Fecal coliform analysis is not done due to bacteriological lab under rehabilitation.

I/C Water Laboratory

Dr. Shweta Gupta

Incharge (Water Laboratory)

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/25-26/154/2235

Dated 06/10/25

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2025

1. Name of STP : Kondli New
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 02.09.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	Ph-IV (45)	Inlet	7.7	214	150	324	12.8	11.2	6.9	Meeting the Standards
		Outlet	7.1	7	8	32	1.2	1.6	0.9	
		OLMS	7.40	9.40	5.30	20.90	-	4.62	-	
Total 45										

Note - Fecal coliform analysis is not done due to bacteriological lab under rehabilitation.

I/C Water Laboratory
Dr. Shikha Gupta
Incharge (Water Laboratory)

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/158/2236

Dated: 06/10/25

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2025

1. Name of STP : Rithala
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 08.09.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	Ph-I(40)	Inlet	6.5-9.0	10	10	50	10	5	2	Meeting the standards
		Inlet	7.6	184	160	352	8	9.8	10.9	
		Outlet	7.2	8	6	28	1.2	1.6	0.7	
		OLMS	7.13	8.62	6.89	31.59	-	2.01	-	
2	Ph-II(40)	Inlet	7.1	214	170	348	10.8	8.3	10.9	Meeting the standards
		Outlet	7.9	7	7	24	0.8	1.4	0.8	
		OLMS	7.37	8.19	7.24	35.28	-	3.15	-	
Total 80										

Note - Fecal coliform analysis is not done due to bacteriological lab under rehabilitation

I/C Water Laboratory

Dr. Shweta (Water Laboratory)

Scientist 'B'/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocemms.nic.in>)



Report Number DPCC/W/STP/25-26/154 /2231

Dated 06/10/25

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER -2025

1. Name of STP : Rohini
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 08. 09. 2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	25	Inlet	7.3	202	155	344	10.8	9.7	11.8	Meeting the standards.
		Outlet	7.6	8	8	36	1.6	1.0	0.6	
		OLMS	7.35	7.40	4.90	26.91	-	1.27		
Total 25										

Note - Fecal coliform analysis is not done due to bacteriological lab under rehabilitation

Shweta Gupta

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

Scientist 'B'/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmrms.nic.in>)



Report Number: DPCC/W/STP/25-26/ 160/2238

Dated 06/10/25

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2025

1. Name of STP : Yamuna Vihar Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 08.09.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	25	Inlet	7.4	180	160	328	8.8	11.5	5.4	Not meeting the Standards wrt TSS, BOD & COD
		Outlet	7.3	22	16	56	1.2	2.4	1.4	
		OLMS	7.67	26.75	16.46	76.15	-	27.34	-	
Total 25										

Fecal coliform analysis is not done due to bacteriological lab under rehabilitation

Note - Fecal coliform analysis is not done due to bacteriological lab under rehabilitation.

Shankar
I/C Water Laboratory
Dr. Shrivastava
Incharge (Water Laboratory)

Scientist B
Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocms.nic.in>)



Report Number: DPCC/W/STP/25-26/164 / 2234

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2025

Dated 06/10/25

1. Name of STP : Yamuna Vihar
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 08.09.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	10 Ph-1	Inlet	6.5-9.0	10	10	50	10	5	2	Not meeting the standards wrt TSS, BOD & COD.
		7.6	264	170	364	4.8	9.7	7.4		
		Outlet	7.5	34	20	60	1.2	2.1	1.2	
		OLMS	7.51	37.08	NA	NA	-	23.10		
2	15 Ph-2	Inlet	7.8	192	150	352	5.2	11.2	6.4	BOD and COD were showing red at time of DPCC Inspection
		Outlet	7.5	8	6	32	1.6	1.8	1.0	
		OLMS		5.85	1.65	27.97	-	3.53		
		Total 20								
Meeting the standards										

Note - Fecal coliform analysis is not done due to bacteriological lab under rehabilitation.

I/C Water Laboratory
Dr. Shweta Gupta

Incharge (Water Laboratory)

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/162/2290

Dated 06/10/25

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER -2025

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of sampling : 10.09.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	Ph-I,II (20)	Inlet	6.5-9.0	10	10	50	10	5	2	Meeting the standards
		7.3	216	110	312	8.8	11.0	4.2		
		Outlet	7.5	8	6	28	0.8	1.0	0.9	
		OLMS	7.57	7.36	5.08	22.85	-	1.66		
2	Ph-III (10)	Inlet	7.6	204	130	296	8	9.8	8.5	Meeting the standards.
		Outlet	7.5	7	4	24	1.2	1.6	0.8	
		OLMS	7.72	7.46	5.38	24.02	-	1.41		
		Total 30								

Note - Fecal coliform analysis is not done due to bacteriological lab under rehabilitation.

Shweta Gupta
Incharge (Water Laboratory)
I/C Water Laboratory

Scientist 'B' /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/163/2241

Dated 06/10/25

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2025

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of sampling : 10.09.2025
4. Samples collected by : DPCC Lab
5. Parameters Analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	70 MGD	Inlet	7.9	184	120	268	5.6	10.4	8.5	Meeting the standards.
		Outlet	7.7	6	4	20	1.6	1.2	0.8	
		OLMS	7.31	5.47	5.49	43.23	-	1.7	-	
Total 70										

Note - Fecal coliform analysis is not done due to bacteriological lab under rehabilitation.

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/164/2242

Dated 06/10/25

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2025

1. Name of STP : Keshopur
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 12.09.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	60	Inlet	6.5-9.0	10	10	50	10	5	2	Meeting the Standards
			7.8	252	160	336	12.4	10.9	8.3	
		Outlet	7.4	8	6	28	1.2	1.2	0.8	
		OLMS	7.5	8	6	34	-	2		
2	20	Outlet	7.2	7	4	16	0.8	1.4	0.7	Meeting the Standards..
		OLMS	7.78	7.8	9	35	-	3		
Total 60										

Note - Fecal coliform analysis is not done due to bacteriological lab under rehabilitation.

I/C Water Laboratory
Incharge (Water Laboratory)

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/165/2243

Dated 06/10/25

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2025

1. Name of STP : Keshopur STP (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 12.09.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	12	Inlet	6.5-9.0	10	10	50	10	5	2	Meeting the standards.
			7.7	184	120	296	9.2	10.6	7.5	
			7.4	7	6	28	0.8	2.2	0.7	
			OLMS	7.61	7.04	6.04	27.85	-	2.58	
Total 12										

Note - Fecal coliform analysis is not done due to bacteriological lab under rehabilitation.

[Signature]
I/C Water Laboratory
Dr. Shashi Gupta
Incharge (Water Laboratory)

[Signature]
Scientist B/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/166/2244

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2025

Dated 06/10/25

1. Name of STP : Okhla
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 18.09.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	124 MGD	Inlet	6.5-9.0	10	10	50	10	5	2	
		Outlet	7.5	252	120	344	16.8	10.0	11.2	
		OLMS	7.89	7	5.72	28.62	-	2.54	0.9	Meeting the Standards.
Total 124										-

- Fecal coliform analysis is not done due to bacterial

Note - Fecal coliform analysis is not done due to bacteriological lab under rehabilitation.

I/C Water Laboratory
Dr. S. Gupta

Incharge (Water Laboratory)

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/167/2215

Dated 06/10/25

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2025

1. Name of STP : Okhla New
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 18.09.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
1	30	Inlet	6.5-9.0	10	10	50	10	5	2	Meeting the Standards.	
			7.9	220	120	288	13.6	9.4	10.1		
			Outlet	7.6	8	7	32	1.2	1.5		1.1
			OLMS	7.53	6.66	5.70	24.90	-	1.61		-
Total 30											

Note - Fecal coliform analysis is not done due to bacteriological lab under rehabilitation.

I/C Water Laboratory

Dr Shweta Gupta

(Incharge Water Laboratory)

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocms.nic.in>)



Report Number: DPCC/W/STP/25-26/168 / 2246

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2025

Dated 06/10/25

1. Name of STP : Okhla
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 18.09.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
16		Inlet	7.5	252	120	344	16.8	10.0	11.2	Not meeting the Standards w.r.t. Dissolved Phosphate
		Outlet	7.2	7	6	20	0.8	2.3	2.4	
		OLMS	7.40	10.45	7.84	38.02	-	4.64	-	
Total 16										

Note - Fecal coliform analysis is not done due to bacteriological lab under rehabilitation.

I/C Water Laboratory

DR. Shweta Gupta
Incharge (Water Laboratory)

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/169/2241

Dated 06/10/25

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2025

1. Name of STP : Molarband (Mini STP)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 18.09.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	0.66	Inlet	6.5-9.0	10	10	50	10	5	2	Not meeting the standard wrt TSS, BOD& COD
			7.8	284	120	320	12.8	10.9	8.0	
		Outlet	7.7	26	20	64	0.4	1.6	1.8	
		OLMS	7.49	31.42	23.79	82.65	-	8.54	-	
Total 0.66										

Fecal coliform analysis is not done due to bacteriological lab under rehabilitation

Note - Fecal coliform analysis is not done due to bacteriological lab under rehabilitation.

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/170/2248

Dated 06/10/25

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2025

1. Name of STP : Pappankalan (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 19.09.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	30	Inlet	7.2	208	150	364	17.2	9.9	9.2	Meeting the Standards.
		Outlet	7.6	10	8	28	1.2	1.1	0.9	
		OLMS	7.60	8.75	5.84	26.34	-	1.84	-	
Total 30										

Note - Fecal coliform analysis is not done due to bacteriological lab under rehabilitation.

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmnms.nic.in>)



Report Number: DPCC/W/STP/25-26/17/1/2249

Dated 06/10/25

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2025

1. Name of STP : Pappankalan Ph-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 19.09.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
20		Inlet	7.2	208	150	364	17.2	9.9	9.2	Meeting the standards.
		Outlet	7.4	8	7	36	1.6	1.8	0.7	
		OLMS	7.65	6.43	4.71	28.46	-	1.76	-	
Total 20										

Note - Fecal coliform analysis is not done due to bacteriological lab under rehabilitation.

I/C Water Laboratory

Dr. Shweta Gupta

Incharge (Water Laboratory)

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocnms.nic.in>)



Report Number DPCC/W/STP/25-26/179/2250

Dated 06/10/25

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2025

1. Name of STP : Najafgarh
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 19.09.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters										Remarks
Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	5	Inlet	7.5	250	180	384	16	10.3	11.8	Meeting the Standards.
		Outlet	7.1	8	7	32	1.2	1.3	0.7	
		OLMS	7.51	8.70	6.00	30.40	-	2.65	-	
Total 5										

- Fecal coliform analysis is not done due to bacteriological lab under rehabilitation.

Note - Fecal coliform analysis is not done due to bacteriological lab under rehabilitation.

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/13/2251

Dated 06/10/25

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER -2025

1. Name of STP : Narela
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 19.09.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	10	Inlet	6.5-9.0	10	10	50	10	5	2	Meeting the standards
		Outlet	7.5	182	150	328	18.4	11.4	9.9	
		OLMS	7.3	9	7	36	1.6	1.0	0.9	
Total 10			7.83	7.52	5.47	22.91	-	1.45	-	

Note - Fecal coliform analysis is not done due to bacteriological lab under rehabilitation.

Shweta Gupta

I/C Water Laboratory

Dr. Shweta Gupta

In-charge (Water Laboratory)

Scientist 'B' /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/174/2252

Dated 06/10/25

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2025

1. Name of STP : Mehrauli
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 22.09.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	15	Inlet	6.5-9.0	10	10	50	10	5	2	Not meeting the standards wrt TSS & Dissolved Phosphate
		Outlet	7.4	190	160	316	17.2	9.0	11.6	
		OLMS	7.6	18	10	36	1.6	0.8	2.8	
		OLMS	7.53	9.56	8.21	38.71	-	7.53	-	
Total 15										

Note - Fecal coliform analysis is not done due to bacteriological lab under rehabilitation.

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/135/2253

Dated 06/10/25

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2025

1. Name of STP : Vasant Kunj
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 22.09.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	2.2	Inlet	7.2	202	170	348	14.4	11.6	8.9	Not meeting the standards wrt TSS, BOD & COD.
		Outlet	7.5	42	23	84	1.2	1.6	1.6	
		OLMS	7.29	8.91	8.23	39.84	-	5.13	-	
		Inlet	7.3	234	180	432	12.4	9.4	10.5	
2	3	Outlet	7.6	32	20	72	2.4	2.4	1.8	Not meeting the standards wrt TSS, BOD & COD.
		OLMS	7.02	7.51	5.94	34.85	-	4.32		
Total 5.2										

Note - Fecal coliform analysis is not done due to bacteriological lab under rehabilitation

I/C Water Laboratory

Dr. Shweta Gupta

Incharge (Water Laboratory)

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocemms.nic.in>)



Report Number: DPCC/W/STP/25-26/176/2254

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2025

Dated 06/10/25

1. Name of STP : Ghitorni
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 22.09.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	5	Inlet	7.3	250	160	368	19.2	12.6	4.7	Not meeting the Standards wrt TSS, BOD, COD & Dissolved Phosphate
		Outlet	7.2	24	15	60	1.6	1.2	3.0	
		OLMS	7.44	20.67	13.04	67.01	-	5.41	-	
Total 5										

Note - Fecal coliform analysis is not done due to bacteriological lab under rehabilitation.

I/C Water Laboratory

Dr. Shweta Gupta

Incharge (Water Laboratory)

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/177/2255

Dated 06/10/25

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2025

1. Name of STP : Kapasahera
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 22.09.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results:

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	5	Inlet	7.4	208	170	380	14.4	12.1	10.9	Not meeting the Standard wrt TSS & Dissolved Phosphate.
		Outlet	7.2	12	8	36	1.6	2.7	2.2	
		OLMS	7.81	8.43	5.04	39.60	-	2.80	-	
Total 5										

Note - Fecal coliform analysis is not done due to bacteriological lab under rehabilitation.

I/C Water Laboratory

Dr. Shweta Gupta

Incharge (Water Laboratory)

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/178/2256

Dated 06/10/25

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2025

1. Name of STP : Nilothi Phase-II
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 23.09.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters										Remarks
Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	20	Inlet	6.5-9.0	10	10	50	10	5	2	Meeting the standards.
			7.6	220	130	276	14.8	11.5	9.6	
			7.3	8	6	28	1.6	1.6	0.6	
			OLMS	7.86	6.26	4.40	34.82	-	4.68	
Total 40										

- Fecal coliform analysis is not done due to bacteriological lab under rehabilitation.

Note - Fecal coliform analysis is not done due to bacteriological lab under rehabilitation.

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

Scientist R /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocms.nic.in>)



Report Number: DPCC/W/STP/25-26/179/2257

Dated 06/10/25

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2025

1. Name of STP : Nilothi New, Phase-I
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 23.09.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
			6.5-9.0	10	10	50	10	5	2	
1	40	Inlet	7.2	162	160	388	14.4	12.3	11.5	Meeting the Standards.
		Outlet	7.4	9	8	24	1.6	0.9	0.8	
		OLMS	7.71	9.77	7.07	45.28		7.35	-	
Total 20										

Note - Fecal coliform analysis is not done due to bacteriological lab under rehabilitation.

Shweta Bhatia

I/C Water Laboratory

Dr. Shweta Bhatia

Incharge (Water Laboratory)

Scientist B /Analyst

Dr. Shweta Bhatia



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/180/2258

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2025

Dated 06/10/25

1. Name of STP : Sonia Vihar
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 10.09.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters						Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)		Dissolved Phosphate as P (mg/l)
1	7	Inlet	6.5-9.0	10	10	50	10	5	2	No sampling was conducted due to no flow at the time of DPCC inspection
		Outlet	-	-	-	-	-	-	-	
		OLMS								
Total 7										

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

Scientist B /Analyst