



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Dated 01/08/2025

Report Number: DPCC/W/STP/25-26/91/2051

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2025

1. Name of STP : Okhla
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 02.07.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
16	Inlet	7.4	224	135	392	18.8	12.9	11.5	-	Not meeting the Standards wrt. Fecal coliform.	
	Outlet	7.1	8	7	24	1.2	0.9	0.9	280		
	OLMS	7.46	13.95	7.61	48.03	-	5.59	-	-		
Total 16											

[Signature]

I/C Water Laboratory

[Signature]

Scientist B /Analyst

Dr. Shweta Gupta
Incharge (Water Laboratory)



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/92/2052

Dated 01/08/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2025

1. Name of STP : Okhla
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 02.07.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	124 MGD	Inlet	7.4	224	135	392	18.8	12.9	11.5	-	Meeting the standards.
		Outlet	7.2	6	5	20	1.6	0.9	0.9	180	
		OLMS	7.48	7.6	5.7	28.5	-	2.26	-	-	
Total 124											

Shweta
I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

[Signature]
Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/ 93/2053

Dated 01/08/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2025

1. Name of STP : Okhla New
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 02.07.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	30	Inlet	7.5	218	140	312	19.2	10.8	11.8	-	Meeting the standards.
		Outlet	7.3	7	6	24	1.2	0.9	0.8	220	
		OLMS	7.43	5.96	4.95	24.44	-	1.62	-	-	
Total 30											

Shweta

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

[Signature]

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)




Report Number: DPCC/W/STP/25-26/94/2054

Dated 01/08/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2025

1. Name of STP : Molarband (Mini STP)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 02.07.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results :											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	0.66	Inlet	7.2	206	155	392	21.2	7.4	11.1	-	Not meeting the standard wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.3	31	20	60	1.6	1.3	1	310	
		OLMS	-	-	-	-	-	-	-	-	OLMS was non functional
Total 0.66											


I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)


Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/45/2055

Dated 01/08/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2025

1. Name of STP : Vasant Kunj
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 03.07.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	2.2	Inlet	7.7	188	140	440	12.8	8	12.1	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.6	24	20	80	1.2	0.8	0.8	5800	
		OLMS	8.31	25.55	18.79	80.02	-	9.41	-	-	
2	3	Inlet	7.4	178	150	452	15.6	8.8	9.7	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.3	22	16	56	0.8	0.7	0.5	28000	
		OLMS	8.01	14.16	19.24	46.19	-	4.93	-	-	
Total 5.2											

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/96/2056

Dated 01/08/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2025

1. Name of STP : Mehrauli
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 03.07.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	15	Inlet	7.5	192	110	448	18.4	10.2	11.7	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.2	25	18	56	1.6	0.7	1.1	2300	
		OLMS	8.09	14.27	8.95	44.09	-	5.36	-	-	
Total 15											

Shweta

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

[Signature]
Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/ 97/ 2057

Dated 01/08/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2025

1. Name of STP : Yamuna Vihar
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 04.07.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results:

5. Parameters analyzed and results.											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	10 Ph-1	Inlet	7.4	272	210	444	32	11.8	11.2	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform
		Outlet	7.1	33	25	52	1.2	0.9	1	840	
		OLMS	7.50	16.78	6.42	36.79	-	21.77	-		
2	15 Ph-2	Inlet	7.6	284	170	440	31.2	12.3	11.8	-	Meeting the standards.
		Outlet	7.3	8	7	32	1.6	1	0.9	130	
		OLMS	7.65	8.98	6.84	20.35	-	22.67	-		
Total 20											

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)




Report Number: DPCC/W/STP/25-26/ q3/ 2058


Dated 01/08/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2025

1. Name of STP : Yamuna Vihar Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 04.07.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	25	Inlet	7.5	196	130	396	31.6	8.2	11.3	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.4	22	25	64	1.6	0.4	1.2	950	
		OLMS	7.71	32.54	16.69	69.87	-	27.70	-	-	
Total 25											


I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)


Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/99/2059

Dated 01/08/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2025

1. Name of STP : Sonia Vihar
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 04.07.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	7	Inlet	7.2	196	145	304	27.2	6.8	4.5		Not meeting the Standards wrt. Fecal Coliform.
		Outlet	7.3	10	9	32	2.4	0.5	1.8	270	
		OLMS	8.0	9.30	6.80	36.10	-	0.82	-	-	
Total 7											

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/100/2060

Dated 02/08/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY -2025

1. Name of STP : Narela
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 07.07.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	10	Inlet	7.6	188	150	336	13.2	10.5	5.9	-	Meeting the standards.
		Outlet	7.2	9	7	36	0.8	0.8	0.8	110	
		OLMS	7.35	4.96	6.95	20.52	-	11.82	-	-	
Total 10											

Shweta Gupta

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

[Signature]

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/101/2061

Dated 01/08/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2025

1. Name of STP : Kapasahera
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 07.07.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results:

5. Parameters analyzed and results.

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	5	Inlet	7.3	212	165	392	15.2	10	9.2	-	Not meeting the Standard wrt.Fecal Coliform.
		Outlet	7.4	8	7	44	1.2	1.3	0.8	350	
		OLMS	7.50	9.16	8.77	47.18	-	4.88	-	-	
Total 5											

Shweta Gupta

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

Scientist B

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/102/2022

Dated 01/08/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2025

1. Name of STP : Pappankalan (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 07.07.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	20	Inlet	7.8	200	170	360	16	12.8	5.4	-	Meeting the standards.
		Outlet	7.2	6	8	20	1.6	0.8	0.9	110	
		OLMS	7.73	14.11	9.16	61.65	-	1.87	-	-	
Total 20											

Shweta

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

[Signature]

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/103/2063

Dated 01/08/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2025

1. Name of STP : Pappankalan Ph-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 07.07.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
	40	Inlet	7.8	200	170	360	16	12.8	5.4	-	Meeting the standards.
Outlet		7.6	8	7	32	1.2	0.9	0.7	110		
OLMS		7.7	6.2	6.5	32.5	-	1.8	-	-		
Total 20											

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



Dated 01/08/2025

Report Number DPCC/W/STP/25-26/104/2064

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2025

1. Name of STP : Najafgarh
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 07.07.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Fecal Coliform MPN/100ml	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)		
			6.5-9.0	10	10	50	10	5	2	230	
1	5	Inlet	7.6	224	110	368	14.4	9.9	4.7	-	Meeting the standards.
		Outlet	7.2	9	6	32	1.6	0.8	1	79	
		OLMS	7.27	5.70	6.00	27.50	-	2.63	-	-	
Total 5											

Shweta

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/105/2065

Dated 02/08/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY -2025

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of sampling : 08.07.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Ph-I,II (20)	Inlet	7.7	194	115	276	12.4	12.1	5.2	-	Meeting the standards.
		Outlet	7.9	8	7	20	1.2	0.3	0.8	140	
		OLMS	7.60	6.97	4.98	24.57	-	1.43	-	-	
2	Ph-III (10)	Inlet	7.5	206	95	208	17.2	11.9	10.1	-	Meeting the standards.
		Outlet	7.8	5	6	16	0.8	0.7	1.1	210	
		OLMS	7.69	7.20	4.91	24.61		1.34	-	-	
Total 30											

Shweta

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

[Signature]

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/106/2066

Dated 01/08/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2025

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of sampling : 08.07.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	70 MGD	Inlet	7.3	152	110	268	17.6	10.6	4.5	-	Meeting the standards.
		Outlet	7.4	9	8	20	0.8	0.7	1	210	
		OLMS	7.41	6.59	5.81	32.44	-	1.79	-	-	
Total 70											

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/107/2017

Dated 01/08/2015

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2025

1. Name of STP : Nilothi
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 08.07.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	40	Inlet	7.6	198	135	380	14	11	12.2	-	Not meeting the standards wrt. Fecal Coliform.
		Outlet	7.5	6	7	36	1.2	0.5	0.6	250	
		OLMS	7.65	9.94	7.66	47.18	-	2.64	-	-	
Total 40											

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/25-26/108/2068

Dated 01/08/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2025

1. Name of STP : Nilothi New
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 08.07.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	20	Inlet	7.3	135	115	268	16.4	11.2	9.4	-	Meeting the Standards.
		Outlet	7.8	7	8	20	0.8	1	0.6	140	
		OLMS	7.61	6.14	5.76	36.62		4.17	-	-	
Total 20											

Shweta

I/C Water Laboratory

Dr. Shweta Gupta

Incharge (Water Laboratory)

Scientist B

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/109/2069

Dated 01/08/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2025

1. Name of STP : Keshopur
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 08.07.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	60	Inlet	7.4	214	150	336	16.8	10.9	8.9	-	Meeting the Standards.
		Outlet	7.3	7	7	32	1.6	0.8	1.8	95	
		OLMS	7.70	35.41	3.56	75.30	-	3.89	-	-	
2	20	Outlet	7.9	5	6	24	1.2	0.6	0.6	120	Meeting the Standards.
		OLMS	7.52	6.98	6.24	23.57	-	3.19	-	-	
Total 60											

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/110/2070

Dated 01/08/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2025

1. Name of STP : Keshopur STP (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 08.07.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	12	Inlet	7.6	144	135	312	17.6	10.6	5.2	-	Meeting the standards.
		Outlet	7.3	7	6	28	0.8	0.7	0.8	110	
		OLMS	-	-	-	-	-	-	-	-	Non-Operational
Total 12											

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

Scientist B/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/III/2071

Dated 01/08/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2025

1. Name of STP : Delhi Gate (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 09.07.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results											
S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Ph-I & II (2.2)	Inlet	7.6	158	130	268	32	12.1	5	-	Not meeting the standards wrt. Fecal Coliform.
		Outlet	7.1	6	6	24	1.6	0.3	0.9	280	
		OLMS	8.71	9.25	5.96	26.76		1.95			
Total 2.2											

I/C Water Laboratory

Dr. Shweta Gupta

Incharge (Water Laboratory)

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)




Report Number: DPCC/W/STP/25-26/112 | 2072


Dated 01/08/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2025

1. Name of STP : Delhi Gate (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 09.07.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Phase-I & II (15)	Inlet	7.3	180	130	324	28.4	11.1	4.7	-	Meeting the standards.
		Outlet	7.4	7	5	20	0.8	0.9	0.5	170	
		OLMS	7.38	6.62	5.56	22.66		2.13			
Total 15											


I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)


Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/113/2073

Dated 05/08/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2025

1. Name of STP : SEN Nursing Home (SNH)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 09.07.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results.											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Phase-I,II (2.2)	Inlet	7.8	186	150	316	31.6	9.3	4.7	-	Meeting the Standards.
		Outlet	7.5	8	7	28	1.2	0.8	0.6	140	
		OLMS	7.48	6.54	2.76	20.38	-	2.45	-	-	
Total 2.2											

Shweta
I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

[Signature]
Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)




Report Number: DPCC/W/STP/25-26/114/2074


Dated 01/08/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2025

1. Name of STP : Kondli
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 09.07.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Ph-I (10)	Inlet	7.2	94	120	304	20.4	10.3	4.7	-	Meeting the standards
		Outlet	7.3	9	10	48	1.6	0.8	1	190	
		OLMS	7.72	6.40	6.90	31.30	-	2.31	-		
2	Ph-II & III (25+10)	Outlet	7.1	11	8	32	0.8	0.8	0.9	270	Not meeting the Standard wrt TSS & Fecal Coliform.
		OLMS	7.61	7.10	8.10	63.10	-	2.04			
Total 45											


I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)


Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/11S/2075

Dated 01/08/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2025

1. Name of STP : Kondli New
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 09.07.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Ph-IV (45)	Inlet	7.4	102	123	292	24	11.6	4.2	-	Meeting the standards.
		Outlet	7.6	8	10	36	2	1.2	0.7	170	
		OLMS	7.43	17.30	9.90	56.80	-	3.91	-	-	
Total 45											

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)




Report Number: DPCC/W/STP/25-26/116/2076

Dated: 01/08/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2025

1. Name of STP : Rithala
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 11.07.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Ph-I(40)	Inlet	7.7	182	115	316	22.8	8.5	8.9	-	Meeting the standards
		Outlet	7.2	9	8	32	1.6	0.8	0.6	190	
		OLMS	7.18	8.87	7.09	32.52	-	2.07	-	-	
2	Ph-II(40)	Inlet	7.1	176	110	352	12.8	10.2	9.3	-	Meeting the standards
		Outlet	7.3	6	10	36	2.8	0.8	0.7	84	
		OLMS	7.49	8.29	7.34	35.73	-	3.19	-	-	
Total 80											


I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)


Scientist B/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number DPCC/W/STP/25-26/117/2027

Dated 01/08/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY -2025

1. Name of STP : Rohini
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 11.07.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	15	Inlet	7.1	194	155	348	11.6	9.3	9	--	Meeting the standards.
		Outlet	7	10	7	36	1.2	0.5	0.6	180	
		OLMS	7.43	7.42	3.55	21.14	-	2.06	-	-	
Total 15											

Shweta

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

[Signature]

Scientist B/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/25-26/118/2078

Dated 02/08/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2025

1. Name of STP : Ghtorini
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 16.07.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results .

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	5	Inlet	7.6	212	160	412	12.4	12.8	11.7	-	Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.7	36	20	56	1.6	1	1.1	13000	
		OLMS	7.33	22.19	13.00	50.72	-	5.39	-	-	
Total 5											

Shweta

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

[Signature]

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/119/2079

Dated 01/08/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2025

1. Name of STP : Akshardham
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 16.07.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	1	Inlet	7.3	210	170	344	12.4	12.1	4.2	-	Meeting the Standards.
		Outlet	7.1	5	6	24	1.6	0.6	0.9	95	
		OLMS	7.52	0.66	1.57	7.54	-	0.54			
Total 1											

Shweta

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

[Signature]

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/120/2020

Dated 01/08/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2025

1. Name of STP : Chilla
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 16.07.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results:

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	9	Inlet	7.2	108	115	304	12.8	11.9	5.8	-	Meeting the Standards.
		Outlet	7.5	8	7	28	2	0.7	1.7	110	
		OLMS	7.4	6.8	5.39	32.9	-	2.08		-	
Total 9											

Shweta
I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

[Signature]
Scientist B /Analyst