

05/10/2023
05/10/2023



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi, 4th & 5th Floor, ISBT Building,
Kashmere Gate, Delhi 110006)
(Visit us at <https://www.dpccnms.nic.in>)



Report Number: DPCC/W/STP/23-24/131 /311

Dated 26.9.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2023

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 18.09.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	Ph-I,II (20)	Standard	6.5-9.0	10	10	50	10	5	2	Not meeting the standards w.r.t TSS, BOD & COD. OLMS was non-functional
		Inlet	7.6	300	110	304	8	25.1	16.3	
		Outlet	7.5	30	19	56	2	1.5	1.4	
		OLMS	-	-	-	-	-	-	-	
2	Ph-III (10)	Inlet	7.2	236	120	272	8.4	24.2	15.5	Not meeting the standards w.r.t TSS, BOD & COD. OLMS was non-functional
		Outlet	7.6	24	13	57	2.4	1.8	1.6	
		OLMS	-	-	-	-	-	-	-	
		Total 30	-	-	-	-	-	-	-	

05/10/2023
05/10/2023

for I/C LABORATORY
ANAND KUMAR MEENA
Junior Environmental Engineer



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, JSPT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/132/312

Dated 29/9/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2023

1. Name of STP : Delhi Gate (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.09.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters										Remarks
Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	Phase-LII(15)	Inlet	7.2	140	95	80	2	21.6	9.6	Meeting the Standards.
		Outlet	7.4	6	4	24	1.2	1.2	0.9	
		OLMS	7.1	6.9	3.7	26.6	-	0.2	-	
Total 15										

I/C LABORATORY

Dr. Nandita Mishra

Scientist IV

N Mishra



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccommission.in>)



Report Number: DPCC/M/STP/23-24/133/313

Dated: 29.9.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2023

1. Name of STP : Delhi Gate (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.09.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
Phase-I,II(2.2)		Inlet	7.3	157	135	176	4	23.2	11.3	Meeting the Standard.
		Outlet	7.2	8	6	16	1.6	2	1.1	
		OLMS	7.3	5.2	2.1	15.7	-	1.1	-	
Total 2.2										

I/C LABORATORY

Dr. Nandita Mittal
Scientist 'V'

N. Mittal



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/134/314

Dated: 29.9.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2023

1. Name of STP : Keshopur STP (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.09.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	12	Inlet	6.5-9.0	10	10	50	10	5	2	Not Meeting the standards wrt TSS, BOD & COD.
			7.5	240	160	352	17.2	20.3	20.5	
			7.2	18	12	52	1.6	1.3	1.1	
			OLMS	7.7	8.1	5.9	30.6	-	2.8	
Total 12										

M. Mohan
I/C LABORATORY
Dr. Nandita Moitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, JSBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccenms.nic.in>)



Report Number: DPCC/W/STP/23 24/135/315

Dated 29.9.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2023

1. Name of STP : SEN Nursing Home (SNH)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.09.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters										Remarks
Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	Phase-I,II (2.2)	Inlet	7.3	244	175	224	4.8	21.5	19.2	Meeting the Standards
		Outlet	7.5	10	6	20	2.8	1.5	1.3	
		OLMS	7.3	5.9	4.2	24.6	-	1.6	-	
		Total 2.2								

W/ LABORATORY
Dr. Nandini Mishra

Signature

N Mishra



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/136/316

Dated 29.9.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2023

1. Name of STP : Nilothi New
2. Sampling location : Inlet and Outlet of STP
3. Date of inspection : 18.09.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	20	Inlet	7.4	168	135	336	13.6	12.1	11.5	Meeting the standards
		Outlet	7.8	10	8	36	3.2	1.5	1.3	
		OLMS	7.3	31.9	51.8	138.5	-	12.8	-	
Total 20										

Nilothi
Dr. K. S. ABHINAV
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/137/B17 (317)

Dated 29.9.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2023

1. Name of STP : Nilothi
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.09.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	40	Inlet	6.5-9.0	10	10	50	10	5	2	Not meeting the standards wrt TSS, BOD & COD.
			7.6	240	110	320	17.2	24.5	28.6	
		Outlet	7.3	40	27	72	4.8	2.6	1.8	
			OLMS	7.5	8.4	5.5	37.1	-	4.3	
Total 40										

W. S. LABORATORY
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number DPCC/W/STP/23-24/138 /3/18

Dated 29/9/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2023

1. Name of STP : Najafgarh
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.09.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	5	Inlet	7.5	260	110	288	13.4	26.4	11.2	Not meeting the standards wrt TSS, BOD and COD
		Outlet	7.8	30	24	76	1.1	2.5	1.5	
		OLMS	7.3	71.0	15.0	84.0	-	15.5	-	
Total 5										

I/C LABORATORY

Dr. Nandita Mohita

Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/M/STP/23-24/139/319

Dated: 29.9.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2023

1. Name of STP : Rithala
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 12.09.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	Ph-I(40)	Inlet	6.5-9.0	10	10	50	10	5	2	Plant was under Rehabilitation
		Outlet	-	-	-	-	-	-	-	
		OLMS	-	-	-	-	-	-	-	
2	Ph-II(40)	Inlet	7.5	280	130	320	17.6	10.6	1/6	Meeting the standards
		Outlet	7.3	8	5	28	2.8	2.5	1.3	
		OLMS	7.4	9.6	7.4	35.5	-	8.4	-	
Total 80										

M. Kishor
Dr. Meenakshi
Scientist IV



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/140 / 320

Dated 29.9.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2023

1. Name of STP : Pappankalan (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of inspection : 14.09.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results : :

5. Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	20	Inlet	7.5	180	110	304	16	20.2	25.4	Not meeting the Standards wrt TSS, BOD COD & Dissolved Phosphate.
		Outlet	7.4	22	15	64	3.2	2.1	2.4	
		OLMS	7.4	6.9	6.0	50.7	-	1.7	-	
Total 20										

I/C LABORATORY MOITRA

Scientist D

N. Mohan



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/141/321

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2023

Dated 29.9.2023

1. Name of STP : Pappankalan Ph-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.09.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters						Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)		Dissolved Phosphate as P (mg/l)
20		Inlet	6.5-9.0	10	10	50	10	5	2	Meeting the Standards. TSS reading not shown in OLMS
			7.5	180	110	304	16	20.2	25.4	
		Outlet	7.6	10	8	36	2.4	1.2	1.3	
		OLMS	7.5	-	21.19	122.47	-	6.8	-	
Total 20										

Dr. NEELABHABHAR
Sahasrabudhe



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, JSBI Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number DPCC/W/STP/23-24/142/322

Dated 29.9.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2023

1. Name of STP : Rohini
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 12.09.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	15	Inlet	7.5	344	175	312	11.2	22.9	13.9	Not meeting the Standard wrt TSS, BOD & COD.
		Outlet	7.1	28	16	64	5.6	3.5	1.9	
		OLMS	7.7	18.0	12.0	54.0	-	9.5	-	
Total 15										

Dr. Nagesh Laboratory

Selected STP



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/143/323

Dated 29.9.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2023

1. Name of STP : Narela
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 12.09.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results :										
Sr. No.	Installed Capacity (MGD)	SFP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	10	Inlet	7.4	172	75	128	5.6	17.2	10.6	Not meeting the standards wrt TSS, BOD & COD.
		Outlet	7.2	22	13	52	1.6	1.3	0.9	
		CLMS	7.5	9.1	7.7	39.6	-	9.5	-	
Total 10										

Dr. Nandita Moitra
Scientist II

N. Moitra

V/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, JSBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocnms.nic.in>)



Dated 29.9.2023

Report Number: DPCC/W/STP/23-24/14/324

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2023

1. Name of STP : Okhla New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 21.09.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters										Remarks
Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			Meeting the Standards.							
1	30	Inlet	7.6	208	120	296	10	16.9	24.5	
		Outlet	7.4	10	7	44	1.6	1.3	1.3	
		OLWS	7.3	5.49	4.17	23.84	-	1.20	-	
Total 30										

DR. N. SATAPATHY
Scientist 'D'

N. Mohan



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



Dated 29.9.2023

Report Number: DPCC/W/STP/23-24/145/325

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2023

1. Name of STP : Kondli
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.09.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

DPCC Lab										
3. Date of Inspection										
4. Samples collected by										
5. Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters						Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)		Dissolved Phosphate as P (mg/l)
1	Ph-I (10)	Inlet	7.1	10	10	50	10	5	2	Meeting the standards.
		Outlet	7.4	8	6	32	2	2.2	1.5	
		OLMS	7.5	10.5	5.8	39.9	-	7.7	1	
2	Ph-II (25)	Outlet	7.5	8	5	32	0.8	1.6	1	OLMS was non-functional Meeting the standards.
		OLMS	-	-	-	-	-	-	-	
		OLMS	-	-	-	-	-	-	-	
3	Ph-III (10)	Outlet	7.2	6	5	24	4	1.9	1.4	Meeting the standards.
		OLMS	-	-	-	-	-	-	-	
		OLMS	-	-	-	-	-	-	-	
Total 45			7.4	9.6	5.6	28.2	-	3.6	-	

Al Mark

Dr. Nigam Laboratory
Scientist D
Nigam



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISRT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpecommis.nic.in>)



Report Number: DPCC/W/STP/23-24/146 | 326

Dated 29.9.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2023

1. Name of STP : Kondli New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.09.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results :										Remarks
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
		6.5-9.0	10	10	50	10	5	2		
1	Ph-IV (45)	Inlet	7.1	164	150	208	5.6	21.2	23.6	Not Meeting the Standards wrt TSS ,BOD & COD.
		Outlet	7.4	28	14	60	1.6	1.6	1.2	
		OLMS	-	-	-	-	-	-	-	
Total 45										OLMS was non-functional

Dr. Nandini Arora
Scientist 'D'

Nandini



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/147/327

Dated 29.9.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2023

1. Name of STP : Kapasahera
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 06.09.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	5	Inlet	7.4	212	78	224	4.4	24.3	11.9	Not Meeting the standards wrt TSS & BOD.
		Outlet	7.1	18	14	48	2.4	2	1.2	
		OLMS	7.5	9.7	7.1	37.8	-	3.3	-	
Total 5										

NM Sharma

W/C LABORATORY
Dr. Nandini Mishra

Scientist D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, JSRT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccoms.nic.in>)



Report Number: DPCC/W/STP/23-24/148 / 3-2-8

Dated 29.9.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2023

1. Name of STP : Yamuna Vihar Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.09.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

4. Samples collected by											
5. Parameters analyzed and results											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved phosphate as P (mg/l)		
1	25	Inlet	7.1	216	135	184	6.4	19.2	27.8	Not meeting the Standards wrt TSS & BOD.	
			Outlet	7.3	28	17	48	2.4	1.9		1.6
			OLMS	7.3	8.1	5.1	25.3	-	2.8		-
Total 25											

Dr. Nandita Mishra
Secretary



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building,

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/5.19/23-24/149/329

Dated 29.9.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2023

1. Name of STP : Chilla
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.09.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

4. Samples collected	Parameters analyzed and results	Parameters										Remarks
5.		STP Standard	pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)			
Sr. No.	Installed Capacity (MGD)	6.5-9.0		10	10	50	10	5	2			
1	9	Inlet	7.4	184	82	128	4.8	21.7	11.9		Meeting the Standards.	
		Outlet	7.6	10	6	24	2.4	2.5	1.2			
		OLWS	7.1	6.6	3.8	27.6	-	1.5	-			
Total 9												

Dr. Nigam Laboratory

Signature

Nigam



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nctc.in>)



Report Number: DPCC/W/STP/23-24/150/330

Dated 29.9.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2023

1. Name of STP : Akshardham
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.09.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	1	Inlet	6.5-9.0	10	10	50	10	5	2	Meeting the Standards.
			7.1	274	100	240	6	3.2	18.5	
			7.3	6	5	20	1.2	0.8	1	
		Outlet	7.3	6	5	20	1.2	0.8	1	
		OLMS	7.2	0.9	1.6	7.3		0.03	-	
Total 1										

166 LABORATORY
Dr. Mandita Mondal
Scientist (I)

Mandita



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Dated 29.9.2023

Report Number: DPCC/W/STP/23-24/151 | 33 |

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2023

1. Name of STP : Mehrauli
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 06.09.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

4.	Samples collected by									
5.	Parameters analyzed and results :									
Parameters										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Remarks
1	15	Inlet	7.4	180	100	272	4.4	11.2	22.6	Not meeting the standards wrt TSS, BOD & COD. BOD & COD readings not shown in OLMS
		Outlet	7.1	36	24	64	1.2	1.9	1.1	
		OLMS	7.5	15.6	-	-	-	10.7	-	
Total 15										

Dr. Nandita Mehta
Scientist TP
I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Dated 29.9.2023

Report Number: DPCC/W/STP/23-24/152 | 332

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2023

1. Name of STP : Vasant Kunj
2. Sampling location : Inlet and Outlet of STP
3. Date of inspection : 06.09.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

4. Samples collected by : DPCC Lab										
5. Parameters analyzed and results :										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	2.2		6.5-9.0	10	10	50	10	5	2	Not meeting the standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Inlet	7.3	264	160	288	17.8	19.2	25.9	
		Outlet	7.2	36	23	64	2.2	2.1	3.1	
		OLMS	7.4	7.9	5.8	33.5	-	3.8	-	
2	3		7.6	252	140	336	4	19.2	23.6	Not meeting the standards wrt TSS, BOD & COD.
		Inlet	7.1	30	20	56	1.6	3.6	1.9	
		Outlet	7.2	7.3	4.4	25.9	-	3.4	-	
		OLMS								
Total 5.2										

N. Nandita

Dr. Nandita Moitra

Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



Dated 29.09.2023

Report Number: DPCC/W/STP/23-24/153 333

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2023

1. Name of STP : Yamuna Vihar
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.09.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results										Remarks
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	10 Ph-1	Inlet	6.5-9.0	10	10	50	10	5	2	Not meeting the standards wrt TSS & BOD.
		Inlet	7.4	184	85	104	6	15.8	23.9	
		Outlet	7.2	20	12	44	1.6	2.4	1.7	
2	10 Ph-2	OLMS	7.2	13.3	8.5	60.4	-	12.8	-	Not meeting the standard wrt TSS, BOD, COD & Dissolved Phosphate.
		Inlet	7.2	128	90	192	8	14.3	20.3	
		Outlet	7.6	20	14	64	1.6	1.6	2.1	
Total 20		OLMS								

Dr. NARESH KUMAR
Scientist 'D'

Naresh Kumar



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



Dated 29/9/2023

Report Number: DPCC/W/STP/23-24/154/334
ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2023

1. Name of STP : Okhla
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 21.09.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters										Remarks
Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	12	Inlet	6.5-9.0	10	10	50	10	5	2	Not meeting the Standards wrt TSS, BOD & COD.
		Outlet	7.4	224	140	384	8.4	18.3	14.6	
		OLMS	7.1	18	13	56	1.2	1.2	1.5	Meeting the Standard.
		Outlet	7.7	26.48	13.67	63.22	-	26.05	-	
		OLMS	7.5	8	6	28	0.4	2.1	1.3	
1	16	Outlet	7.8	9.26	6.33	26.28	-	3.58	-	Not meeting the Standards wrt TSS, BOD & COD.
		OLMS	7.3	26	18	48	0.8	2.3	1.4	
		Outlet	7.2	28.68	17.95	86.53	-	10.58	-	Not meeting the Standards wrt TSS, BOD & COD.
		OLMS	7.4	30	26	72	2.4	2.4	1.2	
		OLMS	7.5	34.43	16.28	73.87	-	15.52	-	
Total 110										

N. Mehta
V. Chhabra
Laboratory
Scientist D



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



Dated 29.9.2023

Report Number: DPCC/W/STP/23-24/6 / 335

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2023

1. Name of STP : Molarband (Mini STP)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 21.09.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

4. Samples collected by										
5. Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	0.66		6.5-9.0	10	10	50	10	5	2	Not meeting the Standards wrt TSS, BOD, COD & Dissolved phosphate.
		Inlet	7.8	284	145	368	6.8	23.5	16.3	
		Outlet	7.6	38	19	72	2.8	1.9	2.1	
		CLMS	7.6	22.28	15.9	72.4	-	12.52	-	
Total 0.66										

N Nishu
Dr. Nandita Moitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/155/336

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2023

Dated 29.9.2023

1. Name of STP : Keshopur
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.09.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results :										Remarks
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	40	Inlet	6.5-9.0	10	10	50	10	5	2	Not meeting the Standards wrt TSS, BOD & COD.
		Inlet	7.4	196	135	192	16	24.2	20.3	
		Outlet	7.5	24	16	68	1.6	1.9	1.1	
		OLMS	8.0	108	80	296	-	2.8	-	
2	20	Inlet	7.4	196	135	192	16	24.2	20.3	Not meeting the Standards wrt TSS, BOD & COD.
		Outlet	7.3	20	14	56	2	4.1	1.1	
		OLMS	7.1	69.0	32.91	161.6	-	12.8	-	
		Total 60								

Dr. Manjula Mathur
Secretary

Manjula Mathur



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



Dated 29.9.2023

Report Number: DPCC/W/STP/23-24/156/237

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2023

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 22.09.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

4. Samples collected by										
5. Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	Ph- (70)	Inlet	7.3	248	150	384	10.8	22.5	26.4	Meeting the standards: pH & Ammonical Nitrogen readings not shown in OLMS
		Outlet	7.6	10	7	32	2.3	2.8	1.6	
		OLMS	-	8.3	3.5	31.9	-	-	-	
Total 70										

Dr. Nankhata Laboratory
Scientist IV

Nankhata



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, JSBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Dated 29.9.2023

Report Number: DPCC/W/STP/23-24/157/338
ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2023

1. Name of STP : Ghitorni
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 06.09.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters						Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)		Dissolved Phosphate as P (mg/l)
1	5		6.5-9.0	10	10	50	10	5	2	Not meeting the Standards wrt TSS & BOD.
		Inlet	7.4	104	42	64	4.8	17.8	23.6	
		Outlet	7.5	32	17	48	2	1.1	1.8	
		OLMS	7.4	18.1	14.4	42.3	-	10.1	-	
Total 5										

Nirula
Dr. Nand Lal
Scientist