



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/225/1518

Dated 06.01.2025

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2024

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 13.12.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	70 MGD	Inlet	7.4	160	89	268	14.8	21.4	22.6	-	Not meeting the standards wrt Fecal Coliform.
		Outlet	7.1	9	8	28	1.2	1.7	1.3	1500	
		OLMS	6.4	10.9	3.2	40.5	-	1.3	-	-	
Total 70											

Dr. NANDITA MOITRA
Scientist-D
I/C Water Laboratory

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/24-25/226/1519

Dated 06.01.2025

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2024

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 13.12.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Fecal Coliform MPN/100ml	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)			
1	Ph-I,II (20)	Inlet	7.5	234	150	316	14.8	22.8	21.4	-	Meeting the standards.	
		Outlet	7.4	9	7	36	1.6	2.1	1.4	220		
		OLMS	7.9	7.5	4.9	26.5	-	0.08	-	-		
		Inlet	7.3	246	125	324	17.2	23.6	20.8	-		
2	Ph-III (10)	Outlet	7.6	8	6	28	1.2	1.4	1.5	84	Meeting the standards.	
		OLMS	-	-	-	-	-	-	-	-	OLMS was non-functional	
Total 30												

I/C Water Laboratory

Scientist-D

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/227/1520

Dated 06.01/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2024

1. Name of STP : Delhi Gate (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.12.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	Phase-I & II (15)	Inlet	7.6	166	83	276	19.2	15.2	18.6	-	Meeting the Standards.
		Outlet	7.1	7	6	28	1.6	2.3	1.2	92	
		OLMS	7.0	7.5	3.8	23.5	-	2.7	-	-	
Total 15											

NMitra
I/C Water Laboratory
J. NANDIA MOITRA
Scientist-D

SSA
SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, JSBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/228/152

Dated 06.01.2025

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2024

1. Name of STP : Delhi Gate (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.12.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	Ph-I & II (2.2)	Inlet	7.4	204	133	280	16.4	16.4	18.3	-	Not meeting the standards wrt Fecal Coliform.
		Outlet	7.2	6	5	32	1.2	1.4	1.6	1800	
		OLMS	7.5	3.7	2.5	15.1	-	1.4	-	-	
Total 2.2											

M. Nisha

SSA/Analyst/SLA

I/C Water Laboratory
Scientist-D
SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/229/1522

Dated 06.01.2025

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2024

1. Name of STP : Keshopur STP (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.12.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)		Fecal Coliform MPN/100ml
1	12	Inlet	7.5	234	150	328	13.2	22.6	23.8	-	Not meeting the standards wrt TSS, BOD, COD & fecal coliform.
		Outlet	7.2	27	18	68	1.6	2.4	1.3	1200	
		OLMS	7.5	8.3	5.6	33.2	-	3.5	-	-	
Total 12											

I/C Water Laboratory
Scientist-D

Signature

SSA/Analyst/SLA

Signature

Dr. NANDITA MOITRA
Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/230/) S23

Dated 06.01.2025

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2024

1. Name of STP : SEN Nursing Home (SNH)
2. Sampling Location : Inlet and Outlet of STP
3. Date of Inspection : 19.12.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	Phase-I,II (2.2)	Inlet	7.3	188	150	272	23.2	15.2	18.1	-	Not meeting the standards wrt Fecal Coliform.
		Outlet	7.4	5	3	36	0.8	1.6	1.1	330	
		OLMS	7.4	5.7	5.1	22.4	-	1.2	-	-	
Total 2.2											

I/C Water Laboratory

SSA/Analyst/SLA

Dr. NANDITA MOITRA
Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/231/1524

Dated 06/01/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2024

1. Name of STP : Nilothi New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.12.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results											Remarks
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	20	Inlet	7.6	252	183	288	15.6	13.6	15.4	-	Meeting the standards.
		Outlet	7.3	7	6	36	1.2	2.1	1.6	120	
		OLMS	7.7	6.5	4.1	38.2	-	3.7	-	-	
Total 20											

I/C Water Laboratory

SSA/Analyst/SLA

Dr. NANDITA MOITRA

Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/24-25/232/1525

Dated 06.01.2025

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2024

1. Name of STP : Nilothi
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.12.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters									Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml		
1	40	Inlet	7.3	228	180	300	23.2	15.6	21.6		Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.	
		Outlet	7.1	31	16	92	1.6	2.4	1.8	1400		
		OLMS	6.6	19.4	13.2	90.6	-	28.4	-	-		
Total 40												

I/C Water Laboratory
Scientist-D

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number DPCC/W/STP/24-25/233/1526

Dated 06.01.2025

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2024

1. Name of STP : Najafgarh
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.12.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Fecal Coliform MPN/100ml	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
1	5	Inlet	7.6	234	175	284	21.2	18.6	22.6	-	Meeting the standards.
		Outlet	7.2	9	6	40	0.8	0.9	0.7	84	
		OLMS	-	-	-	-	-	-	-	-	
Total 5											OLMS was non functional

Mishra

SSA

I/C Water Laboratory MOITRA
Scientist-D

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/234/JS27

Dated: 06.01.2025

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2024

1. Name of STP : Rithala
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.12.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters									Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml		
1	Ph-I(40)	Inlet	7.4	204	150	276	17.2	17.3	23.8	-	Meeting the standards	
		Outlet	7.2	6	5	28	1.2	2.1	1.6	110		
		OLMS	-	-	-	-	-	-	-	-		
2	Ph-II(40)	Inlet	7.5	134	100	232	14.4	19.2	24.2	-	Meeting the standards	
		Outlet	7.2	7	6	36	2.8	2.4	1.5	140		
		OLMS	7.2	6.8	4.9	27.8	-	4.9	-	-		
Total 80												

Signature

I/C Water Laboratory
Dr. NANDITA MOITRA
Scientist-D

SSA/Analyst/SLA

Signature



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/235/528

Dated 06.01.2025

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2024

1. Name of STP : Pappankalan (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.12.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	20	Inlet	7.3	266	200	304	14.4	17.6	19.6	-	Not meeting the Standards wrt TSS, BOD COD & Fecal Coliform.
		Outlet	7.1	32	17	72	1.2	1.4	1.6	1400	
		OLMS	6.9	-	-	-	-	21.2	-	-	
Total 20											

I/C Water Laboratory
Dr. NANDITA MOITRA
Scientist-D

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocems.nic.in>)



Report Number: DPCC/W/STP/24-25/236/1529

Dated 06.01.2025

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER -2024

1. Name of STP : Pappankalan Ph-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.12.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
20		Inlet	7.3	266	200	304	14.4	17.6	19.6	-	Not meeting the standards wrt Fecal Coliform.
		Outlet	7.4	8	6	24	0.8	1.3	1.1	1100	
		OLMS	6.6	6.3	4.9	28.9	-	1.3	-	-	
Total 20											OLMS was non functional

I/C Water Laboratory

Dr. NANDITA MOITRA

Scientist-D

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocnms.nic.in>)



Report Number DPCC/W/STP/24-25/237/1530

Dated 06.01.2025

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER -2024

1. Name of STP : Rohini
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.12.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	15	Inlet	7.3	214	143	268	18.8	19.2	21.6	-	Meeting the standards.
		Outlet	7.1	5	4	36	0.8	1.9	1.3	79	
		OLMS	-	-	-	-	-	-	-	-	
Total 15											OLMS was non functional

I/C Water Laboratory

Dr. NANDITA MOITRA
Scientist-D

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/238/1531

Dated 06.01.2025

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER -2024

1. Name of STP : Narela
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.12.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	10	Inlet	6.5-9.0	10	10	50	10	5	2	230	Meeting the standards.
		Outlet	7.6	186	157	232	24.4	18.2	21.5	-	
		OLMS	7.3	8	7	32	1.6	2.3	1.6	43	
Total 10			7.8	6.0	4.4	18.0	-	1.2	-	-	

I/C Water Laboratory

Dr. NANDITA MOITRA
Scientist-D

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocemms.nic.in>)



Report Number: DPCC/W/STP/24-25/239/1532

Dated 06.01.2025

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER -2024

1. Name of STP : Okhla New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 16.12.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	30	Inlet	7.3	252	140	300	20.8	17.6	19.4	-	Meeting the Standards.
		Outlet	7.7	8	7	28	1.2	1.8	1.4	190	
		OLMS	7.2	7.0	4.8	24.0	-	1.3	-	-	
Total 30											

I/C Water Laboratory
Dr. NANDITA MOITRA
Scientist-D

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/24-25/240/1533

Dated 06.01.2025

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER -2024

1. Name of STP : Kondli
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.12.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	Ph-I (10)	Inlet	7.4	208	120	264	16.4	20.8	19.8	-	Meeting the standards.
		Outlet	7.3	6	4	32	0.8	1.3	1.5	95	
		OLMS	-	-	-	-	-	-	-	-	
2	Ph-II & III (25+10)	Outlet	7.5	7	6	28	1.6	1.5	1.3	180	Meeting the standards
		OLMS	-	-	-	-	-	-	-	-	
Total 45											

Maitra

Alankar

I/C Water Laboratory
ANINDITA MOITRA
Scientist-D

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/241/1534

Dated 06.01.2025

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER -2024

1. Name of STP : Kondli New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.12.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters											Remarks
Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	Ph-IV (45)	Inlet	7.6	201	140	256	14.4	21.4	22.1	-	Meeting the Standards.
		Outlet	7.5	6	5	36	2.4	1.4	1.9	150	
		OLMS	-	-	-	-	-	-	-	-	-
Total 45											

Murika
I/C Water Laboratory
Dr. NANDITA MOITRA
Scientist-D

SSA
SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/242/1835

Dated 06.01.2025

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER -2024

1. Name of STP : Kapasahera
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 12.12.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

		Parameters										Remarks
Sr. No.	Installed Capacity (MGD)	pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml			
1	5	STP Standard	6.5-9.0	10	10	50	10	5	2	230	Not meeting the Standards wrt TSS, BOD COD & Fecal Coliform.	
		Inlet	7.6	208	125	308	15.2	22.9	23.6			
		Outlet	7.3	27	16	64	1.2	2.1	1.2	1300		
		OLMS	-	-	-	-	-	-	-	-	OLMS was non functional	
Total 5												

I/C Water Laboratory MDITA MOITRA

Scientist-D

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocoms.nic.in>)



Report Number: DPCC/W/STP/24-25/243//536

Dated 06/01/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER -2024

1. Name of STP : Yamuna Vihar Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 04.12.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	25	Inlet	7.6	264	167	276	12.4	22.3	23.5	-	Not meeting the Standards wrt TSS, BOD & COD.
		Outlet	7.2	19	14	76	1.6	2.2	1.6	170	
		OLMS	7.2	18.7	11.0	65.4	-	14.7	-	-	
Total 25											

I/C Water Laboratory

SSA/Analyst/SLA

Dr. NANDITA MOITRA
Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/244/1537

Dated 06.01.2025

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER -2024

1. Name of STP : Chilla
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.12.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	9	Inlet	7.2	212	160	260	17.6	22.3	21.6	-	Meeting the Standards.
		Outlet	7.1	7	4	32	2.4	1.8	1.7	84	
		OLMS	7.1	5.3	3.5	21.2	-	1.9	-	-	
Total 9											

I/C Water Laboratory
MOITRA
Scientist-D

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/245/1538

Dated 06.01.2025

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER -2024

1. Name of STP : Akshardham
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.12.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	1	Inlet	6.5-9.0	10	10	50	10	5	2	230	Meeting the Standards.
		Outlet	7.5	180	133	284	17.2	21.2	19.4	-	
		OLMS	7.3	3	4	28	1.2	1.7	1.2	95	
Total 1			7.6	0.7	1.4	5.6	-	0.1	-	-	

I/C Water Laboratory

SSA/Analyst/SLA

Dr. NANDITA MOITRA
Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/246/1539

Dated 06.01.2025

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER -2024

1. Name of STP : Mehrauli
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 12.12.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	15	Inlet	7.6	268	150	316	14.4	20.7	16.7	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.3	32	16	56	1.2	1.5	1.2	920	
		OLMS	7.2	13.2	5.0	33.5	-	6.5	-	-	
Total 15											

Mishra

I/C Water Laboratory
Dr. NANDITA MOITRA

Scientist-D

SSA/Analyst/SLA

Mishra



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/247/1540

Dated 06.01.2025

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER -2024

1. Name of STP : Vasant Kunj
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 12.12.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	2.2	Inlet	7.1	262	160	272	12.4	21.5	19.8	-	Not meeting the standards wrt TSS,BOD, COD & Fecal Coliform.
		Outlet	7.6	68	36	84	2.4	1.8	1.2	1700	
		OLMS	6.0	6.8	4.8	31.3	-	6.5	-	-	
2	3	Inlet	7.3	296	175	308	19.2	17.3	18.6	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.6	63	38	72	1.6	2.1	1.8	1500	
		OLMS	-	-	-	-	-	-	-	-	
Total 5.2											

I/C Water Laboratory MOITRA

Scientist-D

SSA/AnalystSLA



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocms.nic.in>)



Report Number: DPCC/W/STP/24-25/248/154

Dated 06.01.2025

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2024

1. Name of STP : Yamuna Vihar
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 04.12.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	10 Ph-1	Inlet	6.5-9.0	10	10	50	10	5	2	230	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform
		7.1	230	86	304	15.6	24.1	21.4	-		
		Outlet	7.5	34	16	84	1.6	1.8	1.3	1300	
		OLMS	-	-	-	-	-	-	-	-	OLMS was non functional
		Inlet	7.4	140	200	324	17.2	21.6	22.4	-	
		Outlet	7.2	8	6	36	2.4	1.2	1.7	79	
2	10 Ph-2	OLMS	7.2	6.3	4.2	25.3	-	6.3	-	-	Meeting the standards.
Total 20											

Mishra

Sharma

I/C Water Laboratory
Dr. NANDITA MOITRA
Scientist-D

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocems.nic.in>)



Report Number: DPCC/W/STP/24-25/249/1542

Dated 06.01.2025

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER -2024

1. Name of STP : Molarband (Mini STP)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 16.12.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)		Fecal Coliform MPN/100ml
1	0.66	Inlet	7.7	264	167	312	18.8	20.2	14	-	Not meeting the standard wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.2	30	25	64	2	1.6	1.4	1800	
		OLMS	7.7	28.4	18.7	118.3	-	17.8	-		
Total 0.66											

M. Mitra

SSA/Analyst/SLA

I/C Water Laboratory

SSA/Analyst/SLA

Dr. NANDITA MOITRA

Scientist-D



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/250/543

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER -2024

Dated 06.01.2025

1. Name of STP : Okhla
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 16.12.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	12	Inlet	6.5-9.0	10	10	50	10	5	2	230	No flow and closed.
		Outlet	-	-	-	-	-	-	-	-	
		OLMS	-	-	-	-	-	-	-	-	
	16	Outlet	7.4	8	5	24	2	1.4	1.8	120	Meeting the Standards.
		OLMS	6.4	11.2	5.2	46.9	-	6.5	-	-	
		Outlet	-	-	-	-	-	-	-	-	
	37	OLMS	-	-	-	-	-	-	-	-	OLMS was non functional
		Outlet	-	-	-	-	-	-	-	-	
		OLMS	-	-	-	-	-	-	-	-	
	45	OLMS	-	-	-	-	-	-	-	-	OLMS was non functional
OLMS		-	-	-	-	-	-	-	-		
Total 110											

Mukherjee

SSA

I/C Water Laboratory
Dr. Anita MOITRA
Scientist-D

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocms.nic.in>)



Report Number: DPCC/W/STP/24-25/251/1544

Dated 06.01.2025

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER -2024

1. Name of STP : Keshopur
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.12.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	40	Inlet	6.5-9.0	10	10	50	10	5	2	230	Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.6	230	143	304	25.6	21.8	22.5	-	
		OLMS	7.4	34	23	72	2.8	3.1	1.8	1300	
2	20	Outlet	-	-	-	-	-	-	-	-	OLMS was non functional
		OLMS	7.3	24	16	60	2	2.5	1.2	1900	
		OLMS	-	-	-	-	-	-	-	-	
Total 60											OLMS was non functional

Murika

ABAR

I/C Water Laboratory
Dr. NANDITA MOITRA
Scientist-D

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/252/1545

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER -2024

Dated 06.01.2025

1. Name of STP : Ghitorini
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 12.12.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters											Remarks
Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	5	Inlet	7.7	256	167	288	18.4	15.8	21.4	-	Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.6	55	26	84	1.6	1.2	1.3	2200	
		OLMS	-	-	-	-	-	-	-	-	
Total 5											OLMS was non functional

M. M. M. M.

SSA/Analyst/SLA

I/C Water Laboratory
Dr. NANDITA MOITRA
Scientist-D

SSA/Analyst/SLA