



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/25-26/12/2159

Dated 02-09-25

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2025

1. Name of STP : Chilla
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 05.08.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results:

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	9	Inlet	7.6	158	125	352	16.4	12.9	11.5	-	Meeting the Standards.
		Outlet	7.3	8	7	24	0.8	0.9	0.9	95	
		OLMS	7.39	7.18	5.69	29.94	-	2.02		-	
Total 9											

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/122/2160

Dated 02-08-25

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2025

1. Name of STP : Kondli New
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 05.08.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Ph-IV (45)	Inlet	7.8	218	140	324	13.6	10.8	11.8	-	Meeting the Standards.
		Outlet	7.9	7	6	32	1.2	0.9	0.8	180	
		OLMS	7.55	9.0	5.50	16.50	-	4.16	-	-	
Total 45											

Shweta
I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

[Signature]
Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/25-26/123 / 2161

Dated 02-09-25

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2025

1. Name of STP : Kondli
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 05.08.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Ph-I (10)	Inlet	7.8	224	135	384	12.4	10.2	9.3	-	Meeting the Standards.
		Outlet	7.5	8	7	28	0.8	0.8	0.7	120	
		OLMS	7.61	7.40	6.10	15.60	-	3.97	-		
2	Ph-II & III (25+10)	Outlet	7.4	7	6	28	0.4	1.3	0.4	270	Not meeting the Standard wrt Fecal Coliform.
		OLMS	7.61	7.40	6.10	15.60	-	3.97			
Total 45											

I/C Water Laboratory
Dr. Shwetam
Incharge (Water Laboratory)

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/124 / 2162

Dated: 02-08-25

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2025

1. Name of STP : Rithala
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 06.08.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Ph-I(40)	Inlet	7.5	188	150	344	8.8	8.5	5	-	Meeting the standards
		Outlet	7.2	9	7	32	0.8	0.8	0.9	81	
		OLMS	7.45	9	7.20	33	-	2.10	-	-	
2	Ph-II(40)	Inlet	7.8	212	165	376	13.2	10.2	4.7	-	Meeting the standards
		Outlet	7.7	8	7	36	1.2	0.8	0.5	79	
		OLMS	7.42	8.24	7.29	35.50	-	3.17	-	-	
Total 80											

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

Scientist 'B'/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number DPCC/W/STP/25-26/ 125 / 2163

Dated 02-08-25

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST -2025

1. Name of STP : Rohini
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 06.08.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	25	Inlet	7.3	200	170	384	11.2	9.3	4.7	-	Meeting the standards.
		Outlet	7.6	8	7	32	1.2	0.5	0.6	120	
		OLMS	7.67	7.02	4.85	25.2	-	1.32	-	-	
Total 25											

Shweta
I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

[Signature]
Scientist 'B'/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)




Report Number: DPCC/W/STP/25-26/126 / 2164


Dated 02-09-25

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2025

1. Name of STP : Mehrauli
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 06.08.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	15	Inlet	7.9	188	140	328	18.4	8.7	11.7	-	Not meeting the standards wrt TSS, BOD & Fecal Coliform.
		Outlet	7.7	14	12	32	1.6	0.9	1.1	2800	
		OLMS	7.35	11.96	7.97	37.59	-	4.81	-	-	
Total 15											


I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)


Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/25-26/127 / 2165

Dated 02-09-25

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2025

1. Name of STP : Ghitorini
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 06.08.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	5	Inlet	7.5	236	150	376	16.8	11.9	4.2	-	Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.6	22	16	52	2.8	0.7	0.9	14000	
		OLMS	7.56	22.61	13.24	51.68	-	5.49	-	-	
Total 5											

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/128/2166

Dated 02-09-25

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2025

1. Name of STP : Vasant Kunj
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 06.08.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	2	Inlet	7.8	196	163	352	13.6	9.2	10.5	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.9	22	19	76	1.2	0.8	0.6	5400	
		OLMS	7.64	26.67	18.67	85.94	-	8.84	-	-	
2	3	Inlet	7.6	232	170	416	14.4	8.9	9	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.1	33	18	68	1.6	0.9	0.6	22000	
		OLMS	7.54	26.01	16.55	82.77	-	8.57	-	-	
Total 5.2											

I/C Water Laboratory
Incharge (Water Laboratory)

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/25-26/129/2167

Dated 02-09-25

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST -2025

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of sampling : 07.08.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Ph-I,II (20)	Inlet	7.4	202	120	280	12.8	12.5	5.6	-	Meeting the standards.
		Outlet	7.1	9	8	24	1.6	0.4	0.6	72	
		OLMS	7.72	7.26	5.28	24.42	-	1.83	-	-	
2	Ph-III (10)	Inlet	7.3	216	110	232	16.8	11.6	10.2	-	Meeting the standards.
		Outlet	7.2	6	7	20	1.2	0.5	0.9	64	
		OLMS	7.70	7.53	5.43	24.25	-	1.42	-	-	
Total 30											

I/C Water Laboratory
Incharge (Water Laboratory)

Scientist 'B' /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/ 130/ 2168

Dated 02-09-25

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2025

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of sampling : 07.08. 2025
4. Samples collected by : DPCC Lab
5. Parameters Analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	70 MGD	Inlet	7.3	170	115	288	16.8	9.6	4.7	-	Meeting the standards.
		Outlet	7.1	7	6	16	0.8	0.6	0.9	56	
		OLMS	7.36	4.89	5.25	39.96	-	1.72	-	-	
Total 70											

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/131 / 2169

Dated 02-09-25

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2025

1. Name of STP : Keshopur
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 07.08.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	60	Inlet	7.5	240	170	360	17.2	10.7	8.6	-	Meeting the Standards.
		Outlet	7.2	7	6	36	1.2	0.7	1.2	50	
		OLMS	7.46	9	6.56	32	-	2.61	-	-	
2	20	Outlet	7.3	6	5	20	1.2	0.8	0.7	54	Meeting the Standards..
		OLMS	7.62	7.01	5.3	21.12	-	3.11	-	-	
Total 60											

I/C Water Laboratory
Incharge (Water Laboratory)

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/134 2170

Dated 02-05-25

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2025

1. Name of STP : Keshopur STP (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 07.08. 2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	12	Inlet	7.4	166	140	336	20.8	10.6	5.4	-	Meeting the standards.
		Outlet	7.2	6	5	24	1.2	0.9	0.6	84	
		OLMS	7.49	7.49	5.99	28.27	-	2.32			
Total 12											

Shweta Gupta
I/C Water Laboratory
Incharge (Water Laboratory)

[Signature]
Scientist B/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/133/ 2171

Dated 02-09-25

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2025

1. Name of STP : Nilothi Phase-II
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 07.08. 2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	20	Inlet	7.5	212	120	280	16.8	11.9	9.8	-	Meeting the standards.
		Outlet	7.4	8	7	24	1.2	0.6	0.5	95	
		OLMS	7. 56	6.54	7.56	41.74	-	4.63	-	-	
Total 40											

1
I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/134/ 2172

Dated 02-09-25

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2025

1. Name of STP : Nilothi New, Phase-I
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 07.08.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P(mg/l) 2	Fecal Coliform MPN/100ml 230	
1	40	Inlet	7.6	156	145	384	14.8	11.5	12.2	-	Meeting the Standards.
		Outlet	7.2	10	8	28	1.6	0.6	0.7	95	
		OLMS	7.81	10.49	7.93	50.20		4.36	-	-	
Total 20											

Shweta

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

[Signature]

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/135/2123

Dated 02-09-25

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2025

1. Name of STP : Delhi Gate (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 08.08.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Phase-I & II (15)	Inlet	7.3	136	110	320	26.8	11	4.4		Meeting the standards.
		Outlet	7.2	7	6	28	1.2	0.9	0.5	150	
		OLMS	7.43	6.63	5.22	22.68	-	1.96			
Total 15											

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/136/2194

Dated 02-09-25

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2025

1. Name of STP : Delhi Gate (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 08.08.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Ph-I & II (10)	Inlet	7.6	154	115	272	29.6	12.0	5.4		Not meeting the standards wrt. Feceal coliform.
Outlet		7.3	8	7	32	1.6	0.4	0.6	250		
OLMS		7.21	4.36	4.75	16.54	-	1.21				
Total 2.2											

Shruti
I/C Water Laboratory
Incharge (Water Laboratory)

[Signature]
Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/ 137/ 2175

Dated 02-09-25

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2025

1. Name of STP : SEN Nursing Home (SNH)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 08.08.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Phase-I,II (2.2)	Inlet	7.1	180	135	304	28.4	9.9	4.9		Not meeting the Standards wrt. Feceal coliform.
		Outlet	7.3	6	5	20	0.8	0.7	0.5	250	
		OLMS	7.15	6.49	6.93	20.90	-	2.32	-	-	
Total 2.2											

Shweta Gupta
I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

[Signature]
Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/3307/38/2176

Dated 02-09-25

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2025

1. Name of STP : Akshardham
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 08.08.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	1	Inlet	7.3	212	125	320	12.8	12.5	4.9		Meeting the Standards.
		Outlet	7.2	3	2	12	0.8	0.7	0.7	96	
		OLMS	7.56	0.76	1.67	7.9	-	0.54			
Total 1											

Shruti
I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

[Signature]
Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/ 139 / 2127

Dated 02-09-25

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2025

1. Name of STP : Yamuna Vihar Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 08.08.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and Results											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	25	Inlet	7.2	192	140	328	12.8	8.7	11.0	-	Not meeting the Standards wrt TSS, BOD, COD & fecal coliform.
		Outlet	7.4	24	20	60	1.2	0.5	1.3	920	
		OLMS	7.73	23.82	17.76	65.21	-	27.75	-	-	
Total 25											

Shweta
I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

[Signature]
Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/140/2198

Dated 02-08-25

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2025

1. Name of STP : Yamuna Vihar
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 08.08.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results:

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	10 Ph-1	Inlet	7.4	278	195	368	12.4	10.7	10.9		Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform
		Outlet	7.6	32	22	56	1.2	0.9	0.8	800	
		OLMS	7.38	41.92			-	26.10	-		BOD and COD were showing red at time of DPCC Inspection.
2	15 Ph-2	Inlet	7.3	286	140	340	11.6	10.1	11.9		Meeting the standards.
		Outlet	7.1	9	8	36	1.6	1.1	0.3	140	
		OLMS	7.58	8.06	4.11	22.48	-	4.88	-		
Total 20											

[Signature]
I/C Water Laboratory
Incharge (Water Laboratory)

[Signature]
Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



LIFE

Lifestyle for Environment

Report Number: DPCC/W/STP/25-26/142/2190

Dated 02-09-25

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2025

1. Name of STP : Molarband (Mini STP)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 11.08.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and Results											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	0.66	Inlet	7.5	202	150	384	13.6	11.2	9.1	-	Not meeting the standard wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.3	30	14	64	0.8	1.3	0.6	350	
		OLMS	7.25	25.48	16.99	70.78	-	7.93	-	-	
Total 0.66											

I/C Water Laboratory
Incharge (Water Laboratory)

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/25-26/143/2181

Dated 02-03-25

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2025

1. Name of STP : Okhla
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 11.08.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	124 MGD	Inlet	7.2	220	140	360	13.2	11.2	10.7	-	Meeting the Standards.
		Outlet	7.6	7	4	28	1.2	0.7	0.7	72	
		OLMS	7.47	6.82	5.58	27.90	-	2.48	-	-	
Total 124											

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/144/ 2182

Dated 02-03-25

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2025

1. Name of STP : Okhla New
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 11.08.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters Analyzed and Results											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	30	Inlet	7.4	216	145	320	11.2	11.7	9.3	-	Meeting the Standards.
		Outlet	7.3	8	6.7	20	1.6	1.3	0.4	84	
		OLMS	7.47	5.46	4.71	23.76	-	1.55	-	-	
Total 30											

Shweta
I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

[Signature]
Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)




Report Number: DPCC/W/STP/25-26/145/ 2183


Dated 02-09-25

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2025

1. Name of STP : Kapasahera
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 12.08.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results:

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	5	Inlet	7.2	210	170	376	16.4	11.4	8.3	-	Meeting the Standards.
		Outlet	7.1	9	6	32	1.2	1.2	0.9	180	
		OLMS	7.67	8.28	5.36	39.36	-	2.93	-	-	
Total 5											


 I/C Water Laboratory
 Dr. Shweta Gupta
 Incharge (Water Laboratory)


 Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)




Report Number: DPCC/W/STP/25-26/146 / 2184

Dated 02-08-25

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2025

1. Name of STP : Pappankalan (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 12.08.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	30	Inlet	7.2	202	160	352	14.4	9.2	8.6	-	Meeting the Standards.
		Outlet	7.3	10	7	20	0.8	0.9	0.8	95	
		OLMS	7.56	12.91	9.15	59.96	-	1.83	-	-	
Total 30											


I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)


Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)




Report Number: DPCC/W/STP/25-26/147/ 2185


Dated 02-09-25

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2025

1. Name of STP : Pappankalan Ph-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 12.08.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
	20	Inlet	7.2	202	160	352	14.4	9.2	8.6	-	Meeting the standards.
Outlet		7.1	8	8	36	1.6	0.8	0.5	84		
OLMS		7.59	6.29	4.23	27.27	-	1.74	-	-		
Total 20											


 I/C Water Laboratory
 Dr. Shweta Gupta
 Incharge (Water Laboratory)


 Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number DPCC/W/STP/25-26/148 / 2186

Dated 02-09-25

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2025

1. Name of STP : Najafgarh
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 12.08.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Fecal Coliform MPN/100ml	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)			
			6.5-9.0	10	10	50	10	5	2	230		
1	5	Inlet	7.1	220	135	260	19.6	8.9	10.5	-	Meeting the Standards.	
		Outlet	7.3	7	6	24	1.2	0.9	0.6	76		
		OLMS	7.49	8.50	6.00	29.70	-	2.66	-	-		
Total 5												

I/C Water Laboratory
Incharge (Water Laboratory)

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/149/ 2187

Dated 02-09-25

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST -2025

1. Name of STP : Narela
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 18.08.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	10	Inlet	7.2	186	155	340	14.4	11.6	9.8	-	Meeting the standards.
		Outlet	7.6	9	8	32	1.6	0.5	0.7	81	
		OLMS	7.48	7.13	5.18	21.71	-	1.77	-	-	
Total 10											

Shweta

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

Scientist 'B' /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/25-26/150/2188

Dated 02-09-25

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2025

1. Name of STP : Sonia Vihar
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 22.08.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	7	Inlet									No sampling was conducted due to no flow at the time of DPCC inspection.
		Outlet									
		OLMS									
Total 7											

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

Scientist B /Analyst