



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/151/5152

Dated: 10/11/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2022

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 18.10.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results :										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	Ph-I,II (20)	Inlet	6.9	332	130	232	26.4	28.5	19.2	Not meeting the standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.4	36	18	72	4.4	4.5	3.6	
		OLMS	7.5	35.90	22.74	128.19	-	12.22	-	
2	Ph-III (70)	Inlet	7.3	240	115	304	12.4	35.8	30.8	Meeting the standards.
		Outlet	7.5	10	08	36	2	4.2	2	
		OLMS*	-	-	-	-	-	-	-	
Total 90										

*Remarks: During the monitoring, the OLMS (Ph-III) was found not functional.

Motira
I/C LABORATORY
Dr. NANDITA MOTIRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/152/5/53

Dated: 10/11/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2022

1. Name of STP : Delhi Gate (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 04.10.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	Phase-I,II(15)	Inlet	7.3	212	105	212	25.2	30	13.2	Meeting the Standards.
		Outlet	7.5	08	06	32	1.6	4.2	1.5	
		OLMS	7.2	7.15	7.31	50.74	-	4.14	-	
Total 15										

Nandita

I/C LABORATORY

Dr. NANDITA MOTIRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/153/S154

Dated: 10/11/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2022

1. Name of STP : Delhi Gate(Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 04.10.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
	Phase-I,II(2.2)	Inlet	7.5	212	115	256	20.4	26.2	11.5	Meeting the Standards
		Outlet	7.2	10	06	28	2.2	4.2	1.2	
		OLMS	7.0	7.75	2.78	17.93	-	2.21	-	
Total 2.2										

I/C LABORATORY

Dr. NANDITA MOTIRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/154/5155

Dated: 10/11/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2022

1. Name of STP : Keshopur STP (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 31.10.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	12	Inlet	7.8	276	135	352	28.4	16.2	15.4	Not Meeting the standards wrt TSS & BOD.
		Outlet	7.3	18	14	32	0.8	1.3	1.4	
		OLMS	7.0	5.38	4.04	28.04	-	2.15	-	
Total 12										

Nandita
I/C LABORATORY
Dr. NANDITA MOTIRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/155/S/S6

Dated: 10/11/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2022

1. Name of STP : SEN Nursing Home (SNH)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 04.10.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	Phase-I,II (2.2)	Inlet	7.4	244	110	188	30	30.8	21.8	Meeting the Standards
		Outlet	7.3	10	08	24	2.0	3.2	1.4	
		OLMS	6.7	4.98	3.44	25.24	-	1.97	-	
Total 2.2										

Nandita

I/C LABORATORY

Dr. NANDITA MOTIRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/156/5/57

Date: 10/11/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2022

1. Name of STP : Nilothi New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.10.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	20	Inlet	7.0	152	110	210	26.4	28.1	7.2	Meeting the standards
		Outlet	7.2	10	06	32	0.8	2.2	1.4	
		OLMS	7.4	5.44	3.09	26.48	-	1.91	-	
Total 20										

N. Motira

I/C LABORATORY
DR. NANDITA MOTIRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/157/158

Dated : 10/11/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER -2022

1. Name of STP : Nilothi
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.10.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	40	Inlet	7.4	252	124	240	18	22.6	19.8	Not meeting the standards wrt TSS, BOD, COD & Ammonical Nitrogen.
		Outlet	7.6	64	46	154	6	9.3	2	
		OLMS	7.4	5.4	3.09	26.48	-	1.91	-	
Total 40										

N. Motira

I/C LABORATORY
Dr. NANDITA MOTIRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/22-23/158/5159

Dated: 10/11/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER -2022

1. Name of STP : Najafgarh
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.10.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	5	Inlet	7.8	220	85	256	24	20.4	18.6	Not meeting the standards wrt TSS, BOD & COD.
		Outlet	7.4	28	18	52	3.2	4.8	1.8	
		OLMS*	7.0	41.10	24.30	141.10	-	12.06	-	
Total 5										

I/C LABORATORY

Dr. NANDITA MOTIRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/159/5160

Dated: 10/11/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER -2022

1. Name of STP : Rithala
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.10.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	Phase-I(40)	Inlet	-	-	-	-	-	-	-	Plant was under Rehabilitation
		Outlet	-	-	-	-	-	-	-	
		OLMS	-	-	-	-	-	-	-	
2	Ph-II(40)	Inlet	7.2	264	86	208	28.4	18.6	19.4	Not meeting the Standards wrt TSS & BOD.
		Outlet	7.6	18	14	44	4.6	5	1.8	
		OLMS	7.4	12.65	8.93	34.80	-	7.25	-	
Total 80										

N. Motira

I/C LABORATORY

Dr. NANDITA MOTIRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/160/5/61

Dated: 10/11/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER -2022

1. Name of STP : Pappankalan (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.10.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	20	Inlet	7.6	192	72	186	19.2	21.1	16.4	Not meeting the Standards wrt TSS, BOD COD, Ammonical Nitrogen & Dissolved Phosphate.
		Outlet	7.8	38	20	68	4.8	6	3	
		OLMS	7.6	34.73	29.25	169.94	-	12.9	-	
Total 20										

Nandita

I/C LABORATORY

Dr. NANDITA MOTIRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/161/5162

Dated: 10/11/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER -2022

1. Name of STP : Pappankalan Ph-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.10.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
	20	Inlet	7.4	160	136	334	17.2	20.2	17	Meeting the Standards.
		Outlet	7.6	8	6	38	2	3.2	2	
		OLMS	7.1	7.12	4.06	30.31	-	1.52	-	
Total 20										

N. Motira
N.C. LABORATORY
Dr. NANDITA MOTIRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/22-23/162/5163

Dated : 10/11/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER -2022

1. Name of STP : Rohini
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.10.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	15	Inlet	7.2	248	140	344	21.2	37.1	24.6	Not meeting the Standards wrt TSS, BOD, COD, Ammonical Nitrogen & Dissolved Phosphate.
		Outlet	7.6	32	22	72	4.8	7.6	3	
		OLMS	7.3	15.82	15.91	26.09	-	12.87	-	
Total 15										

N. Motira
I/C LABORATORY
Dr. NANDITA MOTIRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/163/5164

Dated: 10/11/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER -2022

1. Name of STP : Narela
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.10.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	10	Inlet	7.8	292	95	184	4.8	32.6	21.6	Not Meeting the Standards wrt TSS, BOD & Dissolved Phosphate
		Outlet	7.4	34	18	40	2	2.8	2.1	
		OLMS	7.1	35.85	19.25	82.46	-	10.92	-	
Total 10										

N. Motira

I/C LABORATORY

Dr. NANDITA MOTIRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/164)S165

Dated: 10/11/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER -2022

1. Name of STP : Okhla New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 06.10.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	30	Inlet	7.3	180	100	216	16.8	28.6	19.2	Not meeting the standards wrt TSS & BOD.
		Outlet	7.5	18	14	36	1.6	4.2	1.3	
		OLMS	7.1	6.85	6.11	45.20	-	1.49	-	
Total 30										

Nandita

I/C LABORATORY

Dr. NANDITA MOTIRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/165/5/66

Dated: 10/11/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER -2022

1. Name of STP : Kondli
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.10.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results :										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	Ph-I (10)	Inlet	7.1	312	110	416	18.8	36.4	30.5	Not meeting the standards wrt TSS & BOD.
		Outlet	7.3	16	12	48	0.8	1.8	0.3	
		OLMS*				-		-		
2	Ph-III (10)	Outlet	7.3	12	10	40	2.2	2	1.1	Not meeting the standards wrt TSS.
		OLMS*								
Total 20										

*Remarks: During the monitoring, the OLMS (Ph-I & III) were not functional.

Dr. Nandini Moti
Scientist UCRA
I/C LABORATORY
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/166/5167

Dated: 10/11/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER -2022

1. Name of STP : Kondli New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.10.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	45	Inlet	7.4	212	145	296	20.4	34.5	26.8	Not Meeting the Standards wrt TSS, BOD, COD, Ammonical nitrogen & Dissolved Phosphate.
		Outlet	7.2	82	42	132	5.2	6.2	3.6	
		OLMS*	-	-	-	-	-	-	-	
Total 45										

*Remarks: OLMS was stolen. FIR has been filed as informed by Plant In-charge.

N. Motira

I/C LABORATORY
DR. NANDITA MOTIRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/167/5168

Dated: 10/11/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER -2022

1. Name of STP : Kapasahera
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.10.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	5	Inlet	7.2	184	80	264	6.4	36.4	19.2	Meeting the standards
		Outlet	7.6	8	6	38	1.2	4.5	1.5	
		OLMS	7.6	7.62	4.21	25.28	-	3.52	-	
Total 5										

N. Mitra
I/C LABORATORY
DR. NANDITA MOTIRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/168/5169

Dated: 10/11/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER -2022

1. Name of STP : Yamuna Vihar Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.10.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	25	Inlet	7.5	168	105	288	18	23.6	20.4	Not meeting the Standards wrt TSS & BOD.
		Outlet	7.7	28	18	48	3.6	4.1	1.9	
		OLMS	7.5	13.21	8.85	47.69	-	7.35	-	
Total 25										

Nandita
I/C LABORATORY
Dr. NANDITA MOTIRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Dated: 10/11/2022

Report Number: DPCC/W/STP/22-23/169/5170

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2022

1. Name of STP : Chilla
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.10.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	9	Inlet	7.6	188	90	240	20.4	30.2	20.4	Meeting the Standards.
		Outlet	7.2	10	6	44	1.2	4.2	1.8	
		OLMS	7.6	6.70	5.60	26.68	-	1.28	-	
Total 9										

N. Mishra
I/C LABORATORY
Dr. NANDITA MOTIRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/170/5171

Dated: 10/11/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2022

1. Name of STP : Akshardham
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 04.10.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	1	Inlet	6.9	280	130	184	25.2	21.6	17.2	Meeting the Standards.
		Outlet	7.3	2	4	12	0.4	2.2	1.5	
		OLMS	7.0	0.62	1.23	9.85	-	0.31	-	
Total 1										

N. Motira

I/C LABORATORY
Dr. NANDITA MOTIRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/171/5172

Dated: 10/11/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2022

1. Name of STP : Mehrauli
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.10.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	15	Inlet	7.2	208	100	256	9.2	18.2	40	Not meeting the standards wrt TSS, COD & Dissolved Phosphate.
		Outlet	7.4	14	10	64	1.6	5.4	2.4	
		OLMS	7.4	13.30	8.02	47.32	-	4.06	-	
Total 15										

N. Motira
I/C LABORATORY

Dr. NANDITA MOTIRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/172/5173

Dated: 10/11/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2022

1. Name of STP : Vasant Kunj
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.10.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	2.2	Inlet	7	224	120	320	28.4	18.5	36.2	Not Meeting the Standards wrt TSS, BOD & Dissolved Phosphate
		Outlet	7.4	34	18	48	3.2	3.2	7.5	
		OLMS	6.9	13.47	10.43	33.76	-	9.87	-	
2	3	Inlet	7.3	284	120	296	9.6	20.2	30	Not Meeting the Standards wrt TSS, BOD & Dissolved Phosphate.
		Outlet	7.5	22	12	48	2.4	4.5	2.2	
		OLMS	7.3	3.52	4.68	19.15	-	8.86	-	
Total 5.2										

I/C LABORATORY

Dr. NANDITA MOTIRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/173/5174

Dated: 10/11/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2022

1. Name of STP : Yamuna Vihar
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.10.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	10 Ph-1	Inlet	7.1	212	100	272	15.6	30.4	39.6	Not meeting the standards wrt TSS.
		Outlet	7.5	12	10	36	2.4	4.5	1.8	
		OLMS	8.2	7.40	5.75	32.88	-	7.63	-	
2	10 Ph-2	Inlet	7.4	216	108	286	16.2	32.2	40.2	Not meeting the standard wrt TSS & BOD.
		Outlet	7.3	14	12	40	2.8	4.8	1.6	
		OLMS	6.9	13.62	12.88	66.82	-	1.69	-	
Total 20										

I/C LABORATORY

MOTIRA

Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/174/5175

dated: 10/11/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2022

1. Name of STP : Okhla
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 06.10.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P(mg/l) 2	
1	12	Inlet	7.0	216	90	280	16.8	30.2	18.6	Not meeting the Standards wrt TSS & BOD.
		Outlet	7.2	16	14	48	3.6	4.5	1.4	
		OLMS	8.0	38.48	17.73	44.40	-	1.33	-	
	16	Outlet	7.4	20	14	32	2.8	4.2	2.8	Not meeting the Standards wrt TSS, BOD & Dissolved Phosphate
		OLMS	7.5	6.94	4.60	25.34	-	6.41	-	
	37	Outlet	7.0	14	12	40	1.2	4.5	2.6	Not meeting the Standards wrt TSS, BOD & Dissolved Phosphate.
		OLMS*	-	-	-	-	-	-	-	
	45	Outlet	7.3	18	14	44	2	3.2	1.6	Not meeting the Standards wrt TSS & BOD.
		OLMS	7.2	23.48	13.21	61.63	-	5.58	-	
	Total 110									

*Remarks: OLMS (37 MGD) was found non-operational at the time of Monitoring (informed by JE, DJB).

N. Motira
I/C LABORATORY
DR. NANDITA MOTIRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Dated: 10/11/2022

Report Number: DPCC/W/STP/22-23/175/5176

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2022

1. Name of STP : Keshopur
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 31.10.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	40	Inlet	7.4	132	62	216	16.4	20.2	15.8	Not meeting the Standards wrt TSS & BOD.
		Outlet	7.5	48	30	80	2.4	3.2	1.6	
		OLMS*	-	-	-	-	-	-	-	
2	20	Inlet	7.4	132	62	216	16.4	20.2	15.8	Not meeting the Standards wrt TSS, BOD, COD & Ammonical Nitrogen.
		Outlet	7.6	58	32	84	5.2	5.7	1.8	
		OLMS	-	-	-	-	-	-	-	
Total 60										

*Remarks: During the monitoring, the OLMS of 20 & 40 MGD was found not-functional.

N. Mitra
I/C LABORATORY
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/176/5177

dated. 10/11/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2022

1. Name of STP : Ghitorini
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.10.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	5	Inlet	7.6	92	45	176	6.4	33.8	43.1	Not meeting the Standards wrt TSS & BOD.
		Outlet	7.2	24	14	48	1.8	3.2	2.4	
		OLMS*	-	-	-	-	-	-	-	
Total 5										

Remarks: During the monitoring, the OLMS was found not functional.

Motira
I/C LABORATORY

MOTIRA

Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/07/5178

Dated: 10/11/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2022

1. Name of STP : Molarband (Mini STP)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 06.10.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	0.66	Inlet	7.9	300	125	240	23.2	20.8	19.2	Not meeting the Standards wrt TSS, BOD, COD & Dissolved phosphate.
		Outlet	7.5	24	18	68	3.2	2.4	2.8	
		OLMS	7.1	60.94	5.4	114.6	-	13.75	-	
Total 0.66										

N. Mishra

I/C LABORATORY

ANITA MOTIRA

Scientist 'C'