



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/126/4250

Dated: 13/9/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST -2021

1. Name & Address of Ind./Unit : Coronation Pillar STP
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 05.08.2021
4. Samples collected by : DPCC, Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	Parameters COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P(mg/l) 2	Remarks
1	Ph-I,II(20)	Inlet	7.18	312	160	480	14	32.40	14.20	Not meeting the Standards w.r.t TSS, BOD, COD & Ammonical Nitrogen.
		Outlet	7.24	40	22	84	3.2	14.40	1.80	
		OLMS*	-	-	-	-	-	-	-	
2	Ph-III(10)	Inlet	7.20	212	110	340	44.4	58.12	42.80	Not meeting the standards w.r.t TSS, BOD, COD, Ammonical Nitrogen & Dissolve Phosphate.
		Outlet	7.36	44	40	168	4.0	18.16	4.60	
		OLMS*	7.32	70	60	323	-	26.93	-	
Total 30										


Remarks: Ph-I & II OLMS was not working

N. Moha

I/C LABORATORY
Dr. NANDITA MOITRA
Scientist 'C'

SR. Scientific Assistant

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/127/4251

Dated: 13/9/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST -2021


1. Name & Address of Ind./Unit : Delhi Gate STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.08.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
						COD (mg/l)				
				10	10	50	10	5	2	
1	Phase-I,II(15)	Inlet	7.24	136	98	302	26.4	40.12	4.10	meeting the Standards
		Outlet	7.26	6	8	36	0.8	4.40	1.60	
		OLMS*	-	-	-	-	-	-	-	
Total 15										

Remarks: OLMS was found under maintenance at the time of DPCC Monitoring

Maitra
I/C LABORATORY
Dr. NANDITA MOITRA
Scientist 'C'

SR. Scientific Assistant
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/128/4252

Date: 13/9/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST -2021

1. Name & Address of Ind./Unit : DELHI GATE STP (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.08.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
						COD (mg/l)				
				10	10	50	10	5	2	
1	Phase-I,II(2.2)	Inlet	7.29	168	88	352	26	38.44	8.10	meeting the Standards
		Outlet	7.12	6	6	32	1.2	3.10	1.40	
		OLMS*	6.64	6.57	3.11	20.28	-	0.57	-	
Total 2.2										

Nandita
I/C LABORATORY
Dr. NANDITA MOITRA
Scientist 'C'

SR. Scientific Assistant
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE (Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/129/4253

Date: 13/9/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST -2021

1. Name & Address of Ind./Unit : Keshopur STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 05.08.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	12	Inlet	7.08	152	92	212	14.8	42.10	18.10	Not meeting the Standards w.r.t TSS, BOD, COD, & Dissolve phosphate.
		Outlet	7.40	28	34	120	2.8	5	2.20	
		OLMS*	7.6	99	70	181	-	21	-	
Total 12										

Milka
D/C LABORATORY RA
Scientist 'C'

AB. Arum
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/130/4254

Dated : 13/9/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST -2021

1. Name & Address of Ind./Unit : SEN Nursing Home (SNH)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.08.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results :										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
1	Phase-I,II (2.2)			10	10	50	10	5	2	
		Inlet	7.31	180	104	298	32.4	44.60	12.10	Meeting the Standards.
		Outlet	7.35	8	6	34	2	4.60	1.80	
		OLMS*	5.92	5.31	2.69	15.12	-	Nil	-	
Total 2.2										

Nandita
I/C LABORATORY
Dr. NANDITA MOITRA
Scientist 'C'

Shafiq
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/131/4255

Dated: 13/9/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST -2021

1. Name & Address of Ind./Unit : Nilothi STP-II
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.08.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	20	Inlet	7.30	280	110	296	19.6	24.40	12.10	Meeting with the standards.
		Outlet	7.35	10	8	32	1.4	4	1.80	
		OLMS*	7.56	6.40	5.13	33.65	-	2.52	-	
Total 20										

N. Mitra
I/C LABORATORY
Dr. NANDITA MOITRA
Scientist 'C'

SR. Scientific Assistant
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/132/4256

Dated : 13/9/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST -2021

1. Name & Address of Ind./Unit : Nilothi STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.08.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	40	Inlet	7.17	256	132	396	18	26.10	14.68	Not meeting the standards w.r.t to TSS, BOD & COD
		Outlet	7.32	46	24	96	2.8	4.12	1.60	
		OLMS*	6.49	70.44	29.77	131.65	-	21.77	-	
Total 40										

N. Mitra
I/C LABORATORY
Dr. NANDITA MOITRA
Scientist 'C'

P. Sharma
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/20-21/133/4257

Dated : 13/9/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST -2021

1. Name & Address of Ind./Unit : Najafgarh STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.08.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				
				10	10	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
						50	10	5	2	
1	5	Inlet	7.39	120	68	276	24.4	74.16	19.12	Not meeting the standards w.r.t to TSS BOD, COD, Ammonical Nitrogen & Dissolve Phosphate.
		Outlet	7.55	32	20	84	2	8.10	4.20	
		OLMS*	7.26	43.62	24.45	130.29	-	21.80	-	
Total 5										

N. Mitta
I/C LABORATORY
Dr. NANDITA MITTA
Scientist 'C'

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/134/4258

Dated: 13/9/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST -2021

1. Name & Address of Ind./Unit : Rithala STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 04.08.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	Phase-I(40)	Inlet	-	-	-	-	-	-	-	Rithala Ph-I STP was under maintenance.
		Outlet	-	-	-	-	-	-	-	
		OLMS*	-	-	-	-	-	-	-	
2	Ph-II(40)	Inlet	7.12	116	60	180	30.4	21.62	14.20	Not meeting the standards w.r.t to BOD.
		Outlet	7.4	8	12	40	1.4	4.80	2	
		OLMS*	-	11.04	7.75	23.64	-	-	-	
Total 80										

N. Mitta
I/C LABORATORY
Scientist 'C'

A. Belram
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/135/4259

Dated: 13/9/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST -2021

1. Name & Address of Ind./Unit : Pappankalan STP(Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.08.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	20	Inlet	7.45	72	40	168	22.8	54.64	10.10	Not meeting the Standards w.r.t TSS, BOD, COD & Ammonical Nitrogen.
		Outlet	7.43	40	22	92	4	6.10	2	
		OLMS*	7.47	47.50	24.00	166.79	-	16.3	-	
Total 20										

N. Moitra
I/C LABORATORY
Dr. NANDITA MOITRA
Scientist 'C'

Abdurum
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/136/4260

Dated: 13/9/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST -2021

1. Name & Address of Ind./Unit : Pappankalan STP-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.08.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Remarks
				10	10	50	10	5	2	
	20	Inlet	7.31	136	72	220	8.60	36.98	18	Meeting the standards.
		Outlet	7.35	6	4	20	0.8	3.20	1.40	
		OLMS*	7.63	4.61	8.34	19.09	-	3.44	-	
Total 20										

N. Mitra
I/C LABORATORY
Dr. NANDITA MOITRA
Scientist 'C'

SR. Scientific Assistant
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/20-21/137/4261

Dated : 13/9/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST -2021

1. Name & Address of Ind./Unit : Rohini STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 04.08.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	15	Inlet	7.48	220	110	384	28.60	42.10	14.19	Not meeting the Standards w.r.t TSS, BOD, COD, Ammonical Nitrogen & Dissolved Phosphate.
		Outlet	7.32	24	14	56	4.2	8.16	2.20	
		OLMS*	7.61	30.50	13.74	101.57	-	11.94	-	
Total 15										

Mitra
Dr. I/C LABORATORY
Scientist 'C'

SR. Scientific Assistant
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/138/4262

Dated: 13/9/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST -2021

1. Name & Address of Ind./Unit : Narela STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 05.08.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :


Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	10	Inlet	7.58	104	56	172	2.8	30.16	10.12	
		Outlet	7.80	18	12	44	1.2	4.40	2.0	Not Meeting the Standards w.r.t TSS & BOD.
		OLMS*	-	-	-	-	-	-	-	
Total 10										

Remarks: OLMS was found Under Maintenance at the time of DPCC Monitoring

N. Mitra
I/C LABORATORY

Dr. NANDITA MOITRA
Scientist 'C'

R. Bedram
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/139/4263

Dated: 13/9/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST -2021

1. Name & Address of Ind./Unit : Okhla STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 06.08.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :


5. Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	30	Inlet	7.25	220	110	324	16.4	30.10	14.60	Meeting the Standards.
		Outlet	7.29	8	6	44	1.2	4.20	1.80	
		OLMS*	7.88	8.54	5.29	29.54	-	1.34	-	
Total 30										

N. Mitra

I/C LABORATORY
Dr. NANDITA MOTRA
Scientist 'C'

SR. Scientific Assistant

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/140/4264

Dated: 13/9/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST -2021

1. Name & Address of Ind./Unit : Kondli STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.08.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :


Parameters analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	25	Inlet	7.27	272	136	408	16.4	50.11	40.46	Not meeting the Standards w.r.t TSS, BOD & COD.
		Outlet	7.44	26	16	64	3.6	4	1.60	
		OLMS*	7.33	14.34	15.97	73.45	-	13.76	-	
Total 25										

I/C LABORATORY

Dr. NANDITA MOITRA

Scientist 'C'

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/141/4265

Dated: 13/9/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST -2021


1. Name & Address of Ind./Unit : Kondli STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.08.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Remarks
				10	10	50	10	5	2	
1	45	Inlet	7.89	228	114	456	21.6	18.64	16.60	Not Meeting the Standards w.r.t TSS, BOD, COD, Ammonical Nitrogen & Dissolve Phosphate.
		Outlet	7.42	164	82	246	1.2	5.40	4	
		OLMS*	-	-	-	-	-	-	-	
Total 45										

*OLMS was not found during monitoring time

N. Mishra
I/C LABORATORY
DR. NANDITA MOITRA
Scientist 'C'

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/142/4266

Dated: 13/9/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST -2021

1. Name & Address of Ind./Unit : Kapasahera STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 12.08.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	5	Inlet	7.1	168	86	250	2.8	38.96	12.14	Not meeting the standards w.r.t. TSS, BOD & COD.
		Outlet	7.3	18	14	56	1.2	4.10	1.60	
		OLMS*	7.10	5.04	1.50	23.70	-	0.96	-	
Total 5										

N. Mitta
I/C LABORATORY
DR. NANDHA MOTRA
Scientist 'C'

SR. Scientific Assistant
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/143/4267

Dated: 13/9/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST -2021


1. Name & Address of Ind./Unit : Yamuna Vihar STP Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.08.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	25	Inlet	7.8	464	176	408	42	40.64	40.20	Not meeting the Standards w.r.t TSS, BOD & COD
		Outlet	7.1	30	20	88	3.6	4.20	1.80	
		OLMS*	-	39.88	25.70	88.11	-	-	-	
Total 25										

I/C LABORATORY

Dr. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/144/4268

Dated : 13/9/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST -2021

1. Name & Address of Ind./Unit : Chilla STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.08.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	9	Inlet	7.4	148	74	296	4.4	46.76	14.54	Not meeting the Standards w.r.t TSS.
		Outlet	7.3	16	8	46	1.2	4.20	1.60	
		OLMS*	6.97	25.68	7.77	59.11	-	0.97	-	
Total 9										

N. Mittra
I/C LABORATORY
Dr. NANDITA MOITRA
Scientist 'C'

K. S. Arora
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/145/4269

Dated: 13/9/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST -2021


1. Name & Address of Ind./Unit : Akshardham STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.08.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	1	Inlet	7.26	204	102	302	21.6	44.20	14.60	Meeting the Standards.
		Outlet	7.3	4	2	16	0.4	1.40	1.20	
		OLMS*	7.22	0.22	0.71	11.69	-	0.31	-	
Total 1										

I/C LABORATORY

Dr. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/146/4270

Dated : 13/9/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST -2021

1. Name & Address of Ind./Unit : Mehrauli STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 12.08.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	15	Inlet	7.22	100	52	212	8	18.10	42.16	Not meeting the standards w.r.t TSS, BOD & COD.
		Outlet	7.4	12	16	68	1.2	4.40	1.80	
		OLMS*	7.2	10	7.9	42.7	-	6.5	-	
Total 15										

Mishra
I/C LABORATORY
Scientist 'C'

R. Sharma
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/147/4271

Dated: 13/9/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST -2021

1. Name & Address of Ind./Unit : Vasant Kunj STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 12.08.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	2.2	Inlet	7.1	240	96	384	32.4	20.16	34.40	Not Meeting the Standards w.r.t TSS, BOD, COD & Dissolve Phosphate.
		Outlet	7.4	46	24	72	3.6	2.10	10.10	
		OLMS*	8.6	6.5	4.4	20.8	-	0.09	-	
2	3	Inlet	7.8	216	108	296	7.6	16.86	33.64	Not Meeting the Standards w.r.t COD, BOD, TSS & Dissolve Phosphate.
		Outlet	7.2	28	24	88	2	2.40	4.20	
		OLMS*	8.7	6.4	4.4	20.7	-	0.08	-	
Total 5.2										

White
Dr. I/O LABORATORY
Scientist 'C'

AB Ram
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/148/4272

Date: 13/9/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST -2021


1. Name & Address of Ind./Unit : Yamuna Vihar STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection :
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	10	Inlet	7.3	328	108	432	18.0	38.16	36.40	Not meeting the standards w.r.t TSS, BOD, COD, Ammonical Nitrogen & Dissolve Phosphate
	Ph-1	Outlet	7.5	12	18	68	2.4	7	4	
		OLMS*	7.4	25.62	21.13	100	-	18.36	-	
2	10	Inlet	7.4	332	176	420	24.4	26.11	16.46	Not meeting the standard w.r.t. TSS, COD, BOD, Ammonical Nitrogen & Dissolve Phosphate.
	Ph-2	Outlet	7.3	22	16	64	4.8	10.10	4.20	
		OLMS*	-	-	-	-	-	-	-	
Total 20										

Remarks: Ph-II OLMS was not working.

N. Mitta
Dr. NANDITA MONTA
Scientist 'C'

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/149/4273

Dated: 13/9/2021


ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST -2021

1. Name & Address of Ind./Unit : Okhla STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 06.08.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Remarks
				10	10	50	10	5	2	
1	12	Inlet	7.1	160	86	260	14	32.10	19.46	Not meeting the Standards w.r.t TSS & BOD, COD & Ammonical Nitrogen.
		Outlet	7.30	30	20	64	3.6	5.40	1.60	
		OLMS	7.52	20.63	25.63	82.50	-	4.16	-	
	16	Outlet	7.3	48	28	94	1.2	4.20	2.40	Not meeting the Standards w.r.t TSS, BOD, COD, & Dissolve Phosphate.
		OLMS	7.65	23.82	22.81	11.41	-	-	-	
	37	Outlet	7.3	24	18	72	0.8	5.20	2	Not meeting the Standards w.r.t TSS, BOD, COD & Ammonical Nitrogen.
		OLMS	6.98	43.98	18.90	239.79	-	-	-	
	45	Outlet	7.3	20	16	68	2	4.40	1.40	Not meeting the Standards w.r.t TSS, BOD, & COD.
		OLMS	6.14	37.44	15.60	79.35	-	-	-	
	Total 110									

Nandita
I/C LABORATORY
Dr. NANDITA MOITRA
Scientist 'C'

R.B. Mehta
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/150/4274

Dated: 13/9/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST -2021

1. Name & Address of Ind./Unit : Keshopur STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 05.08.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

STP Parameters Analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	40	Inlet	7.1	188	164	380	28	34.80	16.20	Not meeting the Standards w.r.t TSS, BOD, COD, Ammonical Nitrogen & Dissolve Phosphate,
		Outlet	7.3	72	40	128	4.4	16.84	4.20	
		OLMS*	7.3	69.02	61.29	144	-	29	-	
2	20	Inlet	7.1	188	164	380	28	34.80	16.20	Not meeting the Standards w.r.t TSS, BOD, COD, Ammonical Nitrogen & Dissolve Phosphate,
		Outlet	7.3	36	42	128	3.6	18.64	2.40	
		OLMS*	7.3	70.8	63.8	147.9	-	22.7	-	
Total 60										

Nandita
I/C LABORATORY
Dr. NANDITA MOITRA
Scientist 'C'

Adman
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/6/4275

Dated: 13/9/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST -2021

1. Name & Address of Ind./Unit : Molarband Mini STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 06.08.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
1	0.66	Inlet	7.1	392	188	564	22	22.6	16.11	Not meeting the Standards w.r.t TSS, BOD, COD & Dissolve Phosphate.
		Outlet	7.26	28	18	76	1.6	3.24	2.40	
		OLMS*	7.00	23.02	13.59	68.47	-	0.93	-	
		Total 0.66								

Nandita
I/C LABORATORY

Dr. NANDITA MOITRA
Scientist 'C'

P.B. Sharma

SR. SCIENTIFIC ASSISTANT