



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/276/4692

Dated : 05/04/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH -2022

1. Name & Address of Ind./Unit : Coronation Pillar STP
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 07.03.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	Parameters COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P(mg/l) 2	Remarks
1	Ph-I,II(20)	Inlet	7.0	372	175	418	16	25.32	11.5	Not meeting the standards wrt TSS, BOD, COD, Ammonical Nitrogen & Dissolved Phosphate
		Outlet	7.6	48	19	86	3.2	7.2	2.5	
		OLMS*	-	-	-	-	-	-	-	
2	Ph-III(10)	Inlet	-	-	-	-	-	-	-	Plant was found closed at the time of DPCC monitoring, hence sampling was not done.
		Outlet	-	-	-	-	-	-	-	
		OLMS	-	-	-	-	-	-	-	
Total 30										
*Remarks: OLMS (Ph-I & II) was stolen. FIR has been filed.										

*Remarks: OLMS (Ph-I & II) was stolen. FIR has been filed as informed by Plant Incharge.

N. Mishra
I/C LABORATORY
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/277/4693

Dated: 05/04/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH -2022

1. Name & Address of Ind. /Unit : Delhi Gate STP (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 02.03.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
			6.5-9.0	10	10	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	Phase-I,II(15)	Inlet	6.9	164	85	260	18.8	39.23	6.2	Meeting the Standards.
		Outlet	7.1	8	6	40	0.8	4.32	1.84	
		OLMS	7.3	7.04	3.54	25.93	-	0.06	-	
	Total 15									

M. M. M. M.

I/C LABORATORY

Scientist



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/278/4694

Dated: 05/04/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH -2022


1. Name & Address of Ind./Unit : Delhi Gate STP (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 02.03.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results :										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
			6.5-9.0	10	10	50	10	5	2	
1	Phase-I,II(2.2)	Inlet	6.8	184	80	224	24.2	36.23	10.24	Meeting the Standards
		Outlet	6.7	10	6	38	1.6	3.23	1.30	
		OLMS	7.2	4.89	3.63	25.10	-	0.61	-	
Total 2.2										

Misha

I/C LABORATORY

Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/300/476

Date: 05.04.2022

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH -2022

1. Name & Address of Ind./Unit : Keshopur STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 04.03.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
			6.5-9.0	10	10	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
						50	10	5	2	
1	40	Inlet	7.3	228	80	400	26.2	6.4	3.68	Not meeting the Standards wrt TSS,BOD,COD, Ammonical Nitrogen & Dissolved Phosphate
		Outlet	7.4	44	29	90.6	2.4	5.9	4.2	
		OLMS*	-	-	-	-	-	-	-	
2	20	Inlet	7.3	228	80	400	26.2	6.4	3.68	Not meeting the Standards wrt TSS, BOD, COD, Ammonical Nitrogen & Dissolved Phosphate
		Outlet	7.5	32	29	122.6	3.2	7.0	2.8	
		OLMS	7.7	88.73	72.01	276.13	-	23.47	-	
Total 60										

Remarks: OLMS (40 MGD) was found non-functional at the time of DPCC Monitoring

I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/280/4696

Dated: 05/04/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH -2022

1. Name & Address of Ind./Unit : SEN Nursing Home (SNH)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 02.03.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results :										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
1	Phase-I,II (2.2)	Inlet	6.6	272	90	244	28.2	42.21	16.2	Meeting the Standards
		Outlet	7.8	8	6	26	1.6	3.3	1.3	
		OLMS	7.4	7.73	4.02	24.95	-	0.27	-	
	Total 2.2									

M. M. M. M.
I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/281/4697

Dated: 05/04/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH -2022

1. Name & Address of Ind./Unit : Nilothi STP-II (NEW)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.03.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	20		6.5-9.0	10	10	50	10	5	2	Meeting the standards.
		Inlet	7.0	186	95	224	19.4	18.6	12.8	
		Outlet	7.5	8	6	37.4	1.2	2.6	1.0	
		OLMS	7.5	6.55	5.31	47.63	-	-	-	
Total 20										

Mishra
I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/282/4698

Dated: 05/04/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH -2022

1. Name & Address of Ind./Unit : Nilothi STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.03.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results :										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
			6.5-9.0	10	10	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	40	Inlet	7.2	244	135	50	10	5	2	Not meeting the standards wrt TSS, BOD & COD
		Outlet	7.4	52	21	288	20.0	24.8	8.8	
		OLMS	7.8	56.37	34.73	74.6	2.8	3.8	1.5	
Total 40						180.94	-	-	-	

M. Mitra

I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/21-22/283/4699

Dated: 05/04/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH -2022

1. Name & Address of Ind./Unit : Najafgarh STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.03.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
			6.5-9.0	10	10	50	10	5	2	
1	5	Inlet	7.5	148	75	284	20.4	40.3	17.8	Not meeting the standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.7	46	25	64	2.0	3.8	2.8	
		OLMS*	-	-	-	-	-	-	-	
Total 5										

*Remarks: OLMS was found non-operational at the time of DPCC Monitoring.

Mishra
I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/284/4700

Dated: 05/04/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH -2022

1. Name & Address of Ind./Unit : Rithala STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.03.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
1	Phase-I(40)	Inlet	6.5-9.0	10	10	50	10	5	2	Plant was under Rehabilitation
		Outlet	-	-	-	-	-	-	-	
		OLMS	-	-	-	-	-	-	-	
2	Ph-II(40)	Inlet	7.3	244	80	248	28.4	16.2	19.2	Meeting the standards.
		Outlet	7.6	8	10	46	1.2	3.6	1.5	
		OLMS	7.6	12.73	10.61	41.14	-	12.83	-	
Total 80										

N. Mishra
I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/285/4701

Dated: 05/04/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH -2022

1. Name & Address of Ind./Unit : Pappankalan STP (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.03.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	20		6.5-9.0	10	10	50	10	5	2	Not meeting the Standards wrt TSS, BOD & COD.
		Inlet	7.4	126	42	144	20.8	28.9	11.5	
		Outlet	7.6	44	27	69.3	3.6	3.8	1.6	
		OLMS	7.3	33.02	22.69	162.12	-	-	-	
Total 20										

N. Mishra
I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/286 / 4702

Dated: 05/04/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH -2022

1. Name & Address of Ind./Unit : Pappankalan STP-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.03.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
			6.5-9.0	10	10	50	10	5	2	
	20	Inlet	6.5	140	95	192	8.2	25.8	7.6	
		Outlet	7.1	20	14	32	2.0	2.9	1.8	
		OLMS	7.8	4.80	4.24	27.80	-	-	-	Not Meeting the Standards wrt TSS & BOD.
	Total 20									

Mishra

I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/21-22/287/4703

Dated : 05/04/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH -2022

1. Name & Address of Ind./Unit : Rohini STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.03.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Remarks
			6.5-9.0	10	10	50	10	5	2	
1	15	Inlet	7.5	224	135	368	20.6	35.12	22.8	Not meeting the Standards wrt TSS, BOD, COD, Ammonical Nitrogen & Dissolved Phosphate
		Outlet	7.8	28	18	74.6	4.4	6.2	2.8	
		OLMS	7.2	28.04	15.78	95.90	-	17.86	-	
Total 15										

Mishra
I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/288/4704

Dated: 05/04/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH -2022

1. Name & Address of Ind./Unit : Narela STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.03.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
			6.5-9.0	10	10	50	10	5	2	
1	10	Inlet	7.3	184	60	240	3.0	28.5	15.8	
		Outlet	7.5	86	52	126	1.6	4.8	2.80	Not Meeting the Standards wrt TSS, BOD, COD & Dissolved Phosphate
		OLMS*	-	-	-	-	-	-	-	
Total 10										

*Remarks: OLMS was found non-operational at the time of DPCC Monitoring.

Mitika
I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/289/4705

Dated : 05/04/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH -2022

1. Name & Address of Ind./Unit : Okhla STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.03.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Remarks
1	30	Inlet	6.5-9.0	10	10	50	10	5	2	Meeting the Standards.
		Outlet	7.3	228	112	352	16.8	26.40	18.9	
		OLMS	7.4	8	6	48	1.6	3.2	1.10	
		Total 30	7.8	14.05	8.72	50.37	-	2.0	-	

N. Mitra
I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/290/4706

Dated: 05/04/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH -2022

1. Name & Address of Ind./Unit : Kondli STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 02.03.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
1	25		6.5-9.0	10	10	50	10	5	2	Not meeting the standards wrt TSS & COD
		Inlet	6.8	308	100	444	20.8	35.23	30.12	
		Outlet	6.9	14	8	64	1.2	3.26	1.8	
		OLMS	6.6	13.79	9.03	31.35	-	7.20	-	
Total 25										

Mishra
I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/291/4707

Dated : 05/04/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH -2022

1. Name & Address of Ind./Unit : Kondli STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 02.03.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results :										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Remarks
			6.5-9.0	10	10	50	10	5	2	
1	45	Inlet	7.0	200	140	348	18.8	33.64	25.6	Not Meeting the Standards wrt TSS, BOD, COD, Ammonical Nitrogen & Dissolved Phosphate.
		Outlet	7.3	88	46	144	4.8	5.96	3.8	
		OLMS*	-	-	-	-	-	-	-	
Total 45										

*Remarks: OLMS was found non functional.

*Remarks: OLMS was found non-functional at the time of DPCC Monitoring.

Nishita
I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/292/4708

Dated: 05/04/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH -2022

1. Name & Address of Ind./Unit : Kapasahera STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 04.03.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results :										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
1	5		6.5-9.0	10	10	50	10	5	2	Not Meeting the standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Inlet	7.0	172	75	244	4.8	35.84	15.23	
		Outlet	7.1	24	16	58	1.2	4.23	2.12	
		OLMS	7.3	7.99	5.66	37.60	-	3.02	-	
Total 5										

M. Mitta
I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/293/4709

Dated: 05/04/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH -2022

1. Name & Address of Ind./Unit : Yamuna Vihar STP Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.03.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results :										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
1	25		6.5-9.0	10	10	50	10	5	2	Not meeting the Standards wrt TSS, BOD & COD.
		Inlet	7.4	436	160	340	32.0	36.8	39.4	
		Outlet	7.2	36	25	84	4.4	4.3	1.8	
		OLMS	7.5	36.58	12.93	143.41	-	4.58	-	
Total 25										

Mishra
I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE (Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/294/4710

Dated: 05/04/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH -2022

1. Name & Address of Ind./Unit : Chilla STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 02.03.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Water Quality Analysis and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
			6.5-9.0	10	10	50	10	5	2	
1	9	Inlet	7.9	180	90	232	21.4	28.23	19.8	Meeting the Standards.
		Outlet	7.2	10	6	48	1.2	3.2	1.8	
		OLMS*	-	-	-	-	-	-	-	
Total 9										

*Remarks: OLMS was found non-operational at the time of DPCC Monitoring.

*Remarks: OLMS was found non-operational at the time of DPCC Monitoring.

Mitra
I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/295 14711

Dated: 05/04/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH -2022

1. Name & Address of Ind./Unit : Akshardham STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 02.03.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
			6.5-9.0	10	10	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	1	Inlet	7.0	158	95	292	18.0	35.2	18.4	Meeting the Standards.
		Outlet	7.6	2	1	18	0.4	0.8	1.2	
		OLMS	7.7	0.02	1.45	6.55	-	0.26	-	
Total 1										

N. Mishra

I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/296/4712

Dated: 05/04/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH -2022

1. Name & Address of Ind./Unit : Mehrauli STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 04.03.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
			6.5-9.0	10	10	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	15	Inlet	7.2	192	95	244	9.2	15.23	35.72	Not meeting the standards wrt TSS, BOD & COD.
		Outlet	7.3	14	12	64	1.6	4.23	1.34	
		OLMS	6.9	20.10	9.99	49.33	-	7.97	-	
Total 15										

I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/297/4713

Dated: 05/04/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH -2022

1. Name & Address of Ind./Unit : Vasant Kunj STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 04.03.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
			6.5-9.0	10	10	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	2.2	Inlet	7.0	276	115	320	28.4	17.36	35.68	Not Meeting the Standards wrt TSS & Dissolved Phosphate
		Outlet	7.1	32	14	28	3.2	2.23	7.2	
		OLMS	7.3	5.75	4.35	21.24	-	3.61	-	
2	3	Inlet	7.3	256	120	288	10.2	18.23	28.30	Not Meeting the Standards wrt TSS, BOD & Dissolved Phosphate
		Outlet	7.2	18	12	48	2.2	4.2	2.30	
		OLMS	8.0	6.10	3.01	25.34	-	4.12	-	
Total 5.2										

M. Mittal
I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/298/4714

Dated: 05/04/2022


ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH -2022

1. Name & Address of Ind./Unit : Yamuna Vihar STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.03.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results :										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
			6.5-9.0	10	10	50	10	5	2	
1	10 Ph-1	Inlet	6.90	204	95	276	18.8	30.25	38.20	Not meeting the standards wrt TSS, BOD & Dissolved Phosphate
		Outlet	7.30	12	14	21.4	2.8	6.9	4.2	
		OLMS	7.3	23.44	23.19	140.53	-	14.82	-	
2	10 Ph-2	Inlet	7.3	336	188	456	24.8	32.12	18.26	Not meeting the standard wrt TSS, BOD, COD & Dissolved Phosphate
		Outlet	7.0	24	20	72	5.2	12.16	5.10	
		OLMS	-	-	-	-	-	-	-	
Total 20										

Remarks: Ph-II OLMS was found non-operational at the time of DPCC Monitoring.

N. Mishra
I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/299/4715

Date: 05/04/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH -2022

1. Name & Address of Ind./Unit : Okhla STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.03.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
			6.5-9.0	10	10	50	10	5	2	
1	12	Inlet	7.0	180	85	184	14.8	30.12	18.26	Not meeting the Standards wrt TSS, BOD, COD & Ammonical Nitrogen
		Outlet	7.4	28	16	48	3.2	5.3	1.8	
		OLMS	7.7	28.6	22	110	-	6.20	-	
	16	Outlet	7.4	24	16	26.6	2.8	4.10	2.32	Not meeting the Standards wrt TSS, BOD, COD & Dissolved Phosphate
		OLMS	7.7	2.83	1.87	12.27	-	1.18	-	
	37	Outlet	7.3	26	15	78	1.2	4.9	1.8	Not meeting the Standards wrt TSS, BOD & COD.
		OLMS*	-	-	-	-	-	-	-	
	45	Outlet	7.4	44	14	68	2.4	3.8	1.3	Not meeting the Standards wrt TSS, BOD & COD.
		OLMS	7.0	40.95	28.63	113.12	-	4.83	-	
	Total 110									

*Remarks: OLMS (37 MGD) was found non-operational at the time of DPCC Monitoring.

N. Mittal
I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/300/47/6

Dated: 05/04/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH -2022

1. Name & Address of Ind./Unit : Keshopur STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 04.03.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results :										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
			6.5-9.0	10	10	50	10	5	2	
1	40	Inlet	7.3	228	80	400	26.2	6.4	3.68	Not meeting the Standards wrt TSS,BOD,COD, Ammonical Nitrogen & Dissolved Phosphate
		Outlet	7.4	44	29	90.6	3.2	5.9	4.2	
		OLMS*	-	-	-	-	-	-	-	
2	20	Inlet	7.3	216	80	400	26.2	10.31	16.42	Not meeting the Standards wrt TSS, BOD, COD, Ammonical Nitrogen & Dissolved Phosphate
		Outlet	7.5	56	29	122.6	3.2	7.0	2.8	
		OLMS	7.7	88.73	72.01	276.13	-	23.47	-	
Total 60										

Remarks: OLMS (10 x 500)

Remarks: OLMS (40 MGD) was found non-functional at the time of DPCC Monitoring

Nisha
I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/12/4717

Dated: 05/04/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH -2022

1. Name & Address of Ind./Unit : Molarband Mini STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.03.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
1	0.66		6.5-9.0	10	10	50	10	5	2	Not meeting the Standards wrt TSS, BOD & COD
		Inlet	7.3	180	110	416	20.8	18.90	14.8	
		Outlet	7.5	16	13	68	1.8	2.45	1.98	
		OLMS	7.3	26.58	16.80	127.55	-	2.95	-	
Total 0.66										

N. Mittal
I/C LABORATORY