

DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/274/4640

Dated: 09/03/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2022

1. Name & Address of Ind./Unit : Okhla STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 21.02.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results											
Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
			6.5-9.0	10	10		50	10	5	2	
1	12	Inlet	7.0	180	85		284	20.4	30.23	38.70	Not meeting the Standards w.r.t TSS, BOD, COD, Ammocial Nitrogen & Dissolved Phosphate
		Outlet	7.4	24	15		84	2.8	5.23	2.50	
		OLMS	7.3	26.26	20.2		101	-	19.08	-	
	16	Outlet	7.3	28	14		72	2.6	4.9	1.85	Not meeting the Standards w.r.t TSS, BOD & COD.
		OLMS	7.4	5.13	12.88		101.19	-	2.07	-	
	37	Outlet	7.4	30	18		96	1.2	4.8	1.2	Not meeting the Standards w.r.t TSS, BOD & COD.
		OLMS	7.3	36.71	25.67		101.42	-	2.21	-	
	45	Outlet	7.1	24	14		92	2.4	4.0	1.4	Not meeting the Standards w.r.t TSS, BOD & COD.
		OLMS	--	-	-		-	-	-	-	
	Total 110										

Remarks: 45 MGD OLMS was found non-operational at the time of DPCC Monitoring.

Mishra

I/C LABORATORY

Scientist 'C'

6173 BT(e)
9/3/22



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/273/4639

Dated: 09/03/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY -2022

1. Name & Address of Ind./Unit : Yamuna Vihar STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.02.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
			6.5-9.0	10	10	50	10	5	2	
1	10 Ph-1	Inlet	7.4	200	85	400	14.4	30.4	57.6	Not meeting the standards w.r.t TSS, BOD & Dissolved Phosphate
		Outlet	7.2	24	16	32	1.2	3.2	3.6	
		OLMS*	7.0	22.03	14.01	74.63	-	13.83	-	
2	10 Ph-2	Inlet	7.3	268	128	336	16.8	26.3	23.09	Not meeting the standard w.r.t TSS, COD & Dissolved Phosphate
		Outlet	7.4	14	10	64	1.2	3.2	4.23	
		OLMS*	-	-	-	-	-	-	-	
Total 20										

Remarks: Ph-II OLMS was found non-operational at the time of DPCC Monitoring.

Nmitra
I/C LABORATORY

Scientist



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/272/4638

Dated: 09/03/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY -2022


1. Name & Address of Ind./Unit : Vasant Kunj STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 03.02.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
			6.5-9.0	10	10	50	10	5	2	
1	2.2	Inlet	7.6	256	120	352	18.8	22.2	26.2	Not Meeting the Standards w.r.t TSS & Dissolved Phosphate
		Outlet	7.3	14	10	28	3.6	4.2	3.79	
		OLMS*	7.7	4.85	3.67	19.35	-	0.19	-	
2	3	Inlet	7.0	240	120	512	6.4	22.41	31.5	Not Meeting the Standards w.r.t TSS, BOD & COD.
		Outlet	7.2	16	11	96	1.4	4.23	1.8	
		OLMS*	7.7	6.09	3.02	25.37	-	3.43	-	
Total 5.2										

Mishra

I/C LABORATORY

Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/271/4637

Dated: 09/03/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2022

1. Name & Address of Ind./Unit : Mehrauli STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 03.02.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Remarks
			6.5-9.0	10	10	50	10	5	2	
1	15	Inlet	7.2	216	80	352	18.4	18.27	34.8	Not meeting the standards w.r.t TSS & BOD.
		Outlet	7.0	14	11	32	1.6	3.2	1.55	
		OLMS*	7.5	33.59	10.15	51.13	-	6.30	-	
Total 15										

I/C LABORATORY

N. Mitta

Scientist 'C'

6/143/ITC/11
9/13/22



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/270/4636

Dated: 09/03/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2022

1. Name & Address of Ind./Unit : Akshardham STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 01.02.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
			6.5-9.0	10	10	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
						50	10	5	2	
1	1	Inlet	7.8	192	60	320	20.4	34.6	21.5	Meeting the Standards.
		Outlet	7.1	4	1	24	0.6	1.2	1.5	
		OLMS*	6.8	0.63	0.85	8.29	-	0.24	-	
Total 1										

I/C LABORATORY

Scientist C



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/269 / 4635


Dated: 09/03/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY -2022

1. Name & Address of Ind./Unit : Chilla STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 01.02.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
			6.5-9.0	10	10	50	10	5	2	
1	9	Inlet	7.3	184	100	352	22.8	18.2	26.4	Meeting the Standards.
		Outlet	7.2	8	5.5	21.3	1.6	2.23	1.6	
		OLMS*	7.0	8.6	5.0	24.86	-	1.81	-	
Total 9										

Mitra
I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/268/4634

Dated: 09/03/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY -2022

1. Name & Address of Ind./Unit : Yamuna Vihar STP Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.02.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
			6.5-9.0	10	10	50	10	5	2	
1	25	Inlet	7.5	348	150	352	22.4	26.2	28.97	Not meeting the Standards w.r.t TSS, BOD, COD & Dissolved Phosphate
		Outlet	7.4	90	48	144	1.6	4.3	3.78	
		OLMS*	-	-	-	-	-	-	-	
Total 25										
Remarks: OLMS was found to be in compliance with the standards.										

Remarks: OLMS was found non-operational at the time of DPCC Monitoring.

I/C LABORATORY

Scientist 'C'

6/73/2711
9/13/22



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/267/4633

Dated: 09/03/2022


ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY -2022

1. Name & Address of Ind./Unit : Kapasahera STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 03.02.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	5	Inlet	6.9	104	80	336	4.4	26.2	16.8	Meeting the standards.
		Outlet	6.8	10	8	48	1.6	4.3	1.57	
		OLMS*	7.5	5.72	4.02	35.75	-	3.27	-	
Total 5										

I/C LABORATORY

DR. DIANDITA MOITRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/266/4632

Dated : 09/03/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY -2022

1. Name & Address of Ind./Unit : Kondli STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 01.02.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :


Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	45	Inlet	7.4	272	95	320	18.2	36.42	39	Not Meeting the Standards w.r.t TSS, BOD, COD, Ammonical Nitrogen & Dissolved Phosphate.
		Outlet	7.3	134	88	244	2.4	5.2	3.5	
		OLMS*	-	-	-	-	-	-	-	
Total 45										

Remarks: OLMS was found non-functional at the time of DPCC Sampling.

Mitra

I/C LABORATORY

Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/265/4631

Dated: 09/03/2022


ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY -2022

1. Name & Address of Ind./Unit : Kondli STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 01.02.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
			6.5-9.0	10	10	50	10	5	2	
1	25	Inlet	7.2	240	95	480	18.4	38.26	82.7	Meeting the Standards.
		Outlet	7.0	10	9	42	2.4	4.8	1.8	
		OLMS*	6.6	11.75	7.69	26.70	-	5.55	-	
Total 25										

I/C LABORATORY

Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/264/4630

Dated: 09/03/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY -2022

1. Name & Address of Ind./Unit : Okhla STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 21.02.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :


5. Parameters analyzed and results :										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
			6.5-9.0	10	10	50	10	5	2	
1	30	Inlet	7.3	240	105	448	14.8	20.23	23.9	Meeting the Standards.
		Outlet	7.52	8	5	36	1.2	0.8	1.2	
		OLMS*	7.9	5.14	5.45	27.0	-	1.81	-	
Total 30										

Mishra

I/C LABORATORY

Scientist 'C'

6173 17244
9/3/22



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/263/4629

Dated : 09/03/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY -2022

1. Name & Address of Ind./Unit : Narela STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.02.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
			6.5-9.0	10	10	50	10	5	2	
1	10	Inlet	7.3	256	110	320	16.4	25.3	14.6	Not Meeting the Standards w.r.t TSS, BOD, Ammocial Nitrogen & Dissolved Phosphate
		Outlet	7.6	22	10	38	1.6	5.2	3.2	
		OLMS*	-	-	-	-	-	-	-	-
Total 10										

Remarks: OLMS was found non-operational at the time of DPCC Monitoring.

I/C LABORATORY

Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/21-22/262/4628

Dated : 09/03/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY -2022


1. Name & Address of Ind./Unit : Rohini STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 04.02.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
			6.5-9.0	10	10	50	10	5	2	
1	15	Inlet	7.5	336	150	476	18.4	35.4	27.08	Not meeting the Standards w.r.t TSS, BOD, COD, Ammonical Nitrogen & Dissolved Phosphate
		Outlet	7.8	20	18	68	1.6	6.20	3.23	
		OLMS*	7.4	22.51	17.39	108	-	11.4	-	
Total 15										

I/C LABORATORY

Scientist 'C'

6173/12T(11)
9/3/22



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/261/4627

Date: 09/03/2022


ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY -2022

1. Name & Address of Ind./Unit : Pappankalan STP-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.02.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Remarks
			6.5-9.0	10	10	50	10	5	2	
	20	Inlet	6.8	224	100	288	16.4	34.2	8.58	Meeting the Standards.
		Outlet	7.5	10	8	48	1.6	4.2	1.8	
		OLMS*	7.0	5.65	4.11	21.36	-	0.86	-	
Total 20										

I/C LABORATORY

Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/260/4626

Dated: 09/03/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY -2022


1. Name & Address of Ind./Unit : Pappankalan STP(Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.02.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
			6.5-9.0	10	10	50	10	5	2	
1	20	Inlet	7.9	120	77	208	16.8	32.1	12.7	Not meeting the Standards w.r.t TSS, BOD & COD.
		Outlet	7.8	22	24	96	4.4	4.2	1.3	
		OLMS*	7.2	33.96	23.39	169.23	-	18.4	-	
Total 20										

N. MITRA
I/C LABORATORY

N. MITRA
Scientist (C)

173/ITcell
9/3/22



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/259/4625

Dated: 09/03/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY -2022

1. Name & Address of Ind./Unit : Rithala STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 04.02.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

5. Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
			6.5-9.0	10	10	50	10	5	2	
1	Phase-I(40)	Inlet	-	-	-	-	-	-	-	Plant was under Rehabilitation
		Outlet	-	-	-	-	-	-	-	
		OLMS*	-	-	-	-	-	-	-	
2	Ph-II(40)	Inlet	7.4	240	115	428	15.2	16.8	24.9	Meeting the standards
		Outlet	7.5	10	07	48	1.6	3.6	1.8	
		OLMS*	7.5	12.54	10.51	31.62	-	9.86	-	
Total 80										

N. Mittal

I/C LABORATORY

Scientist 'C'

6/72/STC(1)
9/3/22



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/21-22/258/4624

Dated: 09/03/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY -2022

1. Name & Address of Ind./Unit : Najafgarh STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.02.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :


Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
			6.5-9.0	10	10	50	10	5	2	
1	5	Inlet	7.8	228	87	400	18.4	43.2	22.0	Not meeting the standards w.r.t to TSS, BOD, COD, Ammonical Nitrogen & Dissolved Phosphate
		Outlet	7.5	30	16	88	1.4	5.6	4.2	
		OLMS*	-	-	-	-	-	-	-	
Total 5										

Remarks: OLMS was found non-operational at the time of DPCC Monitoring.

I/C LABORATORY

Scientist 'C'

6/17/2022
9/13/22



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/257/4623

Dated: 09/03/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY -2022

1. Name & Address of Ind./Unit : Niloti STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.02.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :


Parameters analyzed and results :										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
			6.5-9.0	10	10	50	10	5	2	
1	40	Inlet	7.2	364	148	480	22.4	24.8	10.3	Not meeting the standards w.r.t to TSS, BOD, COD, Ammonical Nitrogen & Dissolved Phosphate
		Outlet	7.4	40	26	80	2.8	5.4	2.4	
		OLMS*	7.4	55.40	35.96	178.92	-	25.52	-	
Total 40										

N. Mitra

I/C LABORATORY

K. S. MITRA
SCIENTIST

6173-127111
9/3/22



DELHI POLLUTION CONTROL COMMITTEE (Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/256/4622

Dated: 09/03/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY -2022


1. Name & Address of Ind./Unit : Nilothi STP-II
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.02.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
			6.5-9.0	10	10	COD (mg/l)	10	5	2	
1	20	Inlet	7.0	184	120	480	18.4	18.6	22.11	Meeting the standards.
		Outlet	7.4	10	8	48	2.4	4.2	2.0	
		OLMS*	7.7	6.17	3.82	31.49	-	1.82	-	
Total 20										

I/C LABORATORY

Scientist 'C'

6/73/IT/cell
9/3/22



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/255/4621

Dated: 09/03/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY -2022

1. Name & Address of Ind./Unit : SEN Nursing Home (SNH)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 01.02.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :


Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
						COD (mg/l)				
			6.5-9.0	10	10	50	10	5	2	
1	Phase-I,II (2.2)	Inlet	7.8	264	95	384	18.4	36.23	23.4	Meeting the Standards
		Outlet	7.2	10	08	48	0.8	1.62	1.87	
		OLMS*	7.3	7.54	3.05	22.60	-	0.23	-	
Total 2.2										

I/C LABORATORY

Mishra

Scientist 'C'

6/73/107(41)
9/3/22



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/254/4620

Dated: 09/03/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY -2022


1. Name & Address of Ind./Unit : Keshopur STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.02.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
			6.5-9.0	10	10	COD (mg/l)				
1	12	Inlet	7.4	220	55	256	14.4	32.23	22.2	Not meeting the standards w.r.t. TSS, BOD & Dissolved Phosphate
		Outlet	7.6	34	13	48	2.4	4.20	2.8	
		OLMS*	7.3	7.49	4.62	26.03	-	1.79	-	
Total 12										

I/C LABORATORY

Scientist 'C'

6/13/22/STP(1)
9/13/22



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/253/4619

Dated: 09/03/2022


ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY -2022

1. Name & Address of Ind./Unit : Delhi Gate STP Old
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 01.02.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
			6.5-9.0	10	10	50	10	5	2	
1	Phase-I,II(2.2)	Inlet	7.2	240	105	272	16	34.8	38.8	Meeting the Standards
		Outlet	7.4	10	8	42.6	0.8	2.20	1.86	
		OLMS*	7.1	5.79	6.71	24.9	-	0.53	-	
Total 2.2										

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/252/4618

Dated: 09/03/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY -2022


1. Name & Address of Ind. /Unit : Delhi Gate STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 01.02.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
			6.5-9.0	10	10	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	Phase-I,II(15)	Inlet	7.1	220	80	320	26.4	35.6	20.6	Meeting the Standards.
		Outlet	7.4	8	6	48	0.8	2.12	1.4	
		OLMS*	7.1	7.0	2.95	24.43	-	0.05	-	
		Total 15								

I/C LABORATORY

Scientist 'C'

8/12/22
9/3/22



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/251/4617

Dated: 09/03/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY -2022

1. Name & Address of Ind./Unit : Coronation Pillar STP
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 04.02.2022
4. Samples collected by : DPCC, Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	Parameters COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P(mg/l) 2	Remarks
1	Ph-I,II(20)	Inlet	6.8	364	155	480	20.4	26.2	32.6	Not meeting the standards w.r.t. TSS, BOD, COD, Ammonical Nitrogen & Dissolved Phosphate
		Outlet	7.4	42	17	96	3.6	7.23	4.8	
		OLMS*	-	-	-	-	-	-	-	
2	Ph-III(10)	Inlet	-	-	-	-	-	-	-	Plant was found closed at the time of DPCC monitoring, hence sampling was not done
		Outlet	-	-	-	-	-	-	-	
		OLMS*	-	-	-	-	-	-	-	
Total 30										


Remarks: Ph-I & II OLMS was stolen FIR has been filed as informed.

N. Mittal

I/C LABORATORY

Scientist 'C'

6/7/22
9/3/22



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/275/14641

Date: 09/03/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2022

1. Name & Address of Ind./Unit : Keshopur STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.02.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	Parameters	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
			6.5-9.0	10	10		50	10	5	2	
1	40	Inlet	6.9	256	105		368	18.4	12.23	18.5	Not meeting the Standards w.r.t TSS,BOD,COD, Ammonical Nitrogen & Dissolved Phosphate
		Outlet	7.4	50	35		116	3.2	6.2	6.3	
		OLMS*	-	-	-		-	-	-	-	
2	20	Inlet	6.9	256	105		368	18.4	12.23	18.5	Not meeting the Standards w.r.t TSS, BOD, COD, Ammonical Nitrogen & Dissolved Phosphate
		Outlet	7.4	82	30		96	4.4	5.6	8.2	
		OLMS*	8.5	104.65	82.98		356.93	-	21.31	-	
Total 60											

Remarks: OLMS was found non functional.

Remarks: OLMS was found non-functional at the time of DPCC Monitoring

I/C LABORATORY

Scientist 'C'