



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/365 /2458

02/09/20

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2020

- 1 Name & Address of Ind./Unit
Coronation Pillar STP
- 2 Sampling location
Inlet and Outlet of STP
- 3 Date of Inspection
21.08.20
- 4 Samples collected by
DPCC Lab
- 5 Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
				10	10	50	10	5	2	
1	Ph-I,II(20)	Inlet	6.9	172	110	304	24.4	26.4	7.6	Not meeting the Standards w.r.t BOD,TSS.
		Outlet	7.4	20	14	44	1.6	2.4	1.8	
		OLMS*	-	-	-	-	-	-	-	
	Ph-III(10)	Inlet	7.2	252	200	580	27.2	29.2	8.6	Not meeting the standards w.r.t TSS, BOD,COD.
		Outlet	7.0	36	28	76	1.6	2.3	1.3	
		OLMS*	-	-	-	-	-	-	-	
	Total 30									

I/C LABORATORY

NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi)
4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/366/2459

02/09/20

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2020

1. Name & Address of Ind./Unit

DELHI GATE STP NEW

2. Sampling location

Inlet and Outlet of STP

3. Date of Inspection

18.08.20

4. Samples collected by

DPCC Lab

5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	Phase-I,II(15)	Inlet	7.2	132	105	320	16.4	18.2	7.4	Meeting the Standards.
		Outlet	7.3	4	3	12	0.4	1.2	0.9	
		OLMS*	7.28	3.90	2.48	33.81	-	5.17	-	
	Total 15									

N. Mitra
Dr. NANDITA MOITRA
I/C LABORATORY Scientist 'C'

SR. SCIENTIFIC ASSISTANT

[Signature]



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/367/2460

02/09/20

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2020

1. Name & Address of Ind./Unit

DELHI GATE STP

2. Sampling location

Inlet and Outlet of STP

3. Date of Inspection

18.08.20

4. Samples collected by

DPCC Lab

5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Remarks
1	Phase-I, II (2.2)	Inlet	7.0	152	65	292	18.4	23.2	7.8	Meeting the Standards.
		Outlet	7.2	8	5	12	0.8	1.6	0.6	
		OLMS*	-	-	-	-	-	-	-	
	Total 2.2									

Remarks-OLMS found under maintenance.

I/C LABORATORY

Dr. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/368/2461

02/09/20

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2020

1. Name & Address of Ind./Unit
Keshopur STP new
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
18.08.20
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
	12	Inlet	7.1	140	100	292	18.4	19.6	7.0	
1		Outlet	7.2	16	14	40	1.2	2.0	1.6	
		OLMS*	-	-	-	-	-	-	-	Not Meeting the Standards w.r.t TSS,BOD.
	Total 12									

Remarks: OLMS was found locked.

I/C LABORATORY

N. Mitra

Dr. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT

[Signature]



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)
4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/369/2462

02/09/20

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2020

1. Name & Address of Ind./Unit

Sen Nursing Home (SNH)

2. Sampling location

Inlet and Outlet of STP

3. Date of Inspection

18.08.20

4. Samples collected by

DPCC Lab

5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
1	Phase-I,II(2.2)	Inlet	7.0	116	60	184	15.2	17.6	7.6	Meeting the Standards .
		Outlet	7.1	6	3	8	0.4	1.2	0.4	
		OLMS*	6.85	4.25	2.3	13.9	-	3.87	-	
	Total 2.2									

I/C LABORATORY

Dr. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)
4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/370 /2463

02/09/20

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2020

1. Name & Address of Ind./Unit

Nilothi STP-II

2. Sampling location

Inlet and Outlet of STP

3. Date of Inspection

18.08.20

4. Samples collected by

DPCC Lab

5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Remarks
				10	10	50	10	5	2	
1	20	Inlet	7.2	120	85	292	17.2	19.8	7.3	Meeting the Standards.
		Outlet	7.3	10	6	24	0.8	1.7	0.8	
		OLMS*	7.85	6.32	5.11	9.11	-	3.35		
	Total 20									

N. Moitra
I/C LABORATORY
Dr. NANDITA MOITRA
Scientist 'C'

SR. Scientific Assistant
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/371/2464

02/09/20

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2020

1. Name & Address of Ind./Unit
Nilothi STP
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
18.08.20
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Remarks
				10	10	50	10	5	2	
	40	Inlet	7.2	180	95	228	20.4	23.4	8.6	
1		Outlet	7.3	36	30	80	3.2	5.2	2.0	Not Meeting the Standards w.r.t TSS, BOD, COD, A.N.
		OLMS*	6.55	40.44	22.64	150.64	-	11.41	-	
	Total 40									

I/C LABORATORY

Dr. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT

[Signature]



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/20-21/372/2465

02/09/20

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2020

1. Name & Address of Ind./Unit
Najafgarh STP
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
05.08.20
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Remarks
				10	10	50	10	5	2	
	5	Inlet	7.7	176	120	320	26.4	29.9	8.4	Not meeting the standards w.r.t to TSS, BOD, & D.P.
		Outlet	7.6	26	16	40	1.6	3.9	2.1	
		OLMS*	7.29	23.00	3.34	33.40	-	15.80	-	
	Total 5									

I/C LABORATORY **DR. NANDITA MOITRA**
Scientist 'C'

SR. SCIENTIFIC ASSISTANT

[Signature]



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/373 / 2466

02/9/20

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2020

1. Name & Address of Ind./Unit

Rithala STP

2. Sampling location

Inlet and Outlet of STP

3. Date of Inspection

21.08.20

4. Samples collected by

DPCC Lab

5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	Phase-I(40)	Inlet	7.2	284	165	412	29.6	31.6	8.7	Not meeting the standards w.r.t to TSS,BOD,COD.A.N&D.P.
		Outlet	7.2	76	36	120	4.0	5.4	2.6	
		OLMS*	-	-	-	-	-	-	-	
2	Ph-II(40)	Inlet	7.2	284	165	412	29.6	31.6	8.7	Meeting the Standards.
		Outlet	7.2	10	8	20	0.8	1.3	0.8	
		OLMS*	7.33	15.86	7.80	57.28	-	3.12	-	
	Total 80									

Remarks-ph-I OLMS was not working.

I/C LABORATORY
DR. NANDHA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/374

2467

02/09/20

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2020

1. Name & Address of Ind./Unit
Pappankalan STP(old)
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
18.08.20
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
				10	10	50	10	5	2	
1	20	Inlet	7.1	284	205	480	29.6	34.5	9.6	Not meeting the Standards w.r.t TSS,BOD,A.N,COD&D.P.
		Outlet	7.2	54	28	68	3.2	5.7	3.2	
		OLMS*	-	-	-	-	-	-	-	
	Total 20									

Remarks-OLMS not working due to electrical problem.

I/C LABORATORY

Dr. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT

[Signature]



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi)
4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/376 /2468

02/09/20

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-20 AUGUST-2020

1. Name & Address of Ind./Unit Narela STP
2. Sampling location Inlet and Outlet of STP
3. Date of Inspection 06.08.20
4. Samples collected by DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	10	Inlet	7.2	88	55	260	14.4	19.6	7.4	Not Meeting the Standards w.r.t TSS,BOD
		Outlet	7.4	20	16	44	1.6	2.4	1.4	
		OLMS*	7.54	26.50	26.42	60.86	-	7.60	-	
	Total 10									

I/C LABORATORY

Dr. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/377 / 2469

02/09/20

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2020

1. Name & Address of Ind./Unit
Okhla STP New
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
20.08.20
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	30	Inlet	7.3	104	65	124	15.2	17.2	6.3	Meeting the Standards
		Outlet	7.4	4	2	16	0.4	1.2	0.4	
		OLMS*	7.16	6.08	1.58	17.67	-	2.27	-	
	Total 30									

I/C LABORATORY

Nandita
DR. NANDITA MOITRA
Scientist 'C'

SR. Scientific Assistant
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/378/2470

02/09/20

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2020

1. Name & Address of Ind./Unit **Kondli STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **18.08.20**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Remarks
				10	10	50	10	5	2	
1	25	Inlet	7.2	260	210	412	28.8	31.6	9.2	Not meeting the Standards w.r.t TSS, BOD & COD.
		Outlet	7.2	26	20	64	2.0	3.9	1.7	
		OLMS*	-	-	-	-	-	-	-	
	Total 25									

Remarks; -OLMS found in non-operational condition.

Nandita
Dr. NANDITA MOITRA
Scientist 'C'

I/C LABORATORY

SR. Scientific Assistant
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/379 /2471

02/09/20

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2020

1. Name & Address of Ind./Unit
KONDLI STP New
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
18.08.20
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameter s COD (mg/l)	Oil & Grease (mg/l)	Ammonical/Nitro gen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	45	Inlet	7.2	180	150	420	25.65	28.9	8.9	Not Meeting the Standards w.r.t TSS,BOD&COD&D.P.
		Outlet	7.3	30	24	72	2.4	4.8	2.6	
		OLMS*	-	-	-	-	-	-	-	
	Total 45									

Remarks;OLMS
found locked.

Nandita
DR. NANDITA MOITRA
Scientist 'C'

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT

Abhishek



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/380

2472

02/09/20

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2020

1. Name & Address of Ind./Unit
Kapashera STP
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
11.08.20
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

5.1 Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	5	Inlet	7.1	328	150	380	29.6	34.8	9.6	Meeting the Standards .
		Outlet	7.3	8	4	16	0.8	1.3	0.8	
		OLMS*	-	-	-	-	-	-	-	
		Total 5								

Remarks-OLMS was under maintenance

I/C LABORATORY

Nandita
DR. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT

Shravan



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/381

2473

02/09/20

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2020

1. Name & Address of Ind./Unit
Yamuna Vihar STP Ph-III
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
18.08.20
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	25	Inlet	7.1	308	220	508	29.6	33.4	9.8	Not meeting the Standards w.r.t TSS,BOD,COD&D.P.
		Outlet	7.2	36	28	88	2.4	4.6	2.7	
		OLMS*	7.49	28.86	18.27	123.45	-	13.29	-	
	Total 25									

I/C LABORATORY

Nandita
Dr. NANDITA MOITRA
Scientist 'C'

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/382

12474

02/09/20

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2020

1. Name & Address of Ind./Unit

Chilla STP

2. Sampling location

Inlet and Outlet of STP

3. Date of Inspection

18.08.20

4. Samples collected by

DPCC Lab

5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Remarks
1	9	Inlet	7.2	10 88	10 55	50 164	10 12.8	5 15.2	2 6.8	Meeting the Standards.
		Outlet	7.3	8	6	20	0.4	1.3	0.8	
		OLMS*	-	-	-	-	-	-	-	
		Total 9								

Remarks:-OLMS found in non-operational condition.

Nandita Moitra
DR. NANDITA MOITRA
Scientist 'C'

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT

Abhimanyu



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/383/2475

02/09/20

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2020

1. Name & Address of Ind./Unit Akshardham STP
2. Sampling location Inlet and Outlet of STP
3. Date of Inspection 18.08.20
4. Samples collected by DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	1	Inlet	7.4	96	60	188	12.4	14.6	6.9	Meeting the Standards.
		Outlet	7.5	2	1.4	4	ND	ND	0.2	
		OLMS*	7.63	0.58	1.49	8.43	-	0.91	-	
	Total 1									

I/C LABORATORY

Nandita
Dr. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT

Sh. Anand



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/384

2476

02/09/20

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2020

1. Name & Address of Ind./Unit
Mehrauli STP
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
11.08.20
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
	15	Inlet	7.5	180	100	280	24.4	26.7	9.2	Not meeting the standards w.r.t TSS, BOD, D.P.
		Outlet	7.6	30	14	40	2.0	4.2	2.3	
		OLMS*	7.97	117.78	31.35	93.44	-	19.22	-	
	Total 15									

I/C LABORATORY

Dr. NANDHA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT

[Signature]



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/385 / 2477

02/09/20

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2020

1. Name & Address of Ind./Unit
Vasant Kunj STP
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
11.08.20
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameter s COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	2.2	Inlet	7.1	172	120	340	25.4	27.2	8.1	Not meeting the Standards w.r.t BOD and TSS.
		Outlet	7.2	16	12	32	0.8	2.3	1.3	
		OLMS*	7.63	16.91	13.09	21.59	-	2.29	-	
	3	Inlet	7.0	352	180	440	28.4	30.4	8.8	Not Meeting the Standards w.r.t BOD,TSS.
		Outlet	7.5	20	16	40	1.6	3.6	1.6	
		OLMS*	7.78	13.71	10.21	45.96	-	11.70	-	
	Total 5.2									

I/C LABORATORY

Dr. Nandita Moitra
Dr. NANDITA MOITRA
Scientist 'C'

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/386

12478

02/09/20

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2020

1. Name & Address of Ind./Unit Yamuna Vihar STP
2. Sampling location Inlet and Outlet of STP
3. Date of Inspection 11.08.2020
4. Samples collected by DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
1	10	Inlet	7.2	244	160	388	26.4	28.8	7.8	Not Meeting the Standards w.r.t BOD, TSS, COD, A.N.
		Outlet	7.3	24	16	52	1.6	2.9	1.4	
		OLMS*	6.81	22.80	54.28	270.54	-	7.90	-	
2	10	Inlet	7.2	244	160	388	26.4	28.8	7.8	Not Meeting the Standards w.r.t TSS, BOD & COD.
		Outlet	7.6	32	26	76	2.4	3.9	1.6	
		OLMS*	-	-	-	-	-	-	-	
	Total 20									

I/C LABORATORY

Dr. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT

Belvan



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/03 /2479

02/09/20

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2020

1. Name & Address of Ind./Unit **Molarband mini STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **20.08.2020**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameter s COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Remarks
				10	10	50	10	5	2	
1	2	Inlet	7.3	240	160	288	26.4	28.4	8.8	Not meeting the Standards w.r.t BOD, TSS & D.P.
		Outlet	7.4	24	16	44	3.6	4.7	2.6	
		OLMS*	6.95	31.76	14.14	56.29	-	13.74	-	
	Total 2									

I/C LABORATORY

N. Moitra
Dr. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT

[Signature]



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/387 / 2480

02/09/20

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2020

1. Name & Address of Ind./Unit **Okhla STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **20.08.20**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results


Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameter s COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	12	Inlet	6.9	104	60	164	14.4	16.7	6.3	Not meeting the Standards w.r.t TSS,BOD&COD.
		Outlet	7.0	36	28	76	1.6	2.3	1.3	
		OLMS	9.08	77.32	17.37	86.58	-	9.91	-	
	16	Outlet	7.1	26	18	68	1.2	2.4	1.4	Not meeting the Standards w.r.t TSS,BOD&COD.
		OLMS	-	-	-	-	-	-	-	
	37	Outlet	7.2	28	24	76	1.6	1.9	0.9	Not meeting the Standards w.r.t TSS,BOD&COD.
		OLMS	7.08	30.13	16.78	53.81	-	2.83	-	
	45	Outlet	7.3	24	20	56	1.2	2.2	1.0	Not meeting the Standards w.r.t TSS,BOD&COD.
		OLMS	8.06	29.21	14.81	77.68	-	5.63	-	
	Total 110									

I/C LABORATORY

Nandita
Dr. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT

Shantanu



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/388

2481

02/09/20

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2020

1. Name & Address of Ind./Unit
Keshopur STP
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
18.08.2020
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Remarks
				10	10	50	10	5	2	
	40	Inlet	7.1	204	110	320	22.4	24.3	8.6	
1		Outlet	7.3	36	26	68	3.2	3.6	2.3	
		OLMS*	-	-	-	-	-	-	-	Not meeting the Standards w.r.t TSS,BOD,COD&D.P.
2	20	Inlet	7.1	204	110	320	22.4	24.3	8.6	
		Outlet	7.2	12	7	20	0.8	1.4	0.7	Not meeting the Standards w.r.t TSS.
		OLMS*	-	-	-	-	-	-	-	
	Total 60									

Remarks; -OLMS was found locked.

I/C LABORATORY

Mandita Moitra
MANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT

Sh. Arun



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi)
4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/389

12482

02/09/20

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2020

1. Name & Address of Ind./Unit
2. Sampling location
3. Date of Inspection
4. Samples collected by
5. Parameters analyzed and results

Oxidation pond STP
Inlet and Outlet of STP
21.08.20
DPCC Lab

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l) 50	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
	6	Inlet	-	10	10	-	10	5	2	
		Outlet	-	-	-	-	-	-	-	Non- operational (under rehabilitation)
		OLMS*	-	-	-	-	-	-	-	
	Total 6									

I/C LABORATORY

Nandita
DR. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT

[Signature]



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/20-21/390/2483

02/09/20

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2020

1. Name & Address of Ind./Unit Rohini STP
2. Sampling location Inlet and Outlet of STP
3. Date of Inspection 21.08.20
4. Samples collected by DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	15	Inlet	7.2	120	85	252	16.4	17.6	6.9	Not meeting the Standards w.r.t TSS,BOD.
		Outlet	7.3	18	16	56	1.2	2.6	1.4	
		OLMS*	-	-	-	-	-	-	-	
	Total 15									

Remarks-OLMS found non-functional.

I/C LABORATORY

N. Moitra
Dr. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)
4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/375 / 2484

02/9/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2020

1. Name & Address of Ind./Unit
Pappankalan STP-II (new)
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
18.08.20
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
1	20	Inlet	7.1	300	150	292	30.4	34.7	9.8	Meeting the Standards.
		Outlet	7.2	10	8	24	0.8	2.6	1.2	
		OLMS*	-	-	-	-	-	-	-	
		Total 20								

Remarks-OLMS was under maintenance.

I/C LABORATORY

DR. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT