



DELHI POLLUTION CONTROL COMMITTEE
WATER LABORATORY
4thFLOOR, ISBT BUILDING, KASHMERE GATE, DELHI-06
visit us at : <http://dpcc.delhigovt.nic.in>

WASTE WATER QUALITY STATUS OF DRAIN

REPORT NO: DPCC/W/D/2025/136-162/ 2206
Date of Sampling: - 03/09/2025

dt. 25/09/25

S.No.	Sampling location	pH	TSS (mg/l)	COD (mg/l)	BOD (mg/l)
	Standards	5.5- 9.0	100	250	30
1.	Najafgarh Drain	7.4	113	52	22
2.	Metcalf House Drain	7.5	109	24	7
3.	Khyber Pass Drain	7.6	116	116	34
4.	Sweeper Colony Drain	7.3	113	52	24
5.	Magazine Road Drain	7.5	112	208	88
6.	ISBT Drain	7.2	112	84	32
7.	Tonga Stand Drain	7.2	110	68	27
8.	Civil Mill Drain	7.3	95	164	62
9.	SEN Nursing Home Drain	7.9	121	244	108
10.	Drain No. 14	7.6	99	40	9
11.	Power House Drain	7.2	102	144	38
12.	Indrapuri Drain	Sampling not possible due to flood in rainy season.			
13.	Sonia Vihar Drain				
14.	Kailash Nagar Drain				
15.	Shastri Park Drain				
16.	Barapulla Drain	7.3	117	156	52
17.	Maharani Bagh Drain	7.5	110	240	92
18.	Old Agra Canal Drain	Sampling not possible due to flood in rainy season.			
19.	Jaitpur Drain				
20.	Sarita Vihar Pool				
21.	Tuglakabad Drain	7.1	109	76	18
22.	Drain Near LPG Bottling Plant	Sampling not possible due to flood in rainy season.			
23.	Drain Near Sarita Vihar Bridge (Mathura Road)	7.5	99	184	70
24.	Shahdara Drain	Sampling not possible due to flood in rainy season.			
25.	Sahibabad Drain				
26.	Molarband Drain	TAPPED			
27.	Abul Fazal Drain	Sampling not possible due to flood in rainy season.			

Shakti

I/C WATER LAB

[Signature]

Scientist B