



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/255 JS429

Dated: 07.03/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2023

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 14.02.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	Ph-I,II (20)	Inlet	6.8	300	125	320	20.8	23.5	13.3	Not meeting the standards wrt TSS, BOD COD & Dissolved Phosphate.
		Outlet	7.4	26	14	64	3.2	4.7	2.9	
		OLMS	-	-	-	-	-	-	-	OLMS was non functional
2	Ph-III (70)	Inlet	7.1	256	120	304	16.4	36	32.4	Meeting the standards.
		Outlet	7.2	8	6	30	1.2	3.9	1.5	
		OLMS	7.4	8.61	5.28	15.82	-	0.56	-	
Total 90										

N. Mittal
I/C LABORATORY
Dr. Nandita Mondal
Scientist D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>


Report Number: DPCC/W/STP/22-23/256/5430

Dated: 07.03.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2023

1. Name of STP : Delhi Gate (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of inspection : 10.02.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	Phase-I,II(15)		6.5-9.0	10	10	50	10	5	2	Meeting the Standards.
		Inlet	7.4	280	135	224	28	34.2	14.6	
		Outlet	7.1	10	8	32	2.4	3.7	1.6	
		OLMS	7.1	6.49	4.43	21.11	-	3.39	-	
Total 15										


I/C LABORATORY
Dr. Nandita Moitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/257/5431

Date: 07.03.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2023

1. Name of STP : Delhi Gate (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.02.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
	Phase-I,II(2.2)	Inlet	7.4	240	120	256	25.6	28.1	15.4	Meeting the Standard.
		Outlet	7.1	6	4	28	3.2	4.3	1.9	
		OLMS	8.0	5.87	3.73	16.81	-	1.64	-	
Total 2.2										

I/C LABORATORY

Dr. Nandita Moitra

Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>


Report Number: DPCC/W/STP/22-23/258 / 5432

Dated: 07.03.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2023

1. Name of STP : Keshopur STP (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.02.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	12	Inlet	7.1	276	70	208	18.8	40.2	28.3	Not Meeting the standards wrt TSS & BOD
		Outlet	7.4	18	12	40	1.6	2.8	1.9	
		OLMS	7.6	8.77	5.92	30.36	-	3.51	-	
Total 12										


I/C LABORATORY
Dr. Nandita Moitra
Scientist D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/259/5433


Dated: 07.03.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2023

1. Name of STP : SEN Nursing Home (SNH)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.02.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	Phase-I,II (2.2)	Inlet	7.8	276	125	320	29.6	32.5	24.7	Meeting the Standards.
		Outlet	7.0	8	6	32	3.2	3.0	1.8	
		OLMS	7.9	5.57	2.94	25.37	-	1.85	-	
Total 2.2										

N. Mitra
Dr. Nandita Moitra
I/C LABORATORY
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>


Report Number: DPCC/W/STP/22-23/260/S434

Dated: 07.03.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2023

1. Name of STP : Nilothi New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.02.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	20	Inlet	7.2	168	80	224	15.2	16.2	21.2	Meeting the standards
		Outlet	7.5	8	6	28	2.8	4.0	1.4	
		OLMS	7.5	7.8	4.67	31.83	-	3.0	-	
Total 20										


I/C LABORATORY
Dr. Nandita Moitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE (Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/261/5435

Dated: 07.03.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2023

1. Name of STP : Nilothi
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.02.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	40	Inlet	7.3	160	95	288	20.4	18.2	30.1	Not meeting the standards wrt TSS, BOD & COD.
		Outlet	7.5	38	21	60	2.0	3.4	1.9	
		OLMS	7.7	112.66	57.52	275.62	-	18.70	-	
Total 40										

N. Mitra

Dr. Nandita Mitra
I/C LABORATORY
Scientist 'II'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/22-23/262/5436

Dated: 07.03.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2023

1. Name of STP : Najafgarh
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.02.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	5	Inlet	7.3	244	115	288	20.4	44.8	23.3	Not meeting the standards wrt TSS, BOD, COD and Dissolved Phosphate.
		Outlet	7.5	62	36	104	1.6	4.8	5.1	
		OLMS	7.2	23.00	21.80	92.10	-	13.65	-	
Total 5										

N. Nandita

I/C LABORATORY

Dr. Nandita Moitra

Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/263/S 437

Dated: 07.02.2023


ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2023

1. Name of STP : Rithala
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 20.02.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	Phase-I(40)	Inlet	-	-	-	-	-	-	-	Plant was under Rehabilitation
		Outlet	-	-	-	-	-	-	-	
		OLMS	-	-	-	-	-	-	-	
2	Ph-II(40)	Inlet	7.4	220	105	320	11.2	14.5	20.6	Not Meeting the Standards wrt TSS & BOD.
		Outlet	7.6	18	12	40	1.6	3.2	2.0	
		OLMS	7.4	12.56	8.87	27.72	-	9.47	-	
Total 80										

N. Mittal

Dr. N. Mittal
LABORATORY
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/264/S 438

Dated: 07.03.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2023

1. Name of STP : Pappankalan (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.02.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	20	Inlet	7.3	164	78	208	21.6	17.3	31.7	Not meeting the Standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.1	44	24	80	2.4	4.0	2.2	
		OLMS	7.5	46.32	24.74	119.96	-		-	
Total 20										

N. Mitra
I/C LABORATORY
Dr. Nandita Mohra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>


Report Number: DPCC/W/STP/22-23/265) 5439


Dated : 07.03.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2023

1. Name of STP : Pappankalan Ph-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.02.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
	20	Inlet	7.3	164	78	208	21.6	17.3	31.7	Meeting the Standards.
		Outlet	7.5	6	4	24	2	2.8	1.2	
		OLMS	7.9	7.27	5.02	29.04	-	1.80	-	
Total 20										


Dr. Nandita Mishra
I/C LABORATORY
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/22-23/266/5440


Date: 07.03.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2023

1. Name of STP : Rohini
2. Sampling location : Inlet and Outlet of STP
3. Date of inspection : 20.02.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

37. Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	15	Inlet	7.3	312	120	304	14.0	29.8	23.4	Not meeting the Standards wrt TSS, BOD, , Ammonical Nitrogen & Dissolved Phosphate.
		Outlet	7.5	18	12	48	2.4	5.3	2.9	
		OLMS	7.5	18.15	15.80	86.33	-	12.57	-	
Total 15										


I/C LABORATORY
Dr. Nandita Moitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/267/5441

Date: 07.03.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2023

1. Name of STP : Narela
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 07.02.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	10	Inlet	7.8	228	105	176	14.8	21.9	18.6	Not meeting the standards wrt TSS, BOD & Dissolved Phosphate.
		Outlet	7.4	26	14	48	2.4	1.6	2.1	
		OLMS	7.6	20.6	17.0	87.8	-	-	-	Ammonical Nitrogen reading not shown in OLMS
Total 10										

N. Moitra
I/C LABORATORY
Dr. Nandita Moitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/268/5442

Dated: 07.03.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2023

1. Name of STP : Okhla New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.02.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	30	Inlet	7.8	176	102	216	16.4	24.6	18.5	Meeting the Standards.
		Outlet	7.5	6	4	24	0.8	2.5	1.4	
		OLMS	8.4	6.88	4.39	23.44	-	1.37	-	
Total 30										

I/C LABORATORY
Dr. Nandita Moitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/269/5443

Dated: 07.03.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2023

1. Name of STP : Kondli
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.02.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	Ph-I (10)	Inlet	7.5	208	130	224	29.2	43.2	33.5	Meeting the standards.
		Outlet	7.3	6	4	40	1.6	3.4	1.8	
		OLMS	7.0	6.45	4.22	36.96	-	-	-	Ammonical nitrogen reading not shown in OLMS portal
2	Ph-III (10)	Outlet	7.2	8	6	48	2.0	3.2	1.5	Meeting the standards.
		OLMS	-	-	-	-	-	-	-	OLMS was found locked
Total 20										

N. Mitta
Dr. Nandita Mitta
W/C LABORATORY
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/270/5444

Dated: 07.03.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2023

1. Name of STP : Kondli New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.02.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	45	Inlet	7.6	308	165	256	26.4	35.2	29.6	Not Meeting the Standards wrt TSS, BOD, COD, Ammonical nitrogen & Dissolved Phosphate.
		Outlet	7.1	140	66	190	5.6	14.8	7.5	
		OLMS	-	-	-	-	-	-	-	OLMS was non functional
Total 45										

Nandita
I/C LABORATORY
Dr. Nandita Moura
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE (Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/271/5445

Dated: 09.03.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2023

1. Name of STP : Kapasahera
2. Sampling location : Inlet and Outlet of STP
3. Date of inspection : 03.02.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	5	Inlet	7.2	112	80	224	6.4	27.5	20.1	Meeting the standards
		Outlet	7.4	8	6	34	1.6	4.1	1.8	
		OLMS	7.4	9.64	6.86	36.67	-	4.61	-	
Total 5										

N. Mitra
I/C LABORATORY
Dr. Nandita Moitra
Scientist (D)



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/272 **5446**

Dated: 07.03.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2023

1. Name of STP : Yamuna Vihar Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.02.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	25	Inlet	7.4	368	180	384	23.2	25.8	30.4	Not meeting the Standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.3	26	14	64	3.2	4.5	3.9	
		OLMS	7.5	16.13	6.96	27.41	-		-	
Total 25										

N. Moitra
I/C LABORATORY
Dr. Nandita Moitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/273/5447

Dated: 07.03.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2023

1. Name of STP : Chilla
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.02.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	9	Inlet	7.4	176	135	192	13.6	26.1	19.7	Meeting the Standards.
		Outlet	7.0	4	8	32	2.4	3.3	1.6	
		OLMS	7.5	6.49	4.7	20.47	-	2.34	-	
Total 9										

N. Mitta
Dr. Nandana Mitta
V/LABORATORY
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/274/Sy 48

Dated: 07.03.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2023

1. Name of STP : Akshardham
2. Sampling location : Inlet and Outlet of STP
3. Date of inspection : 10.02.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	1	Inlet	7.3	156	90	160	20.0	16.4	20.1	Meeting the Standards.
		Outlet	7.0	4	6	24	0.8	1.8	1.0	
		OLMS	7.7	0.51	1.20	8.03	-	0.25	-	
Total 1										

N. Mitra
I/C LABORATORY
Dr. Nandita Mitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/275 / 5449

Date: 07.03.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2023

1. Name of STP : Mehrauli
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 03.02.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	15		6.5-9.0	10	10	50	10	5	2	Not meeting the standards wrt TSS, BOD & COD.
		Inlet	7.4	168	90	304	11.2	17.2	33.8	
		Outlet	7.1	30	16	64	3.6	4.1	1.8	
		OLMS	7.5	16.07	9.37	47.98	-	10.63	-	
Total 15										

N. Nandita

I/C LABORATORY
Dr. Nandita Moitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/276/5450

Dated: 07.03.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2023

1. Name of STP : Vasant Kunj
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 03.02.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	2.2	Inlet	7.2	284	135	288	19.6	23.3	27.2	Not meeting the standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.5	26	19	64	3.6	3.9	3.1	
		OLMS	7.7	6.87	5.18	26.11	-	13.63	-	
2	3	Inlet	7.2	236	115	288	7.6	19.9	30.4	Not meeting the standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.3	36	15	80	1.6	4.5	3.0	
		OLMS	7.7	4.99	5.57	30.56	-	10.59	-	
Total 5.2										

Maitra
I/C LABORATORY
Dr. Nandita Maitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE (Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/277 / 5451

Date: 07.03.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2023

1. Name of STP : Yamuna Vihar
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.02.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	10 Ph-1	Inlet	7.2	160	110	320	11.2	11.5	30.7	Not meeting the standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.0	24	16	64	2.0	4.2	3.9	
		OLMS	7.5	7.25	5.88	35.28	-	-	-	
2	10 Ph-2	Inlet	7.6	208	90	240	14.0	22.8	20.5	Not meeting the standard wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.2	28	14	56	2.4	2.6	4.0	
		OLMS	7.7	11.97	9.35	48.62	-	11.41	-	
Total 20										

N. Moitra

I/C LABORATORY
Dr. Nandita Moitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Dated: 07.03.2023

Report Number: DPCC/W/STP/22-23/278 / 5452

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2023

1. Name of STP : Okhla
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.02.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	12	Inlet	7.4	240	110	304	16.4	29.8	20.4	Not meeting the Standards wrt TSS, BOD & COD.
		Outlet	7.1	24	14	56	3.6	2.9	1.8	
		OLMS	7.5	26.35	12.30	30.75	-	5.48	-	
	16	Outlet	7.3	40	24	84	4.0	4.7	2.7	Not meeting the Standards wrt TSS, BOD, COD & Dissolved Phosphate
		OLMS	8.0	23.70	7.83	48.63	-	9.96	-	
	37	Outlet	7.5	22	18	58	1.6	4.5	2.6	Not meeting the Standards wrt TSS, BOD, COD & Dissolved Phosphate.
		OLMS	-	-	-	-	-	-	-	
	45	Outlet	7.2	24	19	56	4.0	3.1	1.8	Not meeting the Standards wrt TSS, BOD & COD
		OLMS	7.4	15.92	8.95	41.79	-	0.92	-	
	Total 110									

Mishra
M.C. LABORATORY
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Dated : 07.03.2023

Report Number: DPCC/W/STP/22-23/279/5453

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2023

1. Name of STP : Keshopur
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.02.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	40	Inlet	7.8	164	80	256	17.6	24.2	15.4	Not meeting the Standards wrt TSS, BOD & COD.
		Outlet	7.3	72	38	120	4.0	4.4	1.8	
		OLMS	7.3	93.0	70.0	269.0	-	30.44	-	
2	20	Inlet	7.8	164	80	256	17.6	24.2	15.4	Not meeting the Standards wrt TSS, BOD, COD & Dissolved phosphate.
		Outlet	7.5	78	34	112	5.6	2.7	5.1	
		OLMS	7.3	101.57	83.08	330.39	-	23.19	-	
Total 60										

Dr. Nandana Mishra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Dated: 07.03.2023

Report Number: DPCC/W/STP/22-23/280/5454

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2023

1. Name of STP : Ghitorini
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 03.02.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	5	Inlet	7.4	100	52	160	5.2	26.8	35.4	Not meeting the Standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.2	58	26	72	2.8	2.1	3.4	
		OLMS	7.5	16.61	13.84	98.0	-	12.11	-	
Total 5										

N. Mittal
I/C LABORATORY
Dr. Nandita Molra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/11/5455

Date: 07.03.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2023

1. Name of STP : Molarband (Mini STP)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.02.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results :										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	0.66	Inlet	7.3	316	130	368	24.8	19.4	18.6	Not meeting the Standards wrt TSS, BOD, COD & Dissolved phosphate.
		Outlet	7.5	32	20	66	4.8	3.8	3.4	
		OLMS	7.2	21.77	17.0	85.5	-	10.52	-	
Total 0.66										

N. Mishra
I/C LABORATORY
Dr. Nandita Moitra
Scientist 'D'