



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/113/ 1230

Dated 10/09/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2024

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 09.08.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	70 MGD	Inlet	7.2	256	125	332	14.4	21.3	20.6	-	Meeting the standards.
		Outlet	7.6	6	5	24	0.4	2.2	1.2	95	
		OLMS	7.6	9.0	6.3	39.7	-	1.9	-	-	
Total 70											

I/C Water Laboratory

Mishra

SSA/Analyst/SLA

[Signature]

Dr. Nandita Mohita

Scientist ID



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpeccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/114/1231

Dated 10/09/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2024

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 09.08.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Fecal Coliform MPN/100ml	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
1	Ph-I,II (20)	Inlet	7.1	284	134	304	16	24.6	26.2	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.4	20	14	56	1.2	2.1	1.6	840	
		OLMS	7.4	14.9	9.9	49.5	-	5.6	-	-	
		Inlet	7.3	189	113	260	15.6	24.1	26.8	-	
2	Ph-III (10)	Outlet	7.5	16	17	72	2.8	1.4	1.8	920	Not meeting the standards wrt TSS, BOD COD & fecal coliform.
		OLMS	-	-	-	-	-	-	-	-	
Total 30											OLMS was non-functional

LC Water Laboratory

Scientist 'D'

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/24-25/115/1232

Dated 10/09/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2024

1. Name of STP : Delhi Gate (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 21.08.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	Phase-I & II (15)	Inlet	6.5-9.0	10	10	50	10	5	2	230	Meeting the Standards.
		Outlet	7.1	210	80	240	12.8	22.2	10.8	-	
		OLMS	7.6	5	4	36	1.2	2.9	0.8	120	
Total 15			7.3	6.6	2.7	22.3	-	1.7	-	-	

I/C Water Laboratory

SSA/Analyst/SLA

Dr. Mandita Mohita
Scientist D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/116/1233

Dated 10/09/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2024

1. Name of STP : Delhi Gate (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 21.08.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	Ph-I & II (2.2)	Inlet	6.5-9.0	10	10	50	10	5	2	230	Meeting the Standards.
		Outlet	7.6	172	100	236	16.8	24.4	14.4	-	
		OLMS	7.3	9	8	32	1.6	2.2	1.5	95	
Total 2.2			7.3	5.0	2.2	15.2	-	1.2	-	-	

Dr. Water Laboratory

Scientist 'D'

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/24-25/117/1234

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2024

Dated 10/09/2024

1. Name of STP : Keshopur STP (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.08.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	12	Inlet	7.2	228	167	312	18.8	20.4	21.8	-	Not meeting the standards wrt TSS, BOD, COD & fecal coliform.
		Outlet	7.5	22	15	76	2.4	2	1.2	930	
		OLMS	7.5	8.6	6.6	30.0	-	4.3	-	-	
Total 12											

I/C Water Laboratory
Dr. Nandita Moitra

Scientist 'D'

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/118/1235

Dated 16/09/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2024

1. Name of STP : SEN Nursing Home (SNH)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 21.08.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	Phase-I,II (2.2)	Inlet	7.5	180	120	248	18.4	26.8	16.6	-	Meeting the Standards
		Outlet	7.2	7	6	24	0.8	2.7	1.2	140	
		OLMS	7.4	2.2	-	13.0	-	2.2	-	-	
Total 2.2											

I/C Water Laboratory

Dr. Nandita Moitra

Scientist 'D'

SSA/Analyst/SLA

Nandita

Abhinav



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/24-25/119/1236

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2024

Dated 10/09/2024

1. Name of STP : Nilothi New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 12.08.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	20	Inlet	7.5	208	140	324	20.8	14.2	11.9	-	Meeting the standards.
		Outlet	7.1	8	7	36	0.8	1.6	1.8	76	
		OLMS	6.8	5.7	5.2	41.1	-	6.2	-	-	
Total 20											

I/C Water Laboratory
Dr. Nandita Moitra

Scientist 'D'

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/120/1237

Dated 10/09/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2024

1. Name of STP : Nilothi
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 12.08.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters									Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml		
1	40	Inlet	6.5-9.0	10	10	50	10	5	2	230	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.	
		Outlet	7.7	272	175	324	17.2	20.4	22.1	-		
		OLMS	7.3	31	20	72	2.8	2	1.1	2400		
Total 40			7.1	25.5	14.5	156.5	-	16.2	-	-		

I/C Water Laboratory

Signature
Dr. Mandita Moitra
Scientist 'D'

SSA/AnalystSLA
Signature



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.mic.in>)



Report Number DPCC/W/STP/24-25/121/1238

Dated 10/09/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2024

1. Name of STP : Najafgarh
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 12.08.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Fecal Coliform MPN/100ml	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
1	5	Inlet	6.5-9.0	10	10	50	10	5	2	230	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
			7.3	206	150	292	14.8	25.6	18.4	-	
		Outlet	7.6	31	12	64	3.6	2.3	1.7	2100	
		OLMS	-	-	-	-	-	-	-	-	OLMS was non functional
Total 5											

I/C Water Laboratory

Mukta

SSA/Analyst/SLA

Dr. Nandita Mohita
Scientist 'D'

Shree



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/122/1239

Dated: 10/09/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2024

1. Name of STP : Rithala
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 07.08.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters									Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml		
1	Ph-I(40)		6.5-9.0	10	10	50	10	5	2	230	Meeting the standards	
		Inlet	7.6	216	120	296	17.6	19.6	22.3	-		
		Outlet	7.5	7	6	44	1.2	1.9	1.7	110		
		OLMS	-	-	-	-	-	-	-	-		
2	Ph-II(40)	Inlet	7.4	224	100	268	22.4	21.2	18.5	-	OLMS was not installed	
		Outlet	7.1	5	4	36	1.6	1.5	1.9	79		
		OLMS	7.3	8.2	7.3	39.7	-	4.9	-	-		
Total 80											Meeting the standards	

I/C Water Laboratory

Murli

Dr. Nandita MONTA

Scientist 'D'

SSA/Analyst/SLA

Alka



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, JSBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/123/1240

Dated 10/09/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2024

1. Name of STP : Pappankalan (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 12.08.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Fecal Coliform MPN/100ml	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)			
1	20	Inlet	7.3	212	114	320	14.4	21.6	23.2	-	Not meeting the Standards wrt TSS, BOD COD & Fecal Coliform.	
		Outlet	7.4	47	13	88	2.8	2.3	1.4	2400		
		OLMS	-	-	-	-	-	-	-	-		
Total 20											OLMS was non functional	

I/C Water Laboratory

M. Mohan

Dr. Nandita Mohita

Scientist 'D'

SSA/Analyst/SLA

Shruti



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocms.nic.in>)



Report Number: DPCC/W/STP/24-25/124/1241

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2024

Dated 10/09/2024

1. Name of STP : Pappankalan Ph-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 12.08.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :


Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
20		Inlet	6.5-9.0	10	10	50	10	5	2	230	Meeting the Standards.
		7.3	212	114	320	14.4	21.6	23.2	-		
		Outlet	7.5	8	3	24	1.6	1.6	1.4	170	
		OLMS	-	-	-	-	-	-	-	OLMS was non functional	
Total 20											

I/C Water Laboratory

Dr. Nandita Moitra

Scientist 'D'

SSA/AnalystSLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocms.nic.in>)



Report Number DPCC/W/STP/24-25/125/1242

Dated 10/09/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2024

1. Name of STP : Rohini
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 07.08.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Fecal Coliform MPN/100ml	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)			
1	15	Inlet	7.6	276	167	304	16.4	19.8	17.6	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform	
		Outlet	7.3	27	16	52	1.6	2.5	1.1	2200		
		OLMS	-	-	-	-	-	-	-	-		
Total 15											OLMS was non-functional	

I/C Water Laboratory

Dr. Nandita Moitra

Scientist 'D'

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/126/1243

Dated 10/09/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2024

1. Name of STP : Narela
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 07.08.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	10	Inlet	6.5-9.0	10	10	50	10	5	2	230	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.1	218	134	276	18.8	21.7	13.9	-	
		OLMS	7.3	33	14	60	2.4	2.3	1.8	2500	
Total 10			8.7	8.8	7.0	36.6	-	9.8	-		

I/C Water Laboratory
Dr. Nandita Moitra
Scientist 'D'

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/24-25/127/1244

Dated 10/09/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2024

1. Name of STP : Okhla New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.08.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	30	Inlet	7.5	264	175	316	18.4	18.6	24.3	-	Meeting the Standards.
		Outlet	7.1	8	5	40	1.6	2.4	1.2	120	
		OLMS	7.1	7.2	3.7	23.9	-	0.9	-	-	
Total 30											

I/C Water Laboratory

Dr. Nandita Moitra

Scientist D

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/24-25/128/245

Dated 10/09/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2024

1. Name of STP : Kondli
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 21.08.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Fecal Coliform MPN/100ml	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)			
1	Ph-I (10)	Inlet	7.4	224	160	240	11.6	28.4	23.7	-	Meeting the standards.	
		Outlet	7.3	6	4	20	1.2	3.4	1.5	130		
		OLMS	-	-	-	-	-	-	-	-		OLMS was non-functional
2	Ph-II & III (25+10)	Outlet	7.5	7	3	24	1.6	4.3	1.7	140	Meeting the standards	
		OLMS	-	-	-	-	-	-	-	-	OLMS was non-functional	
Total 45												

M. M. M. M.

I/C Water Laboratory
Dr. Nandita Moitra

Scientist 'D'

SSA/Analyst/SLA

A. K. S.



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocms.nic.in>)



Report Number: DPCC/W/STP/24-25/129/1246

Dated 10/09/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2024

1. Name of STP : Kondli New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 21.08.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	Ph-IV (45)	Inlet	7.3	162	120	244	14.4	22.7	23.4	-	Meeting the Standards.
		Outlet	7.4	7	8	32	0.8	2.3	1.6	84	
		OLMS	7.3	170.4	23.4	59.9	-	10.9	-	-	
Total 45											


I/C Water Laboratory

Dr. Nandita Moirra

Scientist 'D'

SSA/Analyst/SLA

Signature



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocems.nic.in>)



Report Number: DPCC/W/STP/24-25/130/1249

Dated 10/09/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2024

1. Name of STP : Kapasahera
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.08.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters											Remarks
Sr. No.	Installed Capacity (MGd)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	5	Inlet	7.5	212	167	264	19.6	23.6	13.2	-	Meeting the standards.
		Outlet	7.6	5	3	8	1.6	2.4	1.4	130	
		OLMS	7.8	9.3	3.8	42.5	-	3.3	-	-	
Total 5											

I/C Water Laboratory

Maita

Dr. Nandita Moitra

Scientist 'D'

SSA/Analyst/SLA

Heath



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/24-25/131/1248

Dated 10/09/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2024

1. Name of STP : Yamuna Vihar Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.08.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	25	Inlet	7.3	150	133	272	11.6	16.4	27.2	-	Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.5	24	15	64	2.8	1.8	1.2	1800	
		OLMS	7.1	22.1	13.6	53.5	-	19.6	-	-	
Total 25											

I/C Water Laboratory

Dr. Nandita Moitra

Scientist 'D'

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/24-25/132/1249

Dated 10/09/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2024

1. Name of STP : Chilla
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 21.08.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :


Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Fecal Coliform MPN/100ml	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
1	9	Inlet	7.3	192	140	244	13.6	23.4	12.4	-	Meeting the Standards.
		Outlet	7.6	8	5	24	0.4	2.2	1.4	81	
		OLMS	7.1	7.8	6.0	33.0	-	1.9	-	-	
Total 9											

I/C Water Laboratory

Dr. Nandita Morita

Scientist 'B'

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/133/1250

Dated 10/09/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2024

1. Name of STP : Akshardham
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 21.08.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :


Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	1	Inlet	7.4	176	125	232	14.8	18.2	13.4	-	Meeting the Standards.
		Outlet	7.7	3	4	28	1.2	1.6	1.3	79	
		OLMS	7.6	0.8	1.7	6.9	-	0.2	-	-	
Total 1											

I/C Water Laboratory

Dr. Nandita Moitra
Scientist 'D'

SSA/Analyst/SLA

[Signature]



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/134/1251

Dated 10/09/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2024

1. Name of STP : Mehrauli
2. Sampling Location : Inlet and Outlet of STP
3. Date of Inspection : 14.08.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	15	Inlet	7.1	204	120	312	12.4	13.1	26.2	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.4	25	15	88	1.6	2.6	1.7	1700	
		OLMS	7.4	20.7	8.8	58.6	-	13.9	-	-	
Total 15											

Maitra

I/C Water Laboratory

Dr. Nandita Moitra

Scientist 'D'

SSA/Analyst/SLA

SSA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/135/1252

Dated 10/09/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2024

1. Name of STP : Vasant Kunj
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.08.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Fecal Coliform MPN/100ml	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
1	2.2	Inlet	7.2	178	117	292	14.4	18.4	26.2	-	Not meeting the standards wrt TSS,BOD COD & Fecal Coliform.
		Outlet	7.4	60	23	124	3.2	1.6	1.3	2200	
		OLMS	7.7	7.0	4.6	30.2	-	7.6	-	-	
2	3	Inlet	7.4	160	114	308	12.8	18.2	25.1	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.3	50	30	100	1.2	2.8	1.1	1100	
		OLMS	7.0	6.6	4.4	29.3	-	8.9	-	-	
Total 5.2											

I/C Water Laboratory

SSA/Analyst/SLA

Dr. Nandita Moitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/136/1253

Dated 10/09/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2024

1. Name of STP : Yamuna Vihar
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.08.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	10 Ph-1	Inlet	6.5-9.0	10	10	50	10	5	2	230	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
			7.1	148	100	220	15.2	14.3	22.7	-	
		Outlet	7.4	44	13	96	1.6	2.6	1.5	2500	
		OLMS	7.2	15.0	9.0	37.3	-	21.0	-	-	
2	10 Ph-2	Inlet	7.5	168	113	268	12.4	16.5	21.4	-	Not meeting the standard wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.2	25	11	60	1.2	2.3	1.7	640	
		OLMS	7.4	8.7	5.8	29.8	-	4.9	-	-	
		Total 20									

M. M. M. M.

Shash

I/C Water Laboratory

SSA/Analyst/SILA

Dr. Nandita Moitra

Signature ID



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/137/1254

Dated 10/09/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2024

1. Name of STP : Molarband (Mini STP)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.08.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	0.66	Inlet	7.3	252	150	50	10	5	20.8	-	Not meeting the standard wrt BOD, COD & Fecal Coliform.
		Outlet	7.6	30	15	63	2.4	2.6	1.4	1500	
		OLMS	7.0	45.2	-	-	-	14.4	-	-	
Total 0.66											BOD & COD Readings not show OLMS

I/C Water Laboratory

SSA/Analyst/SLA

Dr. Nandita Moitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocms.nic.in>)



Report Number: DPCC/W/STP/24-25/138/1255

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2024

Dated 10/09/2024

1. Name of STP : Okhla
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.08.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Fecal Coliform MPN/100ml	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
	12	Inlet	6.5-9.0	10	10	50	10	5	2	230	Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.6	256	175	324	19.2	24.9	21.4	-	
		OLMS	7.1	23	14	64	2.8	2.6	1.9	1700	
		OLMS	7.2	18.2	5.3	19.9	-	14.6	-	-	
		Outlet	7.7	9	8	32	1.2	1.5	0.7	130	
1	16	OLMS	6.7	9.5	7.4	32.6	-	3.5	-	-	Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.4	29	18	80	2.4	2.3	1.3	1800	
		OLMS	7.0	31.0	19.6	58.36	-	13.0	-	-	
	45	Outlet	7.3	24	15	72	1.6	2.1	1.1	2100	Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform.
		OLMS	6.8	21.6	12.3	61.6	-	9.2	-	-	
Total 110											

I/C Water Laboratory

SSA/Analyst/SLA

Dr. Nandita Mohita

Scientist (D)



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/139/1256

Dated 16/09/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2024

1. Name of STP : Keshopur
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.08.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	40	Inlet	6.5-9.0 7.1	10 220	10 150	50 324	10 17.6	5 23.3	2 19.4	230 -	Not meeting the Standards wrt BOD, COD & Fecal Coliform.
		Outlet	7.3	14	15	64	1.2	3	1.4	430	
		OLMS	13.0	58	31	196	-	15.0	-	-	
2	20	Outlet	7.4	22	20	56	2.4	3.2	1.6	1400	Not meeting the Standards wrt BOD, COD & Fecal Coliform.
		OLMS	7.5	18.6	14.8	85.5	-	12.6	-	-	
Total 60											

Mukta
I/C Water Laboratory
Dr. Nandita Moitra
Scientist D

[Signature]
SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocms.nic.in>)



Report Number: DPCC/W/STP/24-25/140/1257

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2024

Dated 10/09/2024

1. Name of STP : Ghitorni
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.08.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	5	Inlet	7.5	212	150	316	13.2	18.6	23.6	-	Not meeting the Standards wrt T BOD, COD & Fecal Coliform.
		Outlet	7.2	57	36	92	0.8	1.4	1.2	810	
		OLMS	7.4	18.5	12.6	71.5	-	14.6	-	-	
Total 5											

I/C Water Laboratory

Dr. Nandita Moitra

Signed by

SSA/Analyst/SLA

[Signature]