



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/05/771

Dated 09/09/2019

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2019


1. Name & Address of Ind./Unit
Molarband mini STP
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
14.08.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Remarks
1	2	Inlet	7.8	50 364	30 230	250 680	10 32.8	50 36.9	5 8.7	Not meeting the Standards w.r.t BOD.
		Outlet	7.9	46	32	88	4.8	5.9	4.6	
		OLMS*	-	-	-	-	-	-	-	
	Total 2									

I/C LABORATORY

Misha

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/104/772

Dated 09/09/2019

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST- 2019

- 1 Name & Address of Ind./Unit
Coronation Pillar STP
- 2 Sampling location
Inlet and Outlet of STP
- 3 Date of Inspection
13-08-2019
- 4 Samples collected by
DPCC Lab
- 5 Parameters analyzed and results


Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				50	30	250	10	50	5	
1	Ph-I,II(20)	Inlet	7.7	104	85	240	17.2	26.4	7.2	Not meeting the standards w.r.t to BOD.
		Outlet	7.7	48	32	96	3.6	4.6	1.9	
		OLMS*	-	-	-	-	-	-	-	
	Ph-III(10)	Inlet	7.6	276	190	560	32.4	36.6	8.8	Not meeting the w.r.t TSS and BOD.
		Outlet	7.7	72	64	180	4.4	4.8	2.3	
		OLMS*	-	-	-	-	-	-	-	
	Total 30									

*Remarks:

OLMS was found locked

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/105/773

Dated 09/09/2019


ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST- 2019

1. Name & Address of Ind./Unit **DELHI GATE STP NEW**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **08.08.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	250	10	50	5	
1	Phase-I,II(15)	Inlet	7.7	76	55	160	16.4	21.6	6.3	Meeting the Standards.
		Outlet	7.6	6	4	16	0.4	1.6	1.2	
		OLMS*	7.0	9.13	6.25	20.61	-	3.98	-	
	Total 15									

Mehta
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/106 774

Dated 09/09/2019


ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST- 2019

1. Name & Address of Ind./Unit **DELHI GATE STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **08.08.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters		Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
						COD (mg/l)	Oil & Grease (mg/l)			
				10	10	250	10	50	5	
1	Phase-I,II(2.2)	Inlet	7.8	116	85	214	18.4	23.4	6.8	Meeting the Standards.
		Outlet	7.8	10	8	24	0.4	1.3	0.9	
		OLMS*	6.79	8.85	7.84	40.4	-	0.59	-	
	Total 2.2									

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/107 / 775

Dated 09/09/2019

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST- 2019

1. Name & Address of Ind./Unit **Keshopur STP new**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **09.08.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				30	20	250	10	50	5	
1	12	Inlet	7.5	152	130	360	20.8	24.6	7.0	Not meeting the Standards w.r.t TSS and BOD.
		Outlet	7.6	32	28	68	1.6	2.9	1.3	
		OLMS*	7.7	7.39	3.22	19.15	-	0.59	-	
	Total 12									

I/C LABORATORY

Mishra

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/108

1776

Dated 09/09/2019

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST- 2019

1. Name & Address of Ind./Unit
Sen Nursing Home (SNH)
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
08.08.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	250	10	50	5	
1	Phase-I,II(2.2)	Inlet	7.8	80	60	172	14.4	20.4	5.9	Meeting the Standards.
		Outlet	7.7	8	6	20	0.8	2.0	1.1	
		OLMS*	7.32	7.07	4.77	15.48	-	1.73	-	
	Total 2.2									

I/C LABORATORY

N. Mukherjee

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/109 / 777

Dated 09/09/2019

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST- 2019

1. Name & Address of Ind./Unit **Nilothi STP-II**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **09.08.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
				10	10	250	10	50	5	
1	20	Inlet	7.7	56	42	120	12.4	20.6	5.8	Meeting the Standards.
		Outlet	7.5	10	8	28	0.4	1.3	0.4	
		OLMS*	7.0	14.33	2.50	14.89	-	5.31	-	
	Total 20									

I/C LABORATORY

N. Mitra

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/110

778

Dated 09/09/2019


ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST- 2019

1. Name & Address of Ind./Unit
Nilothi STP
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
09.08.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Remarks
				10	10	250	10	50	5	
1	40	Inlet	7.6	208	165	480	24.4	32.4	7.6	Not meeting the Standards w.r.t TSS and BOD.
		Outlet	7.7	52	36	104	4.4	5.2	2.6	
		OLMS*	7.4	28.85	24.59	103.92	-	17.97	-	
	Total 40									

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/111 / 779

Dated 09/09/2019

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST- 2019


1. Name & Address of Ind./Unit
Najafgarh STP
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
09.08.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

5. Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				50	30	250	10	50	5	
1	5	Inlet	7.5	128	95	280	16.4	21.6	6.1	Not meeting the Standards w.r.t TSS and BOD.
		Outlet	7.7	54	38	108	3.6	6.1	2.8	
		OLMS*	-	-	-	-	-	-	-	
	Total 5									

Remarks:- OLMS was found locked

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/112

780

Dated 09/09/2019

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST- 2019


1. Name & Address of Ind./Unit **Rithala STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **13.08.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				50	30	250	10	50	5	
1	Phase-I(40)	Inlet	7.7	284	220	620	32.8	34.6	6.4	Not meeting the standards w.r.t to TSS and BOD.
		Outlet	7.7	78	60	160	16.4	6.0	3.2	
		OLMS*	-	-	-	-	-	-	-	
2	Ph-II(40)	Inlet	7.7	284	220	620	32.8	34.6	6.4	Meeting the standards.
		Outlet	7.8	46	30	96	4.8	4.9	2.6	
		OLMS*	-	-	-	-	-	-	-	
	Total 80									

*Remarks: OLMS was under maintenance

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/113/781

Dated 09/09/2019

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST- 2019


1. Name & Address of Ind./Unit **Pappankalan STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **09.08.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				50	30	250	10	50	5	
1	20	Inlet	7.6	144	110	320	14.4	20.4	6.4	Not meeting the Standards w.r.t TSS and BOD.
		Outlet	7.7	56	32	80	1.6	2.3	1.6	
		OLMS*	-	-	-	-	-	-	-	
	Total 20									

Remarks: OLMS was found locked

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/114/782

Dated 09/09/2019

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST- 2019


1. Name & Address of Ind./Unit Pappankalan STP-II
2. Sampling location Inlet and Outlet of STP
3. Date of Inspection 09.08.19
4. Samples collected by DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	250	10	50	5	
1	20	Inlet	7.6	144	120	340	20.4	28.6	5.9	Not meeting the Standards w.r.t TSS and BOD.
		Outlet	7.6	18	12	36	0.4	1.8	1.2	
		OLMS*	6.9	10.61	4.11	29.86	-	1.54	-	
	Total 20									

I/C LABORATORY

N. Misha

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/115 | 783

Dated 09/09/2019

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST- 2019

1. Name & Address of Ind./Unit **Rohini STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **13.08.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results


Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	250	10	50	5	
1	15	Inlet	7.6	128	95	276	17.6	24.8	7.0	Not meeting the Standards w.r.t TSS and BOD.
		Outlet	7.9	56	34	96	5.2	6.2	3.4	
		OLMS*	-	-	-	-	-	-	-	
	Total 15									

I/C LABORATORY

N. Mehta

SR. SCIENTIFIC ASSISTANT

[Signature]



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/116/784

Dated 09/09/2019

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST- 2019

1. Name & Address of Ind./Unit
Narela STP
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
13.08.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results


5.1 Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				50	30	250	10	50	5	
1	10	Inlet	7.8	200	160	460	26.4	30.6	6.1	Not meeting the Standards w.r.t TSS and BOD.
		Outlet	8.1	88	64	184	6.4	5.4	3.6	
		OLMS*	-	-	-	-	-	-	-	
	Total 10									

Remarks: OLMS was found locked

I/C LABORATORY

[Signature]

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/117 / 785

Dated 09/09/2019

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST- 2019


1. Name & Address of Ind./Unit **Okhla STP New**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **09.08.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	250	10	50	5	
1	30	Inlet	7.9	332	220	640	28.8	29.6	5.9	Meeting the Standards.
		Outlet	7.8	10	6	20	0.4	0.8	0.2	
		OLMS*	-	-	-	-	-	-	-	
	Total 30									

I/C LABORATORY

Misha

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/118

786

Dated 09/09/2019

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST- 2019


1. Name & Address of Ind./Unit **Kondli STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **14.08.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	25	Inlet	7.8	280	210	620	29.6	32.8	8.0	Not meeting the Standards w.r.t TSS and BOD.
		Outlet	8.0	22	18	52	2.4	4.3	1.5	
		OLMS*	-	-	-	-	-	-	-	
	Total 25									

I/C LABORATORY

N. Mishra

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/119 / 787

Dated 09/09/2019


ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2019

6. Name & Address of Ind./Unit **Oxidation pond STP**
7. Sampling location **Inlet and Outlet of STP**
8. Date of Inspection **13.08.19**
9. Samples collected by **DPCC Lab**
10. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters		Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
						COD (mg/l)	Oil & Grease (mg/l)			
				50	30	250	10	50	5	
	6	Inlet	-	-	-	-	-	-	-	Non- operational due to under rehabilitation.
		Outlet	-	-	-	-	-	-	-	
		OLMS*	-	-	-	-	-	-	-	
	Total 6									

N. Mitha
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/120 **1788**

Dated 09/09/2019

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2019


1. Name & Address of Ind./Unit **Kapashera STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **05.08.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	5			10	10	250	10	50	5	Not meeting the Standards w.r.t TSS and BOD.
		Inlet	7.8	164	125	368	24.8	26.2	6.4	
		Outlet	7.6	24	16	48	2.0	2.9	1.2	
		OLMS*	6.8	12.7	6.08	33.90	-	4.37	-	
	Total 5									

I/C LABORATORY

N. Mishra

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/121/789

Dated 09/09/2019

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2019


1. Name & Address of Ind./Unit
Yamuna Vihar STP Ph-III
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
22.08.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				30	20	250	10	50	5	
1	25	Inlet	7.5	220	165	484	29.6	32.2	8.0	Not meeting the Standards w.r.t TSS and BOD.
		Outlet	7.7	44	32	96	6.4	7.4	4.2	
		OLMS*	7.3	46.54	18.75	70.38	-	7.35	-	
	Total 25									

I/C LABORATORY

N. Mehta

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/122/776

Dated 07/09/2019

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST- 2019


1. Name & Address of Ind./Unit **Yamuna Vihar STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **22.08.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				50	30	250	10	50	5	
1	10	Inlet	7.5	392	230	660	32.4	35.4	8.3	Not meeting the Standards w.r.t TSS and BOD.
		Outlet	7.5	52	36	108	8.4	9.2	4.8	
		OLMS*	7.39	60.71	31.80	104.11	-	13.76	-	
	10	Inlet	7.5	392	230	660	32.4	35.4	8.3	Not meeting the Standards w.r.t BOD
		Outlet	7.7	48	34	104	3.23	4.3	2.6	
		OLMS*	7.35	46.54	18.75	70.38	-	26.61	-	
	Total 20									

I/C LABORATORY

N. Mishra

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/123 / 79/

Dated 09/09/2019

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST- 2019

1. Name & Address of Ind./Unit **Chilla STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **22.08.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results


Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	9	Inlet	7.8	244	190	564	30.4	33.6	7.8	Not meeting the Standards w.r.t TSS and BOD.
		Outlet	7.8	22	16	48	2.0	3.4	3.0	
		OLMS*	-	-	-	-	-	-	-	
		Total 9								

Remarks: OLMS was found locked

I/C LABORATORY

Mishra

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/124 / 792

Dated 09/09/2019

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST- 2019

1. Name & Address of Ind./Unit
Akshardham STP
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
22.08.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	1	Inlet	7.9	264	190	560	24.4	26.4	6.9	Meeting the Standards.
		Outlet	8.0	3	2	4	ND	ND	ND	
		OLMS*	7.2	0.17	0.13	1.44	-	0.43	-	
		Total 1								

I/C LABORATORY

Mishra

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/125/793

Dated 09/09/2019

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST- 2019


1. Name & Address of Ind./Unit
Mehrauli STP
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
22.08.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
1	15	Inlet	8.0	50 252	30 185	250 540	10 23.6	50 27.6	5 29.8	Not meeting the Standards w.r.t BOD.
		Outlet	8.2	42	32	96	4.0	6.2	4.0	
		OLMS*	7.31	24.27	17.07	75.58	-	15.42	-	
		Total 15								

I/C LABORATORY

N. Mishra

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/126/794

Dated 07/09/2019

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2019

1. Name & Address of Ind./Unit
Vasant Kunj STP
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
22.08.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Remarks
1	2.2	Inlet	7.4	228	165	480	26.4	28.2	6.1	Not meeting the Standards w.r.t BOD.
		Outlet	7.6	48	34	104	2.8	3.2	3.6	
		OLMS*	7.69	8.29	9.21	43.56	-	12.60	-	
	3	Inlet	7.6	144	120	352	24.4	29.8	6.4	Meeting the Standards
		Outlet	7.7	32	26	72	3.2	4.2	2.1	
		OLMS*	6.53	12.26	7.02	35.96	-	5.22	-	
	Total 5.2									

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/127/795

Dated 09/09/2019

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2019


1. Name & Address of Ind./Unit
Okhla STP
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
14.08.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
1	12	Inlet	7.9	50 212	30 175	250 520	10 26.8	50 26.0	5 6.3	Meeting the Standards
		Outlet	8.0	36	24	76	2.4	4.3	1.8	
	16	Outlet	8.0	42	30	108	2.0	3.5	1.2	Meeting the Standards
	37	Outlet	8.0	18	12	36	1.2	1.8	0.9	Meeting the Standards
	45	Outlet	7.9	16	12	40	0.8	1.8	0.7	Meeting the Standards
	Total 110									Meeting the Standards

I/C LABORATORY

Mika

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/128 / 776

Dated 09/09/2019

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST- 2019

1. Name & Address of Ind./Unit **Keshpur STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **09.08.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
1	40	Inlet	7.6	50 140	30 115	250 320	10 21.2	50 28.6	5 703	Not meeting the Standards w.r.t TSS and BOD.
		Outlet	7.6	92	76	216	4.4	5.3	3.3	
		OLMS*	7.39	60.71	31.80	104.11	-	13.76	-	
	20	Inlet	7.6	140	115	320	21.2	28.6	703	Not meeting the Standards w.r.t TSS and BOD
		Outlet	7.5	52	38	108	3.6	4.8	2.6	
		OLMS*	7.16	405.86	102.48	370.84	-	30.0	-	
	Total 60									

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/129/797

Dated 09/09/2019

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST- 2019

1. Name & Address of Ind./Unit
Kondli STP New
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
14.08.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
1	45	Inlet	7.8	280	210	620	29.6	32.8	8.0	Not meeting the Standards w.r.t TSS and BOD.
		Outlet	7.9	20	16	44	2.0	2.9	1.6	
		OLMS*	-	-	-	-	-	-	-	
	Total 45									

Remarks: OLMS was found locked

I/C LABORATORY

Mehra

[Signature]
SR. SCIENTIFIC ASSISTANT