

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)

**ANALYSIS REPORT OF OKHLA CETP (24 MLD) FOR THE MONTH OF JULY 2025**


Report Number: DPCC/W/CETP/25-26/40/2038

Dated: 01/08/2025

1. Name & Address of Ind. / Unit : OKHLA CETP (24 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 02.07.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS*
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.6	5.5-9.0	7.3	6-9	OLMS was Non-functional
2	TSS	175	600	46	100	
3	COD	424	750	100	250	
4	BOD (3 days at 27° C)	210	300	26	30	
5	Oil & Grease	12	20.0	2.4	10.0	
6	Ammonical Nitrogen as N	7.3	50	0.6	50	
7	Sulphide	4.5	5.0	3.0	2.0	
8	Phosphate	6.6	15.0	1.4	5.0	

All values are in mg/l except pH
Flow: 2.214 MLD


I/C Water Laboratory


Scientist B /Analyst

Dr. Shweta Gupta
Incharge (Water Laboratory)

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)**ANALYSIS REPORT OF JHILMIL CETP (16.8 MLD) FOR THE MONTH OF JULY 2025**Report Number: DPCC/W/CETP/25-26/41/ **2039**Dated: **01/08/2025**

1. Name of CETP : **JHILMIL CETP (16.8 MLD)**
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 04. 07.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.4	5.5-9.0	7.1	6-9	6.33
2	TSS	236	600	38	100	49.76
3	COD	440	750	76	250	127.39
4	BOD (3 days at 27° C)	170	300	26	30	16.72
5	Oil & Grease	21.2	20.0	2.0	10.0	
6	Ammonical Nitrogen as N	14.6	50	5.4	50	
7	Sulphide	3.1	5.0	1.2	2.0	
8	Phosphate	0.8	15.0	0.3	5.0	

All values are in mg/l except pH

Flow: 4.5368 MLD

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

Scientist B/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



ANALYSIS REPORT OF NARELA CETP (24 MLD) FOR THE MONTH OF JULY 2025

Report Number: DPCC/W/CETP/25-26/42/2040

Dated: 01/08/2025

1. Name & Address of Ind. / Unit : NARELA CETP (22.5 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 07.07.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.6	5.5-9.0	7.4	6-9	7.74
2	TSS	208	600	24	100	3.1
3	COD	368	750	40	250	20.3
4	BOD (3 days at 27° C)	190	300	16	30	3.7
5	Oil & Grease	19.2	20.0	2.8	10.0	-
6	Ammonical Nitrogen as N	10.3	50	3.6	50	-
7	Sulphide	3.8	5.0	1.4	2.0	-
8	Phosphate	1.8	15.0	0.2	5.0	-

All values are in mg/l except pH
Flow: 9.933MLD

I/C Water Laboratory

Scientist B/Analyst

Dr. Shweta Gupta
Incharge (Water Laboratory)

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)**ANALYSIS REPORT OF BAWANA CETP (35 MLD) FOR THE MONTH OF JULY 2025**

Report Number: DPCC/W/CETP/25-26/43/2041

Dated: 04/08/2025

1. Name & Address of Ind. / Unit : **BAWANA CETP (35 MLD)**
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 07.07.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.7	5.5-9.0	7.2	6-9	7.79
2	TSS	184	600	40	100	16.76
3	COD	448	750	92	250	28.20
4	BOD (3 days at 27° C)	200	300	23	30	7.05
5	Oil & Grease	32.8	20.0	3.2	10.0	-
6	Ammonical Nitrogen as N	15.6	50	3.2	50	-
7	Sulphide	4.2	5.0	1.3	2.0	-
8	Phosphate	2.3	15.0	0.3	5.0	-

All values are in mg/l except pH

Flow: 29.1034 MLD

I/C Water Laboratory

Scientist B/Analyst

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)

**ANALYSIS REPORT OF GTK CETP (6 MLD) FOR THE MONTH OF JULY 2025**Report Number: DPCC/W/CETP/25-26/44/ **2042**Dated: **01/08/2025**

1. Name & Address of Ind. / Unit : **GTK CETP (6 MLD)**
2. Sampling location : **Inlet and Outlet of CETP**
3. Date of Sampling : **08.07.2025**
4. Sample analyzed and results : **DPCC LAB**
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.5	5.5-9.0	7.2	6-9	OLMS was Non-functional
2	TSS	484	600	84	100	
3	COD	656	750	152	250	
4	BOD (3 days at 27° C)	250	300	43	30	
5	Oil & Grease	12	20.0	1.2	10.0	
6	Ammonical Nitrogen as N	21.6	50	3.6	50	
7	Sulphide	4.2	5.0	1.6	2.0	
8	Phosphate	3.3	15.0	0.2	5.0	

All values are in mg/l except pH
Flow: 1.88 MLD

I/C Water Laboratory

Scientist B Analyst

Dr. Shweta Gupta
Incharge (Water Laboratory)

**DELHI POLLUTION CONTROL COMMITTEE**


(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)

**ANALYSIS REPORT OF WAZIRPUR CETP (24 MLD) FOR THE MONTH OF JULY 2025**Report Number: DPCC/W/CETP/25-26/45/ **1043**Dated: **01/08/2025**

1. Name & Address of Ind. / Unit : **WAZIRPUR CETP (24 MLD)**
2. Sampling location : **Inlet and Outlet of CETP**
3. Date of Sampling : **08.07.2025**
4. Sample analyzed and results : **DPCC LAB**
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS*
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.8	5.5-9.0	7.6	6-9	8.35
2	TSS	368	600	40	100	48.2
3	COD	552	750	80	250	81.4
4	BOD (3 days at 27° C)	210	300	26	30	10.2
5	Oil & Grease	8.0	20.0	1.6	10.0	-
6	Ammonical Nitrogen as N	26.4	50	1.5	50	-
7	Sulphide	3.5	5.0	1.3	2.0	-
8	Phosphate	0.5	15.0	0.1	5.0	-

All values are in mg/l except pH
Flow: - 5.142MLD


I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)


Scientist B /Analyst

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)**ANALYSIS REPORT OF SMA CETP (12 MLD) FOR THE MONTH OF JULY 2025**

Report Number: DPCC/W/CETP/25-26/46/2044

Dated: 01/08/2025

1. Name & Address of Ind. / Unit : SMA CETP (12 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 08.07.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.4	5.5-9.0	7.1	6-9	7.22
2	TSS	184	600	46	100	43.57
3	COD	496	750	80	250	95.86
4	BOD (3 days at 27° C)	230	300	28	30	14.1
5	Oil & Grease	20.8	20.0	4.0	10.0	-
6	Ammonical Nitrogen as N	15.7	50	1.3	50	-
7	Sulphide	4.9	5.0	3.2	2.0	-
8	Phosphate	1.8	15.0	0.1	5.0	-

All values are in mg/l except pH

Flow: 2.268 MLD

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



ANALYSIS REPORT OF NANGLOI CETP (12 MLD) FOR THE MONTH OF JULY 2025

Report Number: DPCC/W/CETP/25-26/47/2045

Dated: 01/08/2025

1. Name & Address of Ind. / Unit : NANGLOI CETP (12 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 09.07.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.8	5.5-9.0	7.4	6-9	7.05
2	TSS	284	600	42	100	27.5
3	COD	376	750	88	250	46.3
4	BOD (3 days at 27° C)	130	300	23	30	12.2
5	Oil & Grease	23.2	20.0	2.4	10.0	-
6	Ammonical Nitrogen as N	8.3	50	2.0	50	-
7	Sulphide	4.3	5.0	1.5	2.0	-
8	Phosphate	1.9	15.0	0.1	5.0	-

All values are in mg/l except pH

Flow: 3.173 MLD

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

Scientist B/Analyst

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)

**ANALYSIS REPORT OF MANGOLPURI CETP (2.4 MLD) FOR THE MONTH OF JULY 2025**Report Number: DPCC/W/CETP/25-26/48/ 2046Dated: 01/08/2025

1. Name & Address of Ind. / Unit
2. Sampling location
3. Date of Sampling
4. Sample analyzed and results
5. Parameters analyzed and result

MANGOLPURI CETP (2.4 MLD)

Inlet and Outlet of CETP

09.07.2025

DPCC LAB

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.4	5.5-9.0	7.3	6-9	6.94
2	TSS	240	600	32	100	5.7
3	COD	400	750	64	250	56.7
4	BOD (3 days at 27° C)	160	300	20	30	9.7
5	Oil & Grease	20	20.0	1.2	10.0	-
6	Ammonical Nitrogen as N	8.4	50	4.1	50	-
7	Sulphide	2.6	5.0	1.1	2.0	-
8	Phosphate	2.2	15.0	0.1	5.0	-

All values are in mg/l except pH

Flow: 1.501 MLD

I/C Water Laboratory

Scientist B/Analyst

Dr. Shweta Gupta
Incharge (Water Laboratory)



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



ANALYSIS REPORT OF MAYAPURI CETP (12 MLD) FOR THE MONTH OF JULY 2025


Report Number: DPCC/W/CETP/25-26/49/2047

Dated: 01/08/2025

1. Name & Address of Ind. / Unit : MAYAPURI CETP (12 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 14.07.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.5	5.5-9.0	7.3	6-9	8.01
2	TSS	212	600	40	100	15.0
3	COD	408	750	56	250	56.1
4	BOD (3 days at 27° C)	170	300	26	30	7.3
5	Oil & Grease	10.8	20.0	3.2	10.0	-
6	Ammonical Nitrogen as N	32.6	50	10.8	50	-
7	Sulphide	4.0	5.0	2.6	2.0	-
8	Phosphate	4.1	15.0	0.4	5.0	-

All values are in mg/l except pH
Flow: 3.687 MLD


I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)


Scientist B /Analyst

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)

**ANALYSIS REPORT OF NARAINA CETP (21.6 MLD) FOR THE MONTH OF JULY 2025**


Report Number: DPCC/W/CETP/25-26/50/2048

Dated: 01/08/2025

1. Name & Address of Ind. / Unit : NARAINA CETP (21.6 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 14.07.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.5	5.5-9.0	7.1	6-9	7.16
2	TSS	220	600	34	100	16.9
3	COD	360	750	72	250	47.2
4	BOD (3 days at 27° C)	160	300	30	30	9.91
5	Oil & Grease	15.2	20.0	1.6	10.0	-
6	Ammonical Nitrogen as N	35.3	50	6.2	50	-
7	Sulphide	3.9	5.0	3.4	2.0	-
8	Phosphate	3.1	15.0	0.3	5.0	-

All values are in mg/l except pH
FLOW: 5 MLD


I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)


Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



ANALYSIS REPORT OF BADLI CETP (12 MLD) FOR THE MONTH OF JULY 2025

Report Number: DPCC/W/CETP/25-26/51/2049

Dated: 01/08/2025

- | | |
|-----------------------------------|--------------------------|
| 1. Name & Address of Ind. / Unit | BADLI CETP (12 MLD) |
| 2. Sampling location | Inlet and Outlet of CETP |
| 3. Date of Sampling | 15.07.2025 |
| 4. Sample analyzed and results | DPCC LAB |
| 5. Parameters analyzed and result | |

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.9	5.5-9.0	7.2	6-9	8.25
2	TSS	230	600	50	100	9.9
3	COD	472	750	120	250	36.1
4	BOD (3 days at 27° C)	170	300	28	30	13.2
5	Oil & Grease	14.4	20.0	2.4	10.0	-
6	Ammonical Nitrogen as N	12.4	50	5.9	50	-
7	Sulphide	4.1	5.0	1.5	2.0	-
8	Phosphate	2.0	15.0	0.1	5.0	-

All values are in mg/l except pH

Flow: - 2.161 MLD

I/C Water Laboratory

Scientist B /Analyst

Dr. Shweta Gupta
Incharge (Water Laboratory)



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



ANALYSIS REPORT OF LAWRENCE ROAD CETP (12 MLD) FOR THE MONTH OF JULY 2025

Report Number: DPCC/W/CETP/25-26/52/2050


Dated: 01/08/2025

1. Name & Address of Ind. / Unit : LAWRENCE ROAD (12 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 15.07.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS*
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.7	5.5-9.0	7.5	6-9	OLMS was Non-functional
2	TSS	176	600	32	100	
3	COD	360	750	60	250	
4	BOD (3 days at 27° C)	160	300	26	30	
5	Oil & Grease	14.8	20.0	3.6	10.0	
6	Ammonical Nitrogen as N	17.1	50	3.2	50	
7	Sulphide	3.4	5.0	2.4	2.0	
8	Phosphate	1.3	15.0	0.2	5.0	

All values are in mg/l except pH

Flow: 1.623MLD


I/C Water Laboratory


Scientist B / Analyst

Dr. Shweta Gupta
Incharge (Water Laboratory)