



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/203/5282

Dated: 05/01/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2022

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 28.12.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	Ph-I,II (20)	Inlet	6.8	328	135	240	26.4	27.8	18.8	Not meeting the standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.3	30	15	76	4.8	4.5	3.4	
		OLMS	7.6	37.38	23.51	139.31	-	54.41	-	
2	Ph-III (70)	Inlet	6.9	240	120	296	12.4	32.2	30	Meeting the standards.
		Outlet	7.3	8	6	36	2.8	3.8	1.2	
		OLMS	-	-	-	-	-	-	-	
Total 90										OLMS was non functional

N. Mishra

Dr. NANDITA MOTIRA
I/C LABORATORY
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/204/S2 83

Dated: 05/01/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2022

1. Name of STP : Delhi Gate (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.12.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results :										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	Phase-I,II(15)		6.5-9.0	10	10	50	10	5	2	Meeting the Standards.
		Inlet	7.4	212	105	208	25.6	30.2		
		Outlet	7.2	8	4	32	1.6	2.7	1.5	
		OLMS	7.5	5.98	5.33	25.92	-	0.08	-	
Total 15										
Mishra I/C LABORATORY										

N. Motira
I/C LABORATORY

Dr. NANDITA MOTIRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/205/S 284

Dated: 05/01/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2022

1. Name of STP : Delhi Gate (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.12.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
	Phase-I,II(2.2)	Inlet	7.5	220	110	240	21.2	26.8	12.8	Meeting the Standard.
		Outlet	7.1	10	6	36	2.8	4.6	1.4	
		OLMS	7.3	6.78	3.83	16.90	-	1.61	-	
Total 2.2										

N. Motira

I/C LABORATORY

Dr. NANDITA MOTIRA

Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/206/S285

Dated: 05/01/2023


ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2022

1. Name of STP : Keshopur STP (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 12.12.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	12	Inlet	6.5-9.0	10	10	50	10	5	2	Not Meeting the standards wrt TSS & COD
		Outlet	7.4	272	126	344	28.4	17.5	15.4	
		OLMS	7	14	10	60	0.8	1.4	1.2	
		Total 12	7.6	6.49	4.34	30.16	-	2.97	-	

Nandita

I/C LABORATORY
Dr. NANDITA MOTIRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/207) 5286


Dated: 05/01/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2022

1. Name of STP : SEN Nursing Home (SNH)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.12.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P(mg/l) 2	
1	Phase-I,II (2.2)	Inlet	7.5	240	102	184	28.4	30.4	22.8	Meeting the Standards
		Outlet	7	8	6	20	2.8	2.6	1.6	
		OLMS	7.0	7.8	3.77	28.18	-	1.78	-	
Total 2.2										

N. Motira
I/C LABORATORY
Dr. NANDITA MOTIRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/208 | 5289

Dated: 05/01/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2022

1. Name of STP : Nilothi New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 12.12.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results :										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	20		6.5-9.0	10	10	50	10	5	2	Meeting the standards
		Inlet	7.2	152	110	208	26.4	28	7.5	
		Outlet	7.4	10	8	36	0.8	2.6	1.6	
		OLMS	7.4	5.58	3.19	27.26	-	2.17	-	
Total 20										

Dr. NANDITA MOTIRA
IC LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/209/5288


Dated: 05/01/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2022

1. Name of STP : Nilothi
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 12.12.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results :										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P(mg/l) 2	
1	40	Inlet	7.6	256	120	240	16.4	22.4	19.5	Not meeting the standards wrt TSS, BOD, COD & Ammonical Nitrogen.
		Outlet	7.3	60	42	152	5.6	8.6	1.2	
		OLMS	7.6	71.94	53.63	232.46	-	12.14	-	
Total 40										

N. Mitra
Dr. NANDITA MOTIPA
I/C LABORATORY
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/22-23/210/5289

Date : 05/01/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2022

1. Name of STP : Najafgarh
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 12.12.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results :										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	5		6.5-9.0	10	10	50	10	5	2	Not meeting the standards wrt TSS, BOD & COD.
		Inlet	7.8	220	80	254	23.6	20.2	17.8	
		Outlet	7.3	22	16	52	3.2	4.2	1.4	
		OLMS	7.6	22.50	16.50	89.70	-	10.44	-	
Total 5										

N. Motira

I/C LABORATORY

Dr. NANDITA MOTIRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/211/5290


Dated: 05/01/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2022

1. Name of STP : Rithala
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 01.12.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	Phase-I(40)	Inlet	6.5-9.0	10	10	50	10	5	2	Plant was under Rehabilitation
		Outlet	-	-	-	-	-	-	-	
		OLMS	-	-	-	-	-	-	-	
2	Ph-II(40)	Inlet	7.2	156	80	224	28.4	18.2	19.8	Meeting the Standards.
		Outlet	7.3	10	8	44	1.6	4.0	1.5	
		OLMS	7.4	12.56	8.87	27.12	-	5.65	-	
Total 80										

N. Mitta
Dr. NANDITA MISHRA
I/C LABORATORY
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/212 /S291


Dated: 05/01/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2022

1. Name of STP : Pappankalan (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.12.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	20	Inlet	7.6	196	82	190	19.2	21.8	16.2	Not meeting the Standards wrt TSS, BOD COD, Ammonical Nitrogen & Dissolved Phosphate.
		Outlet	7.2	38	20	60	4.8	5.6	2.4	
		OLMS	7.4	37.29	25.49	163.97	-	15.9	-	
Total 20										

N. Mishra
I/C LABORATORY
Dr. NANDITA MOTIRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/213 15292


Dated : 05/01/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2022

1. Name of STP : Pappankalan Ph-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.12.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results :										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
	20	Inlet	6.5-9.0	10	10	50	10	5	2	Meeting the Standards.
		Outlet	7.4	160	40	320	18.4	18.6	16.5	
		OLMS	7.3	10	8	32	2.4	3.4	1.6	
Total 20			7.3	7.29	4.03	29.92	-	2.71	-	

N. Motira
I/C LABORATORY
DR. NANDITA MOTIRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/22-23/214 | 5293

Dated: 05/01/2023


ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2022

1. Name of STP : Rohini
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 01.12.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results :										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	15	Inlet	6.5-9.0	10	10	50	10	5	2	Not meeting the Standards wrt TSS, BOD, COD, Ammonical Nitrogen & Dissolved Phosphate.
		7.4	228	96	288	18	24.5	34.8		
		Outlet	7.5	26	20	56	4.4	6.8	3.1	
		OLMS	7.6	18.16	14.44	76.87	-	13.56	-	
Total 15										

N. Motira
I/C LABORATORY

Dr. NANDITA MOTIRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/215)5294

Dated: 05/01/2023


ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2022

1. Name of STP : Narela
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.12.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	10	Inlet	7.5	288	90	176	4.4	28.6	22.8	Not meeting the standards wrt TSS, BOD & Dissolved Phosphate
		Outlet	7.3	34	16	44	2	2.6	2.4	
		OLMS	-	-	-	-	-	-	-	OLMS was non functional
Total 10										

Nandita
I/C LABORATORY

Dr. NANDITA MOTIRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/216/5295

Dated: 05/01/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2022


1. Name of STP : Okhla New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 15.12.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	30	Inlet	7.6	180	105	220	16.8	25.8	19.8	Not Meeting the Standards w.r.t TSS & BOD.
		Outlet	7.4	16	14	32	1.2	3.8	1.6	
		OLMS	7.2	8.64	4.49	23.15	-	1.11	-	
	Total 30									

Mittra

I/C LABORATORY

DR. NANDITA MOTIRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Dated: 05/01/2023

Report Number: DPCC/W/STP/22-23/217/S296

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2022

1. Name of STP : Kondli
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.12.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	Ph-I (10)	Inlet	7.4	236	125	296	27.6	42.8	32.6	Not meeting the standards wrt TSS.
		Outlet	7.0	12	8	40	1.6	3	1.6	
		OLMS	7.8	6.09	5.53	16.40	-	4.9	-	
2	Ph-III (10)	Outlet	7.3	14	10	36	1.6	2.8	1.8	Not meeting the standards wrt TSS.
		OLMS	-	-	-	-	-	-	-	OLMS was found locked
Total 20										

N. Mishra

I/C LABORATORY
Dr. NANDITA MOTIRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/218/5297

dated: 05/01/2023


ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2022

1. Name of STP : Kondli New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.12.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results :										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	45	Inlet	7.5	328	190	344	25.2	40.2	35.4	Not Meeting the Standards wrt TSS, BOD, COD, Ammonical nitrogen & Dissolved Phosphate.
		Outlet	7.2	148	85	200	7.6	16.8	15.8	
		OLMS	-	-	-	-	-	-	-	
Total 45										OLMS was non functional

N. Motira
I/C LABORATORY

Dr. NANDITA MOTIRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/219 15298

Dated: 05/01/2023


ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2022

1. Name of STP : Kapasahera
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.12.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	5	Inlet	6.7	152	76	168	6.8	33.8	19.8	Meeting the standards
		Outlet	7.5	10	8	20	2.4	3.4	1.6	
		OLMS	7.5	8.98	6.43	30.38	-	4.95	-	
Total 5										

Mittra
I/C LABORATORY

DR. SANDITA MOTIRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/220/5299

Dated: 05/01/2023


ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2022

1. Name of STP : Yamuna Vihar Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.12.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	25		6.5-9.0	10	10	50	10	5	2	Not meeting the Standards wrt TSS, BOD & COD.
		Inlet	7.4	252	120	380	15.6	22.8	22.4	
		Outlet	7.2	24	16	76	2.4	2.8	1.5	
		OLMS	7.2	15.46	7.61	31.39	-	9.14	-	
Total 25										

Nandita
I/C LABORATORY

Dr. NANDITA MOTIRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/221/5300

Dated: 05/01/2023


ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2022

1. Name of STP : Chilla
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.12.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results :										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	9	Inlet	6.5-9.0	10	10	50	10	5	2	Not Meeting the Standards wrt TSS.
		Outlet	7.5	192	98	208	18.4	30	22.8	
		OLMS	7.2	14	10	32	3.2	3.3	1.4	
		Total 9	7.4	12.92	5.2	41.5	-	0.86	-	

N. Motira

I/C LABORATORY
Dr. NANDITA MOTIRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/222/5301

Dated: 05/01/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2022

1. Name of STP : Akshardham
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.12.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	1	Inlet	7.6	192	100	176	24.8	22.4	17	Meeting the Standards.
		Outlet	7.2	4	2	12	0.4	2.4	1.4	
		OLMS	7.2	0.53	1.06	8.50	-	0.26	-	
Total 1										

N. Motira
I/C LABORATORY

Dr. NANDITA MOTIRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/223/5302

Dated: 05/01/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2022

1. Name of STP : Mehrauli
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 07.12.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	15		6.5-9.0	10	10	50	10	5	2	Not meeting the standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Inlet	7.8	236	105	248	19.2	26.2	37.2	
		Outlet	7.3	44	28	64	3.2	2.8	3.2	
		OLMS	7.2	15.02	7.15	44.91	-	2.94	-	
Total 15										

N. Mishra
Dr. NANDITA MOTIPA
I/C LABORATORY
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/224/5303


Date: 05/01/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2022

1. Name of STP : Vasant Kunj
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 07.12.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results :										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	2.2	Inlet	6.5-9.0	10	10	50	10	5	2	Not meeting the standards wrt TSS, Dissolved Phosphate
		Outlet	7.6	252	115	224	34.4	25.8	45.8	
		OLMS	7.2	16	10	36	2.8	3.8	2.9	
2	3	Inlet	7.6	10.12	5.07	28.41	-	3.86	-	Not meeting the standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.4	232	110	240	14.8	26.5	35.8	
		OLMS	7.3	24	14	64	2.4	3.2	3	
Total 5.2			7.3	6.91	3.61	27.20	-	9.35	-	

N. Mishra
Dr. NANDITA MOTILAL
SCIENTIST 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/225/5304


Dated: 05/01/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2022

1. Name of STP : Yamuna Vihar
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.12.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results :										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	10 Ph-1	Inlet	6.5-9.0	10	10	50	10	5	2	Not meeting the standards wrt TSS, BOD & COD.
		Outlet	7.6	96	58	128	14.4	28.9	20.8	
		OLMS	7.4	22	15	56	3.6	3.5	1.8	
2	10 Ph-2	Inlet	7.3	6.15	4.30	24.60	-	13.07	-	Not meeting the standard wrt TSS, BOD,COD & Dissolved Phosphate.
		Outlet	7.4	112	75	192	19.6	25.8	12.4	
		OLMS	7.3	24	18	56	2.4	3.5	2.2	
Total 20			7.2	10.49	9.25	47.84	-	9.20	-	

Nandita
Dr. NANDITA MOTRA
SCIENTIST 'C'
LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/09/305

Date: 05/01/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2022

1. Name of STP : Molarband (Mini STP)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 15.12.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results :										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	0.66	Inlet	6.5-9.0	10	10	50	10	5	2	Not meeting the Standards wrt TSS, BOD, COD & Dissolved phosphate. OLMS was non functional
		Outlet	7.6	296	125	244	22.4	18.5	18.4	
		OLMS	7.2	24	18	76	3.6	2.4	2.8	
Total 0.66										

N. Motira
I/C LABORATORY
Dr. NANDITA MOTIRA
Scientist C



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/226/5306

Dated: 05/01/2023


ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2022

1. Name of STP : Okhla
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 15.12.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P(mg/l) 2	
1	12	Inlet	7.5	216	95	284	16.8	27.8	18.9	Not meeting the Standards wrt TSS, BOD & COD.
		Outlet	7.2	20	16	56	3.2	3.8	1.8	
		OLMS	8.0	26.52	12.24	30.60	-	1.08	-	
	16	Outlet	7.3	18	16	32	3.6	4.8	2.9	Not meeting the Standards wrt TSS, BOD & Dissolved Phosphate
		OLMS	6.9	6.08	3.06	14.53	-	5.67	-	
	37	Outlet	7.4	16	12	40	2.0	4.5	2.6	Not meeting the Standards wrt TSS, BOD & Dissolved Phosphate.
		OLMS	-	-	-	-	-	-	-	
	45	Outlet	7.6	18	15	44	2.4	2.9	1.7	OLMS was non functional Not meeting the Standards wrt TSS & BOD.
		OLMS	6.5	16.00	9.0	42.0	-	0.84	-	
	Total 110									

N. Mishra

I/C LABORATORY
Dr. NANDITA MOTIRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/227/5307

Dated: 05/01/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2022

1. Name of STP : Keshopur
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 12.12.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results :										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	40	Inlet	6.5-9.0	10	10	50	10	5	2	Not meeting the Standards wrt TSS, BOD & COD.
		Outlet	7.8	132	62	216	16.4	20.0	14.5	
		OLMS	7	42	30	84	2.4	3.4	1.6	
2	20	Inlet	7.2	93	70	233	-	35.10	-	Not meeting the Standards wrt TSS, BOD & COD.
		Outlet	7.8	132	62	216	16.4	20.0	14.5	
		OLMS	7.5	58	30	84	5.2	4.5	1.2	
Total 60			6.9	101.28	76.01	323.05	-	20.01	-	

Mittra
I/C LABORATORY

Dr. NANDITA MOTIRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/228/5308

Dated: 05/01/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2022

1. Name of STP : Ghitorini
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 07.12.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	5		6.5-9.0	10	10	50	10	5	2	Not meeting the Standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Inlet	7.6	100	50	188	6.4	33.4	43.2	
		Outlet	7.4	24	18	56	1.8	3.2	2.5	
		OLMS	7.4	21.62	12.98	43.25	-	8.69	-	
Total 5										

N. Motira
Dr. NANDITA MOTIRA
Scientist 'C'