



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/175

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER- 2019

1. Name & Address of Ind./Unit **Akshardham STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **14.10.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters		Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
						COD (mg/l)	Oil & Grease (mg/l)			
				10	10	250	10	50	5	
1	1	Inlet	7.8	120	95	236	20.4	20.6	6.7	Meeting the Standards.
		Outlet	8.0	2	1.2	8	ND	ND	ND	
		OLMS*	7.99	5.65	3.86	15.87	-	1.13	-	
	Total 1									

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/156

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER- 2019

- 1 Name & Address of Ind./Unit **Coronation Pillar STP**
- 2 Sampling location **Inlet and Outlet of STP**
- 3 Date of Inspection **18.10.19**
- 4 Samples collected by **DPCC Lab**
- 5 Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				50	30	250	10	50	5	
1	Ph-I,II(20)	Inlet	7.6	268	210	580	29.6	33.8	7.2	Not meeting the standards w.r.t to BOD.
		Outlet	7.9	50	32	80	4.0	20.1	4.9	
		OLMS*	7.99	18	14.03	47.92	-	1.40	-	
	Ph-III(10)	Inlet	7.7	320	230	620	32.8	35.6	7.6	Not meeting the w.r.t TSS and BOD.
		Outlet	7.9	62	42	116	6.0	22.4	4.6	
		OLMS*	7.34	50.28	40.36	79.55	-	19.28	-	
	Total 30									

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/158

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER- 2019

1. Name & Address of Ind./Unit **DELHI GATE STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **14.10.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	250	10	50	5	
1	Phase-I,II(2.2)	Inlet	7.6	144	90	236	24.4	21.2	7.6	Meeting the Standards.
		Outlet	7.4	10	6	24	0.4	4.6	2.3	
		OLMS*	7.70	9.85	6.01	15.93	-	2.66	-	
	Total 2.2									

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/159

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER- 2019

1. Name & Address of Ind./Unit **Keshopur STP new**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **22.10.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				30	20	250	10	50	5	
1	12	Inlet	7.8	168	110	290	16.4	23.6	6.9	Not meeting the Standards w.r.t TSS and BOD.
		Outlet	7.9	46	30	96	2.0	14.8	3.4	
		OLMS*	-	-	-	-	-	-	-	
	Total 12									

Remarks: OLMS was found non-operational

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/160

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER- 2019

1. Name & Address of Ind./Unit
Sen Nursing Home (SNH)
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
14.10.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	250	10	50	5	
1	Phase-I,II(2.2)	Inlet	7.7	236	190	380	25.6	35.3	7.9	Meeting the Standards.
		Outlet	7.3	4	2	8	0.4	2.3	0.6	
		OLMS*	-	-	-	-	-	-	-	
	Total 2.2									

Remarks: OLMS was found under maintenance

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/161

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER- 2019

1. Name & Address of Ind./Unit **Nilothi STP-II**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **22.10.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	250	10	50	5	
1	20	Inlet	7.9	248	175	320	25.6	30.6	6.8	Not meeting the Standards w.r.t TSS and BOD.
		Outlet	7.5	16	14	36	1.2	7.1	1.6	
		OLMS*	7.60	7.79	6.03	20.04	-	1.62	-	
	Total 20									

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/162

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER- 2019

1. Name & Address of Ind./Unit **Nilothi STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **22.10.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	250	10	50	5	
1	40	Inlet	7.6	268	180	368	36.4	32.6	7.3	Not meeting the Standards w.r.t TSS and BOD.
		Outlet	7.8	36	24	52	2.4	12.4	2.5	
		OLMS*	7.4	56.29	44.20	132.86	-	3.89	-	
	Total 40									

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/168

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER- 2019

1. Name & Address of Ind./Unit Narela STP
2. Sampling location Inlet and Outlet of STP
3. Date of Inspection 14.10.19
4. Samples collected by DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters		Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
						COD (mg/l)					
				50	30	250		10	50	5	
1	10	Inlet	7.7	252	152	328		26.8	37.2	8.3	Meeting the Standards.
		Outlet	7.6	32	26	92		2.0	18.6	4.5	
		OLMS*	7.80	44.89	32.84	83.31		-	5.05	-	
	Total 10										

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/169

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER- 2019

1. Name & Address of Ind./Unit **Okhla STP New**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **17.10.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	250	10	50	5	
1	30	Inlet	7.9	176	140	380	20.4	32.8	7.1	Meeting the Standards.
		Outlet	7.6	8	4	16	0.4	4.6	2.6	
		OLMS*	7.45	7.88	5.82	23.45	-	1.55	-	
	Total 30									

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/170

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER- 2019

1. Name & Address of Ind./Unit **Kondli STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **14.10.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	250	10	50	5	
1	25	Inlet	7.8	160	120	288	20.4	25.8	7.1	Not meeting the Standards w.r.t TSS and BOD.
		Outlet	7.5	20	12	32	2.8	15.6	2.6	
		OLMS*	7.99	14.58	11.74	38.67	-	3.38	-	
	Total 25									

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/163

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER- 2019

1. Name & Address of Ind./Unit **Najafgarh STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **18.10.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters		Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
						COD (mg/l)	Oil & Grease (mg/l)			
				50	30	250	10	50	5	
1	5	Inlet	7.6	308	220	600	31.6	34.6	8.0	Not meeting the Standards w.r.t BOD.
		Outlet	7.4	46	32	84	4.4	15.6	4.0	
		OLMS*	7.45	40.19	52.32	116.11	-	4.00	-	
	Total 5									

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/164

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER- 2019

1. Name & Address of Ind./Unit **Rithala STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **14.10.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
						COD (mg/l)				
				50	30	250	10	50	5	
1	Phase-I(40)	Inlet	7.9	248	165	428	26.4	36.4	8.6	Not meeting the standards w.r.t to TSS and BOD.
		Outlet	7.7	86	42	136	4.0	20.6	5.1	
		OLMS*	-	-	-	-	-	-	-	
2	Ph-II(40)	Inlet	7.9	248	165	428	26.4	36.4	8.6	Meeting the standards.
		Outlet	7.6	24	16	76	2.4	14.3	4.0	
		OLMS*	-	-	-	-	-	-	-	
	Total 80									

Remarks: OLMS Calibration was not done.

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/165

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER- 2019

1. Name & Address of Ind./Unit **Pappankalan STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **18.10.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				50	30	250	10	50	5	
1	20	Inlet	8.1	264	215	592	28.6	30.6	6.9	Not meeting the Standards w.r.t TSS and BOD.
		Outlet	8.0	64	46	108	4.8	21.6	3.6	
		OLMS*	7.89	21.17	35.79	100.46	-	2.7	-	
	Total 20									

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/166

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER- 2019

1. Name & Address of Ind./Unit Pappankalan STP-II
2. Sampling location Inlet and Outlet of STP
3. Date of Inspection 18.10.19
4. Samples collected by DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	250	10	50	5	
1	20	Inlet	7.6	276	220	536	20.0	32.8	6.8	Not meeting the Standards w.r.t TSS and BOD.
		Outlet	7.1	52	46	120	5.2	19.8	3.4	
		OLMS*	7.60	46.13	38.17	107.61	-	4.28	-	
	Total 20									

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/167

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER- 2019

1. Name & Address of Ind./Unit **Rohini STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **14.10.19**
4. Samples collected by **DPCC Lab**

5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	250	10	50	5	
1	15	Inlet	7.8	264	160	336	27.2	35.6	8.4	Not meeting the Standards w.r.t TSS and BOD.
		Outlet	7.5	42	36	112	3.2	16.4	4.3	
		OLMS*	-	-	-	-	-	-	-	
	Total 15									

Remarks: OLMS was found locked

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/171

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER- 2019

1. Name & Address of Ind./Unit **Kondli STP New**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **14.10.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	250	10	50	5	
1	45	Inlet	7.7	200	160	348	22.4	26.8	6.3	Not meeting the Standards w.r.t TSS and BOD.
		Outlet	7.8	26	14	44	3.6	16.8	2.9	
		OLMS*	7.83	17.82	14.07	47.06	-	2.41	-	
	Total 45									

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/172

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER- 2019

1. Name & Address of Ind./Unit **Kapashera STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **23.10.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	250	10	50	5	
1	5	Inlet	7.9	164	120	320	24.4	36.5	6.7	Not meeting the Standards w.r.t TSS and BOD.
		Outlet	8.1	28	20	64	2.4	10.6	1.8	
		OLMS*	7.89	25.42	17.63	55.29	-	4.36	-	
	Total 5									

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi)
4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/173

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER- 2019

1. Name & Address of Ind./Unit **Yamuna Vihar STP Ph-III**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **14.10.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				30	20	250	10	50	5	
1	25	Inlet	7.5	348	260	640	32.8	36.4	8.1	Not meeting the Standards w.r.t TSS and BOD.
		Outlet	7.3	60	42	124	6.4	18.6	4.9	
		OLMS*	7.87	29.05	26.04	75.98	-	5.62	-	
	Total 25									

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/174

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER- 2019

1. Name & Address of Ind./Unit **Chilla STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **14.10.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
				10	10	250	10	50	5	
1	9	Inlet	7.6	296	210	540	32.4	37.6	8.1	Not meeting the Standards w.r.t TSS and BOD.
		Outlet	7.2	20	12	36	2.4	6.1	1.8	
		OLMS*	7.8	14.39	12.21	35.89	-	4.04	-	
	Total 9									

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/176

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER- 2019

1. Name & Address of Ind./Unit **Mehrauli STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **15.10.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
				50	30	250	10	50	5	
1	15	Inlet	7.9	232	195	484	25.6	31.8	6.9	Not meeting the Standards w.r.t BOD.
		Outlet	7.7	46	32	96	4.0	10.6	3.4	
		OLMS*	7.89	39.28	27.45	81.55	-	3.59	-	
	Total 15									

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/177

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER- 2019

1. Name & Address of Ind./Unit **Vasant Kunj STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **15.10.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				50	30	250	10	50	5	
1	2.2	Inlet	7.6	196	140	316	22.4	21.6	6.2	Meeting the Standards
		Outlet	7.4	16	12	40	1.2	11.3	2.8	
		OLMS*	-	-	-	-	-	-	-	
	3	Inlet	7.9	220	160	360	21.6	22.8	5.8	Meeting the Standards
		Outlet	7.5	12	8	24	0.8	6.9	1.7	
		OLMS*	-	-	-	-	-	-	-	
	Total 5.2									

Remarks: OLMS was found locked

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/178

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER- 2019

1. Name & Address of Ind./Unit **Yamuna Vihar STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **14.10.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				50	30	250	10	50	5	
1	10	Inlet	7.6	316	265	660	29.6	34.8	7.9	meeting the Standards.
		Outlet	7.2	44	30	76	4.4	18.1	3.9	
		OLMS*	7.40	63.95	144.21	48.06	-	5.09	-	
2	10	Inlet	7.8	344	290	680	32.0	37.8	8.3	Not meeting the Standards w.r.t TSS and BOD
		Outlet	7.4	58	36	88	6.0	17.9	4.6	
		OLMS*	-	-	-	-	-	-	-	
	Total 20									

Remarks: OLMS was found in non-operational condition

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/07

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER- 2019

1. Name & Address of Ind./Unit **Molarband mini STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **17.10.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				50	30	250	10	50	5	
1	2	Inlet	7.9	220	165	400	26.4	36.6	3.2	Meeting the Standards.
		Outlet	8.0	40	26	72	4.0	16.8	6.9	
		OLMS*	8.0	48.49	26.21	69.34	-	2.46	-	
	Total 2									

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/179

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER- 2019

1. Name & Address of Ind./Unit **Okhla STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **17.10.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

5. Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				50	30	250	10	50	5	
1	12	Inlet	7.8	112	85	240	16.4	28.8	5.6	Meeting the Standards
		Outlet	7.4	22	16	40	1.6	9.8	1.8	
		OLMS	8.02	26.69	12.01	31.87	-	2.65	-	
	16	Outlet	7.3	20	12	32	1.2	8.6	2.8	Meeting the Standards
		OLMS	7.95	15.49	14.08	39.61	-	2.62	-	
	37	Outlet	7.4	30	22	60	2.0	24.2	3.2	Meeting the Standards
		OLMS	7.90	26.08	18.13	56.52	-	2.72	-	
	45	Outlet	7.5	34	26	64	2.8	26.8	3.6	Meeting the Standards
		OLMS	7.50	37.12	27.08	90.39	-	3.2	-	
Total 110										

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/180

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER- 2019

1. Name & Address of Ind./Unit **Keshopur STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **22.10.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				50	30	250	10	50	5	
1	40	Inlet	7.9	300	260	620	34.4	36.4	7.6	Not meeting the Standards w.r.t TSS and BOD.
		Outlet	8.0	84	56	132	6.4	22.4	3.6	
		OLMS*	-	-	-	-	-	-	-	
2	20	Inlet	7.9	300	260	620	34.4	36.4	7.6	Not meeting the Standards w.r.t TSS and BOD
		Outlet	7.9	78	52	116	4.4	16.8	3.2	
		OLMS*	6.89	58.15	48.13	133.40	-	5.7	-	
	Total 60									

Remarks: OLMS (40 MGD) was found non operational

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/181

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER- 2019

1. Name & Address of Ind./Unit **Oxidation pond STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **18.10.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				50	30	250	10	50	5	
	6	Inlet	-	-	-	-	-	-	-	Non- operational due to under rehabilitation.
		Outlet	-	-	-	-	-	-	-	
		OLMS*	-	-	-	-	-	-	-	
	Total 6									

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT