

DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/04/2606

Date: 19/10/2020


ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2020

1. Name & Address of Ind./Unit : Molarband Mini STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.09.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	0.66	Inlet	7.2	248	210	312	20	23.6	8.6	Not meeting the Standards w.r.t TSS, BOD, COD, A.N & D.P.
		Outlet	7.4	46	32	84	6.4	9.8	3.2	
		OLMS*	7.37	25.82	16.63	45.61	-	4.74	-	
Total 0.66										

N. Mohan
I/C LABORATORY
DR. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/390/2607

Date: 19/10/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2020

1. Name & Address of Ind./Unit : Coronation Pillar STP
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 03.09.2020
4. Samples collected by : DPCC, Lab
5. Parameters analyzed and results :


Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	Ph-I,II(20)	Inlet	7.1	148	75	188	19.6	24.8	7.9	Not meeting the Standards w.r.t BOD, TSS & COD.
		Outlet	7.3	52	32	94	2.8	4.5	1.8	
		OLMS*	-	-	-	-	-	-	-	
2	Ph-III(10)	Inlet	7.0	328	150	348	29.6	36.4	10.6	Not meeting the standards w.r.t TSS, BOD, COD, A.N & Phosphate.
		Outlet	7.1	60	38	124	4.4	6.8	2.3	
		OLMS*	7.0	35.95	28.0	75.94	-	2.24	-	
Total 30										
Remarks: Ph-I OLMS was not working										

Remarks: Ph-I OLMS was not working

Nandita
I/C LABORATORY

SR. SCIENTIFIC ASSISTANT

Dr. NANDITA MOITRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/391/2608

Date: 19/10/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2020


1. Name & Address of Ind./Unit : Delhi Gate STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 07.09.2020
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
						COD (mg/l)				
				10	10	50	10	5	2	
1	Phase-I,II(15)	Inlet	7.2	176	85	204	18.4	23.8	7.6	Meeting the Standards.
		Outlet	7.3	4	2	4	0.4	1.8	0.6	
		OLMS*	-	5.78	2.64	24.70	-	1.45	-	
Total 15										

I/C LABORATORY

Dr. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/392/2609

Date: 19/10/2020


ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2020

1. Name & Address of Ind./Unit : DELHI GATE STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 07.09.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
						COD (mg/l)				
				10	10	50	10	5	2	
1	Phase-I,II(2.2)	Inlet	7.5	192	105	260	21.6	28.4	8.7	Meeting the Standards.
		Outlet	7.6	6	2	8	0.4	2.3	0.9	
		OLMS*	7.43	8.0	4.99	11.99	-	2.97	-	
Total 2.2										

N. Moitra
I/C LABORATORY
Dr. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/393 / 2810 (2610)

Date: 19/10/2020


ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2020

1. Name & Address of Ind./Unit : Keshopur STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.09.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
						COD (mg/l)				
				10	10	50	10	5	2	
1	12	Inlet	7.3	260	160	212	24.8	28.9	9.8	Not Meeting the Standards w.r.t TSS, BOD, COD, A.N & Phosphate
		Outlet	7.4	30	20	68	1.2	11.6	4.1	
		OLMS*	7.19	16.83	15.06	59.30	-	3.01	-	
Total 12										

Maitra
I/C LABORATORY
Dr. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>


Report Number: DPCC/W/STP/20-21/394 | 2611

Date: 19/10/2020


ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2020

1. Sampling location : Inlet and Outlet of STP
2. Name & Address of Ind./Unit : SEN Nursing Home (SNH)
3. Date of Inspection : 07.09.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
						COD (mg/l)				
				10	10	50	10	5	2	
1	Phase-I,II (2.2)	Inlet	7.0	92	40	88	14.4	19.6	7.2	Meeting the Standards.
		Outlet	7.1	4	3	8	0.4	1.6	0.6	
		OLMS*	7.10	60.1	3.0	8.3	-	1.20	-	
Total 2.2										


I/C LABORATORY
Dr. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE (Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/395 / 2612

Date: 19/10/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2020

1. Name & Address of Ind./Unit : Nilothi STP-II
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 16.09.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :


Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	20	Inlet	6.7	140	60	248	22.0	26.9	8.9	Meeting the Standards.
		Outlet	6.8	10	6	28	0.8	1.8	1.4	
		OLMS*	7.30	9.98	6.0	23.92	-	1.69	-	
Total 20										

Nandita

I/C LABORATORY

Dr. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/396/2613

Date: 19/10/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2020


1. Name & Address of Ind./Unit : Nilothei STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 16.09.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	40	Inlet	6.8	160	65	260	16.4	19.6	7.0	Not Meeting the Standards w.r.t TSS, BOD, COD, A.N & Phosphate.
		Outlet	6.9	36	28	76	4.8	6.6	2.8	
		OLMS*	7.31	52.50	33.04	104	-	5.23	-	
Total 40										

I/C LABORATORY

Dr. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/20-21/397/2614

Date: 19/10/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2020


1. Name & Address of Ind./Unit : Najafgarh STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.09.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	5	Inlet	7.2	144	85	296	17.2	22.6	8.1	Not meeting the standards w.r.t to TSS, BOD, COD, A.N & D.P.
		Outlet	7.3	62	40	168	5.2	8.4	2.8	
		OLMS*	7.46	26.31	16.01	40.12	-	4.03	-	
Total 5										

I/C LABORATORY

Dr. NANDITA MOITRA
Scientist C

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/398/2615

Date: 19/10/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2020

1. Name & Address of Ind./Unit : Rithala STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 02.09.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results


1. Parameters analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	Phase-I(40)	Inlet	7.1	228	125	240	22.4	28.6	8.8	Not meeting the standards w.r.t to TSS,BOD,COD.A.N & D.P.
		Outlet	7.0	60	36	120	6.0	8.6	2.5	
		OLMS*	-	-	-	--	-	-	-	
2	Ph-II(40)	Inlet	7.1	228	125	240	22.4	28.6	8.8	Not meeting the standards w.r.t to TSS.
		Outlet	7.1	12	8	32	1.6	3.5	1.2	
		OLMS*	7.43	16.62	8.0	20.07	-	0.80	-	
Total 80										

Remarks-pH-I OLMS was not working.

I/C LABORATORY

Dr. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/399/2616

Date: 19/10/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2020

1. Name & Address of Ind./Unit : Pappankalan STP (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.09.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :


Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	20	Inlet	7.3	236	180	396	36.8	30.4	9.6	Not meeting the Standards w.r.t TSS, BOD, A.N & COD.
		Outlet	7.4	38	26	128	4.4	6.6	1.8	
		OLMS*	-	-	-	-	-	-	-	
Total 20										

Remarks- OLMS was not working

Nandita
I/C LABORATORY

Dr. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/400 | 2617

Date : 19/10/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2020


1. Name & Address of Ind./Unit : Pappankalan STP-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.09.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	20	Inlet	7.3	144	100	280	18.4	22.8	8.8	Meeting the Standards.
		Outlet	7.4	6	4	12	0.4	1.6	0.9	
		OLMS*	-	-	-	-	-	--	-	
Total 20										

Remarks-OLMS was under maintenance.

Maitra
I/C LABORATORY
Dr. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/20-21/401/2618

Date : 19/10/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2020


1. Name & Address of Ind./Unit : Rohini STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 02.09.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	15	Inlet	7.1	412	270	436	36.4	39.4	11.6	Not meeting the Standards w.r.t TSS, BOD, COD, A.N & D.P.
		Outlet	7.2	18	14	52	4.4	8.2	2.8	
		OLMS*	-	-	-	-	-	-	-	
Total 15										

Remarks-OLMS found non-functional.

Nandita
I/C LABORATORY
Dr. NANDITA MOLTRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/402 | 2619

Date: 19/10/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2020


1. Name & Address of Ind./Unit : Narela STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 04.09.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
			10	10	50	10	5	2		
1	10	Inlet	7.0	144	75	284	20.4	24.6	7.7	
		Outlet	7.3	24	18	68	2.0	4.8	2.0	Not Meeting the Standards w.r.t TSS, BOD & COD.
		OLMS*	7.0	19.97	16.14	44.06	-	2.40	-	
Total 10										

Nandita
I/C LABORATORY

Dr. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE (Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/403/2620

Dated: 19/10/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2020


1. Name & Address of Ind./Unit : Okhla STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.09.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	30	Inlet	7.3	304	115	260	28.4	34.6	10.6	Meeting the Standards
		Outlet	7.4	8	6	20	1.6	2.8	0.4	
		OLMS*	7.41	4.31	2.29	17.06	-	1.20	-	
Total 30										

I/C LABORATORY

Dr. NANDITA MONTA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE (Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/404 / 2621

Dated: 19/10/2020


ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2020

1. Name & Address of Ind./Unit : Kondli STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.09.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	25	Inlet	7.3	248	135	296	26.4	28.4	8.9	Not meeting the Standards w.r.t TSS, BOD, COD & D.P.
		Outlet	7.4	32	20	64	3.2	4.6	2.3	
		OLMS*	7.2	16.97	13.83	36.74	-	3.92	-	
Total 25										

Mitra
I/C LABORATORY
Dr. NANDIA MONTRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/405/2622

Dated: 19/10/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2020


1. Name & Address of Ind./Unit : Kondli STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.09.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	45	Inlet	7.3	172	90	212	24.4	36.4	8.6	Not Meeting the Standards w.r.t TSS, BOD & COD.
		Outlet	7.4	32	24	76	1.6	3.2	2.0	
		OLMS*	-	-	-	-	-	-	-	
Total 45										
Remarks: OLMS was found locked.										

Remarks: OLMS was found locked

Nandita
I/C LABORATORY
DR. NANDITA MONTA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/406/2623

Dated: 19/10/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2020


1. Name & Address of Ind./Unit : Kapasahera STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.09.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	5	Inlet	6.9	212	160	360	24.8	28.8	9.2	
		Outlet	7.1	8	4	16	0.8	1.7	1.3	
		OLMS*	7.31	7.88	4.20	15.88	-	1.24	-	Meeting the Standards.
Total 5										

I/C LABORATORY

Dr. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/407 / 2624

Dated: 19/10/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2020

1. Name & Address of Ind./Unit : Yamuna Vihar STP Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 15.09.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :


Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	25	Inlet	7.1	464	290	10.5	28.4	33.4	11.8	Not meeting the Standards w.r.t TSS,BOD,COD & D.P.
		Outlet	7.3	32	24	76	3.6	4.7	3.2	
		OLMS*	7.27	34.01	24.98	89.91	-	4.59	-	
Total 25										

I/C LABORATORY

Dr. NANDITA MOITRA

Scientist 'C'

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/408/2625

Dated : 19/10/2020


ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2020

1. Name & Address of Ind./Unit : Chilla STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.09.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	9	Inlet	7.2	100	75	188	14.8	19.2	7.6	Not meeting the Standards w.r.t TSS.
		Outlet	7.3	12	9	32	0.4	1.1	0.8	
		OLMS*	7.34	7.83	6.1	19.94	-	1.30	-	
Total 9										

Nandita
I/C LABORATORY
Dr. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/409/2626

Dated : 19/10/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2020

1. Name & Address of Ind./Unit : Akshardham STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.09.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :


Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	1	Inlet	7.0	92	70	196	14.4	18.4	7.4	Meeting the Standards.
		Outlet	7.3	8	4	16	0.8	1.3	1.0	
		OLMS*	-	-	-	-	-	-	-	
Total 1										

Remarks: OLMS was not working.

Nandita
I/C LABORATORY
Scientist 'C'

SR. SCIENTIFIC ASSISTANT

Dr. NANDITA MOITRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/410/2627

Dated : 19/10/2020


ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2020

1. Name & Address of Ind./Unit : Mehrauli STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.09.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
	15	Inlet	7.2	128	85	168	15.2	21.6	7.9	Not meeting the standards w.r.t TSS, BOD & COD
		Outlet	7.3	28	18	72	1.6	3.2	1.6	
		OLMS*	7.60	28.87	13.80	39.69	-	4.07	-	
Total 15										

N. Moitra
I/C LABORATORY
Dr. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/411/2628

Dated: 19/10/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2020


1. Name & Address of Ind./Unit Vasant Kunj STP
2. Sampling location Inlet and Outlet of STP
3. Date of Inspection 11.09.20
4. Samples collected by DPCC Lab
5. Parameters analyzed and results:

Parameters analyzed and results:										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	2.2	Inlet	7.1	328	160	440	32.4	35.6	11.4	Not meeting the Standards w.r.t TSS.
		Outlet	7.1	14	10	44	1.2	3.2	1.7	
		OLMS*	7.29	15.96	11.75	31.87	-	2.21	-	
2	3	Inlet	7.1	272	170	320	28.8	32.6	11.4	Not Meeting the Standards w.r.t TSS, BOD & COD.
		Outlet	7.2	26	18	60	2.0	1.8	1.4	
		OLMS*	7.5	20.02	15.98	39.43	-	3.63	-	
Total 5.2										

I/C LABORATORY

Dr. NANDITA MOTTRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/412/2629

Dated : 19/10/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2020


1. Name & Address of Ind./Unit : Yamuna Vihar STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 15.09.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters Analysis and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	2.2	Inlet	6.7	208	110	220	22.4	25.8	9.6	Not Meeting the Standards w.r.t TSS & COD.
		Outlet	7.3	16	10	52	1.6	2.8	1.7	
		OLMS*	7.19	24.85	15.13	55.51	-	2.57	-	
2	3	Inlet	6.7	208	110	220	22.4	25.8	9.6	Not Meeting the Standards w.r.t TSS & D.P.
		Outlet	7.3	14	8	32	2.8	3.7	2.4	
		OLMS*	-	-	-	-	--	-	-	
Total 5.2										

Nandita
I/C LABORATORY

SR. SCIENTIFIC ASSISTANT

Dr. NANDITA MOITRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/413/2630

Date: 19/10/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2020

1. Name & Address of Ind./Unit : Okhla STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.09.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :


Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	12	Inlet	7.0	248	135	264	33.6	29.6	9.1	Not meeting the Standards w.r.t TSS & D.P.
		Outlet	7.2	24	10	40	3.6	4.9	2.2	
		OLMS	6.99	36.43	27.72	75.80	-	1.07	-	
	16	Outlet	7.2	14	12	36	2.4	4.6	2.4	Not meeting the Standards w.r.t TSS, BOD & D.P.
		OLMS	-	-	-	-	-	-	-	
	37	Outlet	7.3	38	34	96	4.4	5.8	2.8	Not meeting the Standards w.r.t TSS, BOD, COD, A.N & D.P.
		OLMS	7.02	27.71	24.15	76.10	-	2.93	-	
	45	Outlet	7.4	32	22	68	2.4	4.5	2.4	Not meeting the Standards w.r.t TSS, BOD & COD & D.P.
		OLMS	7.3	24.94	20.11	58.09	-	2.04	-	
	Total 110									

Remarks: OLMS (16 MGD) was not working.

I/C LABORATORY

DR. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/414/2631

Dated : 19/10/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2020

1. Name & Address of Ind./Unit : Keshopur STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.09.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	40	Inlet	7.1	232	120	380	16.4	19.8	7.9	Not meeting the Standards w.r.t TSS,BOD,COD, A.N & D.P.
		Outlet	7.2	56	40	128	3.6	6.2	2.9	
		OLMS*	7.34	35.10	26.75	68.15	-	3.32	-	
2	20	Inlet	7.1	232	120	380	16.4	19.8	7.9	Not meeting the Standards w.r.t TSS,BOD,COD, A.N & D.P.
		Outlet	7.2	132	72	240	6.8	10.4	3.6	
		OLMS*	7.50	11.38	7.66	21.01	-	2.19	-	
Total 60										

I/C LABORATORY

Dr. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT